

**Beyond Plastics • Beyond Toxics • Breathe Free Detroit
Blue Water Baltimore • California Communities Against Toxics
Chesapeake Climate Action Network • Clean Air Action Network of Glenn Falls
Clean Air Council • CT Coalition for Economic and Environmental Justice
Durham Environment Watch • Earthjustice • Environmental Integrity Project
Global Alliance for Incinerator Alternatives • Ironbound Community Corporation
The Minnesota Environmental Justice Table
South Baltimore Community Land Trust • Zero Waste Ithaca**

June 21, 2022

Submitted online via Federal eRulemaking Portal at <https://www.regulations.gov/>
Administrator Michael Regan
U.S. Environmental Protection Agency

RE: Public Comments on Docket ID No. EPA–HQ–OAR–2021–0668, Federal
Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National
Ambient Air Quality Standard; Proposed Rule, 87 Fed. Reg. 20,036 (April 6, 2022)

Dear Administrator Regan:

The undersigned groups (“Commenters”) write to respectfully urge the U.S. Environmental Protection Agency (“EPA”) to establish new pollution reduction requirements for municipal solid waste combustor units (“MWCs” or “incinerators”) in its final rule addressing the federal implementation plan for interstate ozone transport. Many of our organizations have been working to reduce pollution from incinerators and promote sustainable waste management models for years if not decades. We appreciate the opportunity to submit these comments.¹

I. Background

In EPA’s proposed rule, it requests comment on whether the final rule should include NO_x limits for incinerators in states that cause or contribute to downwind ozone problems.² The ten states that EPA has identified as falling into this category are listed below, although more states may be subject to this requirement if EPA re-evaluates certain assumptions and omissions on which its analysis is based.

¹ These comments are substantively identical to the Municipal Waste Combustors section in the longer set of comments submitted by a coalition of not-for-profit organizations addressing multiple aspects of the proposed rule.

² EPA, Federal Implementation Plan Addressing Regional Ozone Transport for the 2015 Ozone National Ambient Air Quality Standard, Proposed Rule, 87 Fed. Reg. 20036, 20086 (April 6, 2022).

Table 1: States Potentially Subject to Requirements per EPA Analysis³	
California	New Jersey
Indiana	New York
Maryland	Oregon
Michigan	Pennsylvania
Minnesota	Virginia

EPA also poses certain questions about what limit should be imposed, how record-keeping and reporting should be handled, and other matters. Commenters address each of these questions below.

II. EPA Should Establish Limits for Incinerators in the Final Rule

EPA should require NO_x reductions from incinerators in the final rule. These facilities emit high amounts of NO_x, with large MWCs producing more NO_x on average than even coal plants per unit of energy generated, and can achieve far lower NO_x limits than the limits to which most facilities are currently subject. In addition, MWCs are often sited in economically marginalized communities and communities of color, subjecting residents of those neighborhoods to toxic emissions like lead, mercury, and dioxin in addition to NO_x. Finally, large MWCs are already equipped with continuous emissions monitors for NO_x, reducing one aspect of the cost of complying with new standards under a final EPA rule.

A. Incinerators are Very Large NO_x Emitters


Multiple analyses have shown that incinerators emit more NO_x than coal plants per output generated (based on either megawatt-hours generated or heat input).⁴ In 2017, NEI data shows that incinerators emitted about 65% more NO_x per unit of heat input than coal-fired electrical generating units (“EGUs”), with incinerators producing 0.28 lb/MMBtu of NO_x compared with 0.17 lb/MMBtu NO_x from coal plants.⁵ This is illustrated in Figure 1 below.

³ EPA, Technical Support Document (TSD) for the Proposed Rule, Non-EGU TSD (hereinafter “Non-EGU TSD”) at 82-83.

⁴ See, e.g. Environmental Integrity Project, Waste-to-Energy: Dirtying Maryland’s Air by Seeking a Quick Fix on Renewable Energy? October 2011, at 6, <https://environmentalintegrity.org/wp-content/uploads/2016/11/FINALWTEINCINERATORREPORT-101111.pdf>.

⁵ Emission rates were calculated for incinerators and coal-fired power plants using data from EPA’s 2017 National Emission Inventory (NO_x emissions) and the U.S. Energy Information Administration (EIA’s) 923 Monthly Generation and Fuel Consumption Report. The analysis includes data from 53 incinerators and 235 coal-fired power plants. We excluded facilities if less than 90 percent of their net generation was attributable to either municipal solid waste or coal, based on the fuel type reported in EIA, if no NO_x emission data was available, if the facility is a combined heat and power plant (i.e. produces both electricity and salable steam), or if the facility retired before the end of 2017. Some operators report facility data to NEI and EIA differently. For example, the Fort Smallwood EGU complex in Maryland is a single facility in NEI but reported separately as Brandon Shores and H A Wagner in EIA. In these cases, we combined fuel consumption and net generation, and calculated a collective emission rate.

Figure 1



In fact, in many of the nine transport states with both incinerators and EGU emissions budgets, NOx emissions from incinerators equate to a significant percentage of – or even more than – the EGU emission budgets. Comparing 2017 ozone season incinerator emission data from EPA’s Non-EGU TSD⁶ with the Proposed Rule’s 2023 EGU emissions budgets,⁷ New Jersey has *higher* MWC emissions than its entire EGU emission budget, while New York and Maryland have MWC emissions that exceed over half of their EGU emission budgets. By 2026, if EGU emissions reduce under the rule but incinerator emissions remain constant, an additional three states (Minnesota, Pennsylvania, and Virginia) would have incinerator emissions of 20-37% of their EGU emission budgets.

⁶ Non-EGU TSD at 82–83 tbl.8. Commenters have not conducted a comprehensive review of the information presented in Table 8, but we have noticed at least one item that requires correction. The Detroit Renewable Power facility in Michigan ceased operation in 2019. See, e.g., Aguilar, Louis, et. Al. *Detroit’s controversial incinerator permanently shut down*, Detroit News, March 28, 2019, <https://www.detroitnews.com/story/news/local/detroit-city/2019/03/27/detroits-controversial-incinerator-permanently-shutting-down-today/3287589002>.

⁷ 87 Fed. Reg. at 20044 tbl.I.B-1.

Table 2: MWC Emissions Compared to EGU Emission Budgets				
	2017 MWC NO_x Emissions (tons)	Estimated 2017 Ozone Season MWC NO_x Emissions* (tons)	2023 Ozone Season EGU Emission Budget (tons)	2026 Ozone Season EGU Emission Budget (tons)
CA	654.5	268.8	(no EGU budget)	(no EGU budget)
IN	1,122.0	467.5	11,151	7,791
MD	1,542.9	642.9	1,187	1,189
MI	1,554.4	647.7	10,718	6,114
MN	2,279.7	949.9	3,921	2,536
NJ	2,162.1	900.9	799	799
NY	4,679.4	1,949.7	3,763	3,238
OK	518.5	216.0	10,265	4,275
PA	3,759	1,491.2	8,855	6,819
VA	2,071.7	863.2	3,090	2,567

* 2017 Ozone Season MWC NO_x Emissions estimated by multiplying 2017 MWC NO_x Emissions by 5/12.

B. MWCs Harm Environmental Justice Communities

In addition to NO_x, MWCs emit large amounts of health-harming toxic pollutants like lead, mercury, and dioxin into the air, often in economically marginalized communities or communities of color.

A 2019 report by the Tishman Environment and Design Center at The New School found that 79% of U.S. municipal solid waste incinerators are located in environmental justice communities, and that between 67% and 83% of the twelve incinerators that emit the most nitrogen oxides, sulfur dioxide, lead, mercury, particulate matter, and carbon monoxide are located in environmental justice communities, depending on the pollutant.⁸

MWCs are also recognized as large and problematic polluters within communities and states that house incinerators, including the ten states that house MWCs that EPA has identified as linked to downwind ozone impacts. In Maryland, the state's two large MWCs emit substantially more mercury per unit of energy generated than its largest coal-burning plants. In 2020, the Baltimore City large MWC emitted mercury at a rate 37 times higher than that of the average of the state's largest coal and gas-burning plants, while the Montgomery County large MWC emitted mercury at a rate 11 times higher than the fossil fuel-fired plants.⁹ The large MWCs in the environmental justice communities of Newark and Camden, New Jersey, are the

⁸ Ana Isabel Baptista & Adrienne Perovich, *U.S. Municipal Solid Waste Incinerators: An Industry in Decline* at 15 & App. E, Tishman Env't and Design Ctr. (May 2019), https://static1.squarespace.com/static/5d14dab43967cc000179f3d2/t/5d5c4bea0d59ad00012d220e/1566329840732/CR_GaiaReportFinal_05.21.pdf.

⁹ Environmental Integrity Project, Testimony to Maryland House Economic Matters Committee in Support of HB11 at 1, <https://environmentalintegrity.org/wp-content/uploads/2022/05/FINAL-EIP-2022-Testimony.pdf>.

largest stationary-source emitters of NO_x, PM_{2.5}, HCl, lead, and mercury in their respective counties.¹⁰

C. EPA's Rule Must Not Arbitrarily Fail to Regulate MWCs

EPA's failure to include limits for MWCs in its proposed rule is the result of the agency's arbitrary exclusion of MWCs from its screening analysis of non-EGUs. There is no basis for this exclusion, given the high NO_x emissions from MWCs, and EPA must rectify this lapse by including limits for MWCs in the final rule. Further, EPA should not arbitrarily leave small MWCs – those with a waste burning capacity under 250 tons per day – unregulated. EPA should set NO_x limits in the final rule for small MWCs except those whose operators can demonstrate the infeasibility of meeting the limit.

i. EPA Has Arbitrarily Excluded MWCs from its Screening Assessment

EPA's unexplained, unwarranted exclusion of incinerators from its Screening Assessment – and therefore, from any proposed regulation in the proposed rule – is arbitrary, and the final rule must assess and regulate incinerator emissions. EPA's threshold criteria for considering a non-EGU industry sector in its Screening Assessment is that the sector includes “emissions units that emit greater than 100 tons per year (tpy) of NO_x” and that these are “uncontrolled sources or sources that could be better controlled at a reasonable cost.”¹¹ Incinerators meet both these criteria. Over 90% of the incinerators in transport states emit over 100 tpy of NO_x, with a per-facility average of 473 tpy of emissions.¹² And the proposed rule cites findings by the Ozone Transport Commission (“OTC”) that incinerators could be better controlled at costs well within the proposed rule's cost effectiveness threshold.¹³ Incinerators thus easily meet EPA's threshold criteria for the screening assessment.

But instead of analyzing incinerators in the Screening Assessment, EPA baselessly excludes this entire industry from the assessment. The Screening Assessment's only mention of incinerators is an introductory footnote that “[t]he non-EGU ‘sector’ . . . does not include municipal waste combustors (MWC), cogeneration units, or <25 MW EGUs.”¹⁴ EPA provides no explanation of why it entirely excludes an industry that the proposed rule admits “emit[s] substantial amounts of NO_x.” 87 Fed. Reg. at 20085. To the extent that the footnote suggests that EPA does not consider incinerators to be “non-EGUs” because many of them do produce electricity, that is no rationale given that EPA expressly excludes incinerators from its regulation

¹⁰ Earthjustice & Vermont Law School Environmental Advocacy Clinic, *New Jersey's Dirty Secret: The Injustice of Incinerators and Trash Energy in New Jersey's Frontline Communities* at 9, https://earthjustice.org/sites/default/files/files/nj-incinerator-report_earthjustice-2021-02.pdf.

¹¹ 87 Fed. Reg. at 20083.

¹² Non-EGU TSD Table 8 (showing 39 of 43 incinerators with over 100 tpy of NO_x emissions in 2017).

¹³ 87 Fed. Reg. at 20086.

¹⁴ Screening Assessment at 1 n.1.

of EGUs.¹⁵ Just because incinerators share characteristics of both the EGU and non-EGU sectors does not mean that they can avoid regulation altogether.

Indeed, EPA's exclusion of incinerators from the Screening Assessment and from proposed regulation is particularly arbitrary given that incinerators emit *more* NOx than nearly all of the 41 other non-EGU industries that EPA *did* screen and consider. EPA's supporting documents show that incinerators in transport states emit more NOx than what EPA predicts all but seven of the 41 analyzed industry categories emit.¹⁶ And looking at the absolute number of facilities in transport states that emit 100 tpy or more of NOx, incinerators outnumber other categories of facilities for all but five of the other industries analyzed.¹⁷ It is arbitrary for EPA to fail to propose MWC emission limits when it did propose limits on industries with much less NOx impact – EPA must rectify this by including incinerator limits in the final rule.

ii. EPA Should Not Arbitrarily Fail to Set Limits for Small MWCs

EPA should set NOx limits for all MWCs in transport states, including those that do not meet the 250 ton-per-day capacity threshold for large MWCs from CAA Section 129.¹⁸ Congress's choice of capacity threshold between large and small MWCs in Section 129 has no bearing on whether an incinerator must be regulated under the CAA Good Neighbor Provision. And EPA has not promulgated *any* enforceable NOx emission limit for facilities below this threshold under Section 129,¹⁹ so NOx from these smaller facilities will continue to be entirely unregulated unless EPA imposes an emission limit in the final rule. Such an emission limit would increase NOx reductions and capture MWC units with capacity just below the threshold, like New York's MacArthur Waste-to-Energy facility, which has a capacity of 242.2 tons per day.²⁰

Under Commenters' recommended approach, described in Section II.E below, the operators of smaller MWCs will have the opportunity to demonstrate that they are unable to meet

¹⁵ See 87 Fed. Reg. at 20085 (“The electrical output of MWCs is relatively small compared to the EGUs that will be regulated per the proposed requirements of Section VII.B of this proposal, with most MWCs having an electrical output capacity of less than 25 MW.”).

¹⁶ Compare Non-EGU TSD at 81 (“[I]n 2017[,] 20,344 tons of NOx were emitted from MWCs in the ten transport states containing them,” then multiply 20,344 tons by 5/12 to estimate the 5 months of ozone season emissions, yielding 8,476.7 tons), with Screening Assessment at 25 tbl.A-3 (showing only seven industries with “ozone season emissions” in 2023 above 8,476.7 tons).

¹⁷ Compare Non-EGU TSD at 82-83 tbl.8 (listing 39 incinerators in transport states with emissions above 100 tpy) with Screening Assessment at 25 tbl.A-3 (showing only 5 of the 41 industries listed as having more than 39 facilities in transport states that emit over 100 tpy of NOx).

¹⁸ See 42 U.S.C. § 7429(a)(1)(B), (C).

¹⁹ “[W]aste combustion plants with an aggregate plant combustion capacity less than or equal to 250 tons per day of municipal solid waste . . . do not have a nitrogen oxides emission limit.” 40 C.F.R. § 60.1045(a)(2), (b)(1). “No monitoring, testing, recordkeeping, or reporting is required to demonstrate compliance with the nitrogen oxides limit for [these] units.” 40 C.F.R. Pt. 60, Subpt. AAAA, Tbl. 1; see also *id.* Pt. 60, Subpt. BBBB, Tbl. 4 (same).

²⁰ Ozone Transport Commission Stationary and Area Sources Committee, Municipal Waste Combustor Workgroup Report, Revised April 2022, at 40, https://otcair.org/upload/Documents/Reports/MWC%20Report_revised%2020220425.pdf (“Final OTC MWC Report”).

²⁰ *Id.*

the limit at or below EPA's final cost-effectiveness threshold and to accept the lowest possible limit based on that threshold.

D. The Final Rule Should Set a MWC NO_x Limit of 50 ppm on a 24-Hour Average

EPA must set a 24-hour NO_x emission limit of 50 parts per million dry volume @ 7% O₂ ("ppm") for MWCs based on selective catalytic reduction technology, which is the technology needed to ensure this high-emitting sector stops contributing to downwind ozone pollution. In the alternative, EPA should set a 24-hour emission limit no higher than 110 ppm based on less effective, though still widely available, control technology. It has been demonstrated that many kinds of MWCs can meet a 24-hour limit of 110 ppm by operating cost-effective NO_x controls.

i. It is Critical that EPA Set a Short-Term Limit for Incinerators

As a threshold matter, Commenters consider it imperative that EPA establish a NO_x limit for MWCs that is measured on an averaging period of 24 hours or shorter. As described in more detail in the sections below, it has been well demonstrated that almost all large MWCs can meet a much more stringent 24-hour limit than the one to which most units are currently subject. A 24-hour limit will help to reduce the likelihood that the substantial NO_x emissions from MWCs will contribute to a spike in ozone, which is measured on an eight-hour average for the 2015 ozone standard. This is particularly important for MWCs to prevent dangerous, shorter-term spikes in emissions.

ii. EPA Should Establish A 24-Hour NO_x Limit of 50 ppm for MWCs

EPA should establish a 24-hour NO_x limit of 50 ppm based on selective catalytic reduction ("SCR") technology for incinerators. SCR is a widely available technology that, as the proposed rule notes, already is in use in 60% of the coal fleet, and has been considered Best Available Control Technology ("BACT") for decades.²¹ The OTC's revised Municipal Waste Combustor Workgroup Report ("Final OTC MWC Report") – whose prior version is discussed in the proposed rule – notes that the Palm Beach Renewable Energy Facility uses SCR and has a permitted emission limit of 50 ppm – both of which were considered BACT during the permitting process in 2010.²² The Final OTC MWC Report also notes that analyses of installing SCR at three other existing MWCs also assumed emission rates of 50 ppm.²³

The Final OTC MWC Report presents results from third-party studies of SCR installation and use costs of \$10,296/ton to \$12,779/ton (Wheelabrator Baltimore), \$15,898/ton (Covanta Fairfax), and \$31,445/ton (Covanta Alexandria/Arlington).²⁴ While these estimates vary, the lowest estimate (Wheelabrator Baltimore) is most analogous the \$11,000/ton weighted-average cost for new SCRs for coal units that EPA finds acceptable in the proposed rule.²⁵ As described in more detail below, the accuracy of the Wheelabrator Baltimore estimate appears to depend on

²¹ 87 Fed. Reg. at 20,080.

²² Final OTC MWC Report at 60-61.

²³ *Id.*

²⁴ *Id.*

²⁵ 87 Fed. Reg. at 20,081.

what the cost is of operating the current control system on the Baltimore incinerator and we request that EPA ask for information to verify that cost.

These SCR emission controls are necessary to prevent interstate ozone transport, especially from upwind states like New Jersey where incinerators make up a significant percentage of NO_x emissions but where the rule, as proposed, would result in little to no NO_x emission reductions. EPA predicts that New Jersey will continue to significantly contribute to downwind receptors in 2026, with contributions of up to 8.54ppb for downwind nonattainment receptors and 5.47ppb to downwind maintenance receptors that year, higher than the contributions of all but a handful of other states.²⁶ Yet EPA does not propose measures necessary to reduce this contribution, requiring no reductions from New Jersey's non-EGU sector and no reductions in the state's EGU emission budget after 2023.²⁷ EPA should therefore look to emission reductions from incinerators to eliminate New Jersey's significant contributions to interstate ozone. But all four of New Jersey's currently operating incinerators are already equipped with SNCR systems, and the state's two largest incinerators – responsible for nearly 70% of the state's incinerator NO_x emissions²⁸ – are equipped with the additional Low NO_x systems that are the basis of the 100 ppmvd (24-hour) limit EPA raised in the proposed rule.²⁹ Thus, for the rule to make meaningful reductions in – let alone eliminate – New Jersey's significant 8.54ppb contribution to downwind receptors, EPA must go beyond the technology already in place in New Jersey's largest incinerators, and instead require SCR technology and a 50ppm (24-hour) limit.

EPA cannot discount SCR technology for incinerators merely because it may exceed EPA's cost-effectiveness threshold for non-EGUs. That threshold was determined by finding the “knee in the curve” of a plot of various control measures for EPA's Tier 1 and Tier 2 industries *only*, and so did not consider cost estimates specific to the incinerator industry.³⁰ And as noted above, EPA has cautioned that this knee in the curve “is not on its own a justification for not requiring reductions beyond that point in the cost curve,” and EPA has previously required controls that exceeded this knee in the curve.³¹ Indeed, states subject to this Rule have their own cost-effectiveness thresholds of up to \$18,983/ton NO_x,³² which are more than high enough to accommodate SCR costs for incinerators.

iii. In the Alternative, EPA Should Set a 24-Hour NO_x Limit of 110 ppm for MWCs

Assuming that EPA does not require a 50 ppm limit based on SCR – which it should do – EPA should require that MWCs meet a 24-hour NO_x limit of no more than 110 ppm. Recent

²⁶ 87 Fed. Reg. at 20,071 tbl.V.E.1-2.

²⁷ See tbl. I.B-1 and tbl. VI.C.2-2.

²⁸ This percentage calculated using 2017 NO_x emission data from Non-EGU TSD Table 8 for all New Jersey MWCs except the Covanta Warren Energy Resource Center, which is no longer operating. See Steven Novak, Covanta has shut down its Warren County trash incinerator. But it might not be permanent., Lehighvalley.com, Apr. 4, 2019, <https://www.lehighvalleylive.com/warren-county/2019/04/covanta-has-shut-down-its-warren-county-trash-incinerator-but-it-might-not-be-permanent.html>.

²⁹ See Final OTC MWC Report App.B at 35-36.

³⁰ See Non-EGU Screening Assessment at 4.

³¹ See *supra* Section X.A (quoting 86 Fed. Reg. at 23,107).

³² See *supra* Section X.B.

studies have shown that there are a variety of technologies that can help a wide range of MWC boiler types achieve this limit at costs that are significantly below the \$7,500/ton cost effectiveness threshold in EPA’s proposed rule.

1. Covanta facilities

As noted in the Final OTC MWC Report, there are eight Covanta large MWC units already subject to a 24-hour limit of 110 ppm, with significantly different size, boiler type, and manufacturers. These facilities have achieved this by installing Covanta’s patented Low NO_x system on facilities in combination with SNCR.³³ Two of these are Covanta large MWCs located in Virginia, which were required to meet limits of 110 ppm on a 24-hour basis and 90 ppm on an annual average pursuant to the Virginia Department of Environmental Quality’s (“VADEQ’s”) decision regarding Reasonably Available Control Technology (“RACT”) requirements.³⁴ The cost-effectiveness of meeting the new 110 ppm daily limits was estimated by OTC, based on information submitted during Virginia’s RACT process, as \$3,204 per ton for the Fairfax facility and \$4,639 per ton for the Alexandria/Arlington facility.³⁵

In addition, though it is not currently subject to a 110 ppm permit limit, the Montgomery County Resource Recovery Facility (“MCRRF”) in Maryland also operates Covanta’s Low NO_x technology installed in combination with SNCR. The Low NO_x system was added in 2008-2010. As shown in Table 1 below, this reduction in NO_x emissions was achieved while plant operations remained relatively constant.

Table 3: MCRRF NO_x Emissions and Operating Data 2006-2015³⁶				
Year	NO_x emissions (tons)	Waste processed (tons)	% capacity (waste burning)	Power generated (megawatt hours)
2006	1,041	620,666	94%	371,971
2007	1,009	578,804	88%	343,955
2008	998	573,293	87%	331,055
2009	554	527,623	80%	282,170
2010	499	551,670	84%	303,075
2011	512	556,266	85%	308,150
2012	479	544,647	83%	310,008
2013	388	555,716	85%	312,539
2014	427	Not available	Not available	315,450
2015	441	599,250	91%	Not available

³³ Final OTC MWC Report at 16.

³⁴ See VADEQ February 8, 2019 letters to Covanta with NO_x RACT permit conditions attached (Attachment A; *see also* EPA, Approval and Promulgation of Air Quality Implementation Plans; Virginia; Source-Specific Reasonably Available Control Technology Determinations for 2008 Ozone National Ambient Air Quality Standard, 84 Fed. Reg. 67196, 67197 (Dec. 9.2019).

³⁵ Final OTC MWC Report at 20,21.

³⁶ Emissions data from Maryland Emissions Inventory, obtained by the Environmental Integrity Project (“EIP”) through public record requests. EIP will provide the data to EPA upon request. Capacity and power generation data from Northeast Maryland Power Waste Disposal Authority (“NMWDA”) website at <http://nmwda.org/montgomery-county/>, except for 2014 power generation data from U.S. Energy Information Administration (“EIA”) and 2015

MCRRF's annual average NO_x emissions from 2006-2008 were 1,016 tons per year. After the installation of the new Low NO_x controls, during the period from 2009 through 2011, average NO_x emissions were 522 tons per year. This is an average reduction of 494 tons per year or 48.6% of emissions. EPA also noted at the time that the technology "demonstrated a reduction of NO_x emissions by approximately 50 percent from pre-installation levels."³⁷

Further, based on current NO_x continuous emission monitoring system ("CEMS") data from the MCRRF, OTC states conclusively that this facility can meet a 24-hour NO_x limit of 110 ppm, explaining:

Maryland's NO_x RACT also required a NO_x 30-day rolling average emission rate of 105 ppmvd @7% O₂ to be met beginning on May 1, 2020. Since that time, the peak 24-hour average recorded has been on the order of 103 ppmvd @7% O₂. The facility is capable, and further demonstrates, meeting a 110 ppmvd 24-hour limit. Information from a Montgomery County Resource Recovery NO_x optimization study found that ammonia slip is below 5 ppm for all units with LNTM technology with SNCR and with NO_x emissions of 66 ppm and higher.³⁸

If EPA wishes to review the NO_x CEMS data from MCRRF itself, that data is available online.³⁹

During the OTC process, Covanta representatives submitted comments noting that the Low NO_x technology cannot be installed on certain of its facilities, including those that use Aircel grate technology, those that operate RFD units, and those that use rotary combustor units.⁴⁰

However, even incinerators that don't use Low-NO_x technology may be able to meet the 110 ppm limit with SNCR only. Covanta's Delaware Valley Resource Recovery Facility in Pennsylvania, for example, uses rotary combustors but has no NO_x controls whatsoever. Nevertheless, its per-unit maximum 24-hour NO_x emissions over the past 6 years ranged from 122 ppm to 172.5 ppm, so 110 ppm may be achievable with the installation of SNCR or other cost-efficient NO_x controls. Covanta has already committed to a voluntary trial of SNCR at one of the units on this incinerator.⁴¹

In summary, it appears that the majority of Covanta units should be able to achieve a 24-hour limit of 110 ppm and those that are legitimately unable to meet this limit should be afforded

waste processing data from Maryland Department of the Environment PowerPoint presentation dated August 30, 2016 on NO_x RACT for Large MWCs.

³⁷ U.S. EPA, Clean Air Excellence Award Recipients: Year 2014 at 1, https://www.epa.gov/sites/production/files/2015-06/documents/clean_air_excellence_award_recipients_year_2014.pdf.

³⁸ Final OTC MWC Report at 15 (emphasis added).

³⁹ Montgomery County Department of Environmental Protection, Emissions Data Detail – Resource Recovery Facility, <https://www.montgomerycountymd.gov/sws/facilities/rwf/cem-detail.html>.

⁴⁰ Excerpt from Comments from OTC MWC Stakeholder and OTC Responses (hereinafter "OTC Responses") at 7. (Attachment B). In OTC's recap, it appears that Covanta stated that two of its Pennsylvania facilities use rotary technology, though the Final OTC MWC Report identifies only one facility in PA that uses this boiler type. See Final OTC MWC Report at 37

⁴¹ *Id.* at 8.

the opportunity to submit facility-specific information demonstrating that the limit is infeasible for the facility in question.

2. Babcock Power study on Wheelabrator Baltimore facility

Further, a report completed in 2020 assessing options for reducing NO_x at the Wheelabrator incinerator in Baltimore City demonstrates that Covanta-operated facilities are not the only ones that can achieve a 110 ppm NO_x limit on a 24 hour basis.⁴²

In this study, vendors evaluated the control efficiency and costs of several technology options for reducing NO_x at the Wheelabrator facility in Baltimore. The cost-effectiveness of the technologies was summarized in the Final OTC MWC Report issued in April 2022 and includes a technology capable of achieving a 24-hour limit of 110 ppm at a cost of either \$3,883/ton or around \$6,000/ton depending on which set of assumptions is used, as discussed in more detail below.⁴³

Thus, there is ample evidence that multiple types of large MWCs can achieve a 24-hour limit of 110 ppm at costs well below EPA's proposed cost-effectiveness threshold for non-EGUs of \$7,500 per ton.

E. Responses to Additional EPA Questions in Proposed Rule regarding Municipal Waste Combustors

In addition to the comments above, Commenters provide the direct responses below to EPA's list of six questions about regulating MWC NO_x in the proposed rule.⁴⁴

EPA Question: What NO_x emissions limit and averaging time should MWCs be required to meet, and in particular should the EPA adopt emissions rates of 105 ppmvd on a 30-day averaging basis and 110 ppmvd on a 24-hour averaging basis?

Response:

As explained in detail in Section II.D above, EPA should prioritize a 24-hour NO_x limit, and set this 24-hour limit at 50 ppm.

EPA Question: What types of NO_x control technology could be used to reduce NO_x emissions at MWCs, and in particular should the EPA adopt the combustion control modifications made to units with previously installed SNCR identified by the MWC workgroup?

Response:

As explained in detail in Section II.D above, EPA should set emission limits based on assumed installation of SCR technology. SCR is widely used in the industrial sector and

⁴² Waste to Energy NO_x Feasibility Study Prepared for Wheelabrator Technologies Baltimore Waste to Energy, Baltimore, Maryland, BPE Project No. 100825 (February 20, 2020) (hereinafter "Babcock Power Study for Wheelabrator Baltimore Incinerator", Attachment C).

⁴³ Babcock Power Study for Wheelabrator Baltimore Incinerator at 22, 63. The cost identified in Table 8 on page 22 of the report is \$6,159/ton. However, as described in more detail below, that table overestimates pollution control operating costs.

⁴⁴ 66 Fed. Reg. 20086.

currently installed at the Palm Beach Renewable Energy Facility to meet a 50 ppm NO_x emission limit.

EPA Question: Whether there is information that would call into question the OTC workgroup's estimated cost of controls for reducing NO_x emissions from MWCs of \$2900 to \$6600 per ton, and, assuming that range is accurate, whether there is any justification for not requiring these controls in light of their relative cost-effectiveness and total level of reductions available, which compare favorably with the proposed EGU and non-EGU control strategies?

Response:

There is no justification for failing to set limits for large MWCs that are at least as strong as the limits of 110 ppm on a 24-hour average and 105 ppm on a 30-day average that are identified in the OTC report so long as the operators of individual facilities are given the opportunity to submit facility-specific information demonstrating that a particular MWC is unable to meet the limit.

Commenters expect that industry may submit comments stating or implying that MWCs should not have to incur additional costs because of their ostensibly important role in energy and waste management systems. This is not correct. As explained above, as an energy source, large MWCs are more polluting than coal per unit of heat input for certain pollutants, including NO_x. In addition, incineration should not be encouraged as a waste management approach. MWC industry representatives frequently claim that incineration is environmentally friendly because it avoids the generation of landfill methane emissions. This argument ignores that incinerators are themselves greenhouse-gas emitters,⁴⁵ not to mention emitters of various criteria pollutants and hazardous air pollutants, and generators of potentially toxic ash that itself must be appropriately disposed of at landfills. While reduction of landfill methane is extremely important, EPA must achieve this in other ways, specifically by ramping up programs for waste diversion and requiring improved emission control systems at landfills.

In addition, it appears that OTC overestimated the upper end of the cost-effectiveness range, based on existing materials, of achieving a 24-hour limit of 110 ppm. The upper end of the range for achieving this limit is based on the Babcock Power study on the Wheelabrator Baltimore facility. Using information from this report, OTC estimated in one table, Table 8, that the cost-effectiveness of achieving a 110 ppm limit on a 24-hour basis is \$6,159/ton.⁴⁶ However, this number improperly includes the entire cost of operating the technology associated with that limit, rather than the incremental cost of altering the current control system to achieve the lower limit.

A proper analysis would use the same baseline for calculating emission reductions and costs. In Table 8, emission reductions are calculated using a baseline emissions limit of 150 ppm on a 24-hour average, the limit to which the Baltimore incinerator has been subject since May 2019,⁴⁷ which is achieved using an SNCR system. The cost of operating this system in a manner that meets the baseline 150 ppm limit must be subtracted from the cost of operating technologies

⁴⁵ See U.S. EPA, Inventory of U.S. Greenhouse Gas Emissions and Sinks 1990-2018, at 2-3 (2020), <https://www.epa.gov/sites/production/files/2020-04/documents/us-ghg-inventory-2020-main-text.pdf> (noting incinerators emitted 11 million tons of carbon dioxide in 2018).

⁴⁶ Final OTC MWC Report at 22.

⁴⁷ COMAR 26.11.08.10(B).

to achieve further reductions. However, Table 8 incorporates the entire cost of operating the Advanced SNCR system associated with the 110 ppm limit.⁴⁸ This cost, \$995,000 per year, is clearly identified in the original Babcock Power study as the entire cost, not the incremental cost, of operating Advanced SNCR.⁴⁹

The only baseline cost information provided in the Babcock Power study is \$695,000 for operating the existing SNCR. However, it is not clear from the Babcock Power study whether this cost is associated with a baseline 150 ppm or 135 ppm limit.⁵⁰ If this is the cost of meeting the current 150 ppm limit, then the cost-effectiveness table on page 63 of the Final OTC MWC Report is approximately correct. This table identifies a cost of \$3,883 per ton of achieving a 110 ppm limit using Advanced SNCR.⁵¹ If \$695,000 is the operating cost of meeting a 135 ppm limit, then the incremental cost of going from 135 to 110 ppm using Advanced SNCR is about \$6,067 per ton.⁵²

We urge EPA to request additional information from the incinerator's owner, WIN Waste (formerly Wheelabrator) and/or Babcock Power, the company that performed the study, on the current costs of operating the SNCR system to achieve the 150 ppm limit. Commenters are also concerned about the capital costs estimated in the Babcock Power study for the Advanced SNCR technology associated with achieving 110 ppm and recommend that EPA request a breakdown of the capital costs for that technology. Commenters will also seek this information, particularly then baseline cost of operating the existing SNCR at the Baltimore incinerator, and will provide it to EPA if we obtain it.

⁴⁸ *Id.*

⁴⁹ Babcock Power Study for Wheelabrator Baltimore Incinerator at 29.

⁵⁰ *Id.* at 15, 29.

⁵¹ Final OTC MWC Report at 63.

⁵² The table below is an altered version of Table 8 in the Final OTC MWC Report that incorporates incremental operating costs assuming the Existing SNCR costs identified in the Babcock Power Study are associated with a 135 ppm limit. Bolded values differ from those in Table 8 of the Final OTC MWC Report.

	Advanced SNCR
Capital Costs	\$8,665,162
Annual Operating Costs	\$300,000
Annualized Capital Costs	\$817,930
Projected Lifetime (yr)	20
Interest Rates (%)	7%
Total Yearly Costs	\$1,117,930
Base Case NOx (ppm)	135
Controlled NOx (ppm)	110
Estimated NOx Reduction Factor	0.185
Estimated NOx Reduction (%)	18.5
Baseline NOx Emission (tons/yr)	993.38
Projected Controlled NOx Emissions (tons/yr)	809.38
Emission Reduction (tons/yr)	184
Cost effectiveness (\$/ton)	\$6,067

Lastly, if industry cites increases in urea costs as it did during the OTC process, we urge EPA to require information relating to current urea costs, as many facilities already operate SNCRs and incur costs for its use.

EPA Question: If the final FIP includes emission reduction requirements for MWCs, should any mechanism be available by which a particular MWC source could seek to establish that meeting the required emission limits is not feasible?

Response:

Yes. MWC operators should be allowed to submit facility-specific information demonstrating that a particular MWC cannot meet the new limits at or below the cost-effectiveness threshold in EPA's final rule. If EPA, after evaluation of the materials, determines that the MWC at issue cannot meet the limit at that cost/ton, then the MWC should be required to meet the lowest 24-hour limit that *can* be achieved at the cost threshold.

Among other things, EPA should require an MWC operator who seeks to avoid the FIP limits to submit the following in order to demonstrate that the units cannot meet the limit: (1) costs of operating the current NOx control system, including current urea or ammonia usage; (2) NOx CEMS data showing trends over the last 5 years; (3) information supporting costs and effectiveness of installation of the controls discussed in the Babcock Power study; and (4) if insufficient room for new technology is offered as a reason for infeasibility, facility blueprints or schematics. In addition, to increase transparency, EPA should post online requests submitted by MWC operators for an EPA determination that it is infeasible to meet the FIP limit as well as EPA's determinations letters.

EPA Question: Is there any evidence that retrofit of MWC emission controls would take longer to implement than the 2026 ozone season?

Response:

The information submitted with the Babcock Power study suggests the following retrofit schedules from the start of engineering through commissioning and shows that retrofit of MWC emission controls would not take longer to implement than the 2026 ozone season:

Table 4: Technology Retrofit Schedules Based on Babcock Power Study⁵³	
Control Technology	Schedule
Optimizing Existing SNCR	2 months
Flue Gas Recirculation (FGR) + Existing SNCR	16 months
Advanced SNCR	11 months
FGR + Advanced SNCR	16 months
SCR	18 to 26 months (depending on type)

⁵³ Babcock Power Study, Appendix A-1 (Preliminary Schedule).

EPA Question: Would it be appropriate to rely on existing testing, monitoring, recordkeeping, and reporting requirements for MWCs under the applicable NSPS or other requirements?

Response:

All large MWCs are already required to use CEMS to demonstrate compliance with NO_x limits.⁵⁴ This is yet another reason that EPA should require NO_x reductions from this sector in the final rule.

EPA should improve electronic reporting requirements, however, beyond current requirements in the NSPS. An owner or operator of an MWC that is subject to a limit under the final rule should be required to report NO_x CEMS data electronically at least annually to EPA's Compliance and Emissions Data Reporting Interface ("CEDRI") and any other database that EPA will utilize when considering revisions to the NSPS for large MWCs. In addition, MWC operators should be required to report NO_x CEMS data to EPA's Clean Air Markets database, which will allow the public access to MWC CEMS data on a large scale for the first time.

Thank you for considering our comments.

Respectfully submitted,

Leah Kelly
Senior Attorney
Environmental Integrity Project (**National**)
lkelly@environmentalintegrity.org

Jonathan Smith
Senior Attorney
Earthjustice (**National**)
jjsmith@earthjustice.org

KT Andresky, Campaign Organizer
Breathe Free Detroit (**Michigan**)
Detroit, MI

Lisa Arkin, Executive Director
Beyond Toxics (**Oregon**)
Eugene, OR

Shashawnda Campbell
South Baltimore Community Land Trust (**Maryland**)
Baltimore, MD

Krystle D'Alencar
The Minnesota Environmental Justice Table (**Minnesota**)
Minneapolis, MN

Judith Enck, Former EPA Regional Administrator
President, Beyond Plastics (**National**)

⁵⁴ See, e.g., 40 C.F.R. §§ 60.38b(a), 60.58b(b).

Bennington, VT

Jane Williams, Executive Director
California Communities Against Toxics (**California**)
Rosamond, CA

Tracy Frisch
Clean Air Action Network of Glenn Falls (**New York**)
Glenn Falls, NY

Anne Havemann, General Counsel
Chesapeake Climate Action Network (**Chesapeake Bay Regional**)
Takoma Park, MD

Yayoi Koizumi
Zero Waste Ithaca (**New York**)
Ithaca NY

Sharon Lewis, Executive Director
CT Coalition for Economic and Environmental Justice (**Connecticut**)
Hartford, CT

Maria Lopez-Nunez, Deputy Director of Organizing and Advocacy
Ironbound Community Corporation (**New Jersey**)
Newark, NJ

Joseph Otis Minott, Executive Director and Chief Counsel
Clean Air Council (**Pennsylvania**)
Philadelphia, PA

Kerry Meydam, Founder
Durham Environment Watch (**Canada**)
Courtice, Ontario

Alice Volpitta
Baltimore Harbor Waterkeeper (**Maryland**)
Blue Water Baltimore
Baltimore, MD

Monica Wilson, Associate Director of GAIA U.S.
Global Alliance for Incinerator Alternatives (**National/International**)
Berkeley, CA

Attachment A

Virginia Department of Environmental Quality February 2019 Letters
Regarding Reasonably Available Control Technology (“RACT”)
at Covanta Alexandria/Arlington and Fairfax facilities



Commonwealth of Virginia

VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY

NORTHERN REGIONAL OFFICE
13901 Crown Court, Woodbridge, Virginia 22193
(703)583-3800 FAX (703) 583-3821
www.deq.virginia.gov

Matthew J. Strickler
Secretary of Natural Resources

David K. Paylor
Director
(804) 698-4000

Thomas A. Fahs
Regional Director

February 8, 2019

Mr. Bryan Donnelly
Facility Manager
Covanta Alexandria/Arlington, Inc.
5301 Eisenhower Avenue
Alexandria, Virginia 22304

Location: City of Alexandria
Registration No.: 71895

Dear Mr. Donnelly:

Attached is a permit to operate a solid waste combustor facility in accordance with the provisions of the Commonwealth of Virginia State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution. This permit is for the purpose of implementing the "reasonably available control technology" (RACT) requirements of 9 VAC 5-40-7400, 9 VAC 5-40-7420 and 9 VAC 5-40-7430 of the Regulations of the Board. Except to the extent that conditions in this permit may be more stringent, this permit does not supersede or replace any other valid permit. Furthermore, this approval to operate shall not relieve Covanta Alexandria/Arlington, Inc. (CAAI) to comply with all other local, state, and federal permit regulations.

This permit contains legally enforceable conditions. Failure to comply may result in a Notice of Violation and civil penalty. Please read all conditions carefully.

At any time in the future, should CAAI plan any modifications (within the context of the new source review program) of the facility covered by this permit, CAAI shall have the right to apply to the Board for a new source review permit and the Board may consent to such modifications provided such modifications will meet all of the new source review permit program regulatory requirements in existence at that time.

Issuance of this permit is a case decision. The Regulations, at 9 VAC 5-170-200, provide that you may request a formal hearing from this case decision by filing a petition with the Board within 30 days after this permit is mailed or delivered to you. Please consult that and other relevant provisions for additional requirements for such requests.

Additionally, as provided by Rule 2A:2 of the Supreme Court of Virginia, you have 30 days from the date you actually received this permit or the date on which it was mailed to you, whichever occurred first, within which to initiate an appeal to court by filing a Notice of Appeal with:

Mr. David K. Paylor, Director
Department of Environmental Quality
P. O. Box 1105
Richmond, VA 23218

In the event that you receive this permit by mail, three days are added to the period in which to file an appeal. Please refer to Part Two A of the Rules of the Supreme Court of Virginia for additional information including filing dates and the required content of the Notice of Appeal.

If you have any questions concerning this permit, please contact the Northern Regional Office at (703) 583-3800.

Sincerely,



Thomas A. Faha
Regional Director

TAF/JBL/HGB/71895-RACT SOP (2-8-2019)

Attachment: Permit

cc: Joseph Walsh, Covanta (electronic file submission)
Riley Burger, EPA Region III
Manager/Inspector, Air Compliance Manager (electronic file submission)



Commonwealth of Virginia

VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY

NORTHERN REGIONAL OFFICE
13901 Crown Court, Woodbridge, Virginia 22193
(703)583-3800 FAX (703) 583-3821
www.deq.virginia.gov

Matthew J. Strickler
Secretary of Natural Resources

David K. Paylor
Director
(804) 698-4000

Thomas A. Faha
Regional Director

STATIONARY SOURCE PERMIT TO OPERATE

In compliance with the Federal Clean Air Act and the Commonwealth of Virginia Regulations for the Control and Abatement of Air Pollution,

Covanta Alexandria/Arlington, Inc.
5301 Eisenhower Ave.
Alexandria, Virginia 22304
Registration No.: 71895

is authorized to operate

a municipal solid waste combustor facility

located at

5301 Eisenhower Ave.
Alexandria, VA 22304

in accordance with the Conditions of this permit.

Approved on February 8, 2019.

A handwritten signature in blue ink, appearing to read "Thomas A. Faha".

Thomas A. Faha
Regional Director

Permit consists of 9 pages.
Permit Conditions 1 to 26.

INTRODUCTION/PURPOSE

This permit is, (i) for the purpose of implementing the “reasonably available control technology” (RACT) requirements of 9VAC5-40-7420 of the State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution (“Regulations”), and (ii) establishes control technology and other requirements for the control of nitrogen oxides (NO_x) emissions from Covanta Alexandria/Arlington, Incorporated (CAAI) in the Northern Virginia Ozone Non-Attainment Area and the Ozone Transport Region in Virginia. These RACT requirements shall be the legal and regulatory basis for control of NO_x emissions from this facility.

Words or terms used in this permit shall have meanings as provided in 9VAC5-10-20 of the State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution. The regulatory reference or authority for each condition is listed in parentheses () after each condition.

The availability of information submitted to the Department of Environmental Quality (DEQ) or the Board will be governed by applicable provisions of the Freedom of Information Act, §§ 2.2-3700 through 2.2-3714 of the Code of Virginia, § 10.1-1314 (addressing information provided to the Board) of the Code of Virginia, and 9VAC5-170-60 of the State Air Pollution Control Board Regulations. Information provided to federal officials is subject to appropriate federal law and regulations governing confidentiality of such information.

EQUIPMENT LIST

Equipment List - Equipment at this facility consists of the following:

Emission Unit ID	Equipment Description	Rated Capacity	Pollutant(s)*
001-02	Keeler/Dorr-Oliver municipal waste combustor with Martin stokers Model # MK 325 (Construction Date Feb. 1988)	121.8 MMBtu	NO _x
002-02	Keeler/Dorr-Oliver municipal waste combustor with Martin stokers Model # MK 325 (Construction Date Feb. 1988)	121.8 MMBtu	NO _x
003-02	Keeler/Dorr-Oliver municipal waste combustor with Martin stokers Model # MK 325 (Construction Date Feb. 1988)	121.8 MMBtu	NO _x

*Pollutant(s) listed for each specified emission unit is only as 9VAC5-40-7420 applies.

PROCESS REQUIREMENTS

1. **Emission Controls** – Upon completion of the installation and optimization period per Conditions 2 and 3, respectively, nitrogen oxides (NO_x) emissions from each municipal waste combustor (MWC) (Ref. 001-02, 002-02, and 003-02) shall be controlled by furnace design, proper operation, good combustion practices, ammonia injection (selective non-catalytic reduction (SNCR)), and the Covanta proprietary low NO_x combustion system (LNTM). Until that time, the NO_x emissions shall be controlled by furnace design, proper operation, and ammonia injection (SNCR). The SNCR and LNTM system shall be provided with adequate access for inspection and shall be in operation when each municipal waste combustor (Ref. 001-02, 002-02, and 003-02) is operating.
(9VAC5-80-850 and 9VAC5-40-7420)
2. **Emission Controls** – The permittee shall install the Covanta proprietary low NO_x combustion system (LNTM) on the MWCs (Ref. 001-02, 002-02, and 003-02) on a staged basis. The installation shall be completed according to the following schedule;
 - a. The LNTM system installed on the first MWC no later than the end of the 4th quarter 2019,
 - b. The LNTM system installed on the second MWC no later than the end of the 4th quarter 2020, and
 - c. The LNTM system installed on the third MWC no later than the end of the 4th quarter 2021.
(9VAC5-80-850 and 9VAC5-40-7420)
3. **Emission Controls** – Following the installation of each LNTM systems on the MWCs (Ref. 001-02, 002-02, and 003-02) there shall be no more than a 180-day testing and optimization period, for the respective unit. Completion of the testing/optimization period would mark the start of the revised NO_x emission limits as specified in Condition 4.
(9VAC5-80-850 and 9VAC5-40-7420)

EMISSION LIMITS

4. **Process Emission Limits** – No later than the testing and optimization period of the LNTM system on each of the MWCs (Ref. 001-02, 002-02, and 003-02), as referenced in Condition 3 above, NO_x emissions from such MWC shall not exceed the following:
 - a. Daily Average Nitrogen Oxides
110 ppmvd @ 7% O₂.
 - b. Annual Average Nitrogen Oxides
90 ppmvd @ 7% O₂.
 - c. The daily average is defined as the hourly rolling average of all hourly average emission concentrations (i.e. 24 hourly averages in a 24-hour period). The 24-hour average calculation should exclude those periods in which no waste was being combusted, when the MWC was not on-line or during periods of startup, shutdown or malfunction.

- d. The annual average emissions shall be calculated on a daily basis using the daily average comprising all operating days in the year. Compliance for the annual average period shall be demonstrated daily by averaging the most recently completed daily average with the preceding yearly daily average emissions. The 24-hour average used for the annual average calculation shall begin at 12:00 midnight and continue to the following 12:00 midnight.

Compliance with these emission standards shall be determined by continuous emissions monitors (CEMS) or performance tests.

Compliance with the annual average nitrogen oxide emission limit for each MWC shall begin upon completion of 12 calendar months after the date of this permit, or 12 calendar months following the installation, testing and optimization of the LNTM system on the respective MWC, whichever is later for that unit.

(9VAC5-80-850 and 9VAC5-40-7420)

MONITORING

5. **CEMS** – A continuous emission monitoring system (CEMS) consisting of a nitrogen oxides (NO_x) pollutant concentration monitor, an oxygen (O₂) diluent monitor, and an automated data acquisition and handling system meeting the applicable design specifications of 40 CFR Part 60, Appendix B shall be installed to measure and record the emissions of NO_x from each MWC (Ref. 001-02, 002-02, and 003-02) exhaust stack as ppmvd corrected to 7% O₂. The CEMS shall be installed, calibrated, maintained, audited and operated in accordance with the requirements of 40 CFR 60.13, 40 CFR 60, Appendices B and F, as applicable, or DEQ approved procedures which are equivalent to the requirements of 40 CFR §60.13 and 40 CFR 60, Appendices B and F, as applicable. Data shall be reduced to one-hour averages and 24-hour rolling averages using procedures approved by the Air Compliance Manager of the DEQ's Northern Regional Office (NRO). The span value for the NO_x monitor shall be 125 percent of the maximum estimated hourly potential NO_x emissions of the MWC unit and the O₂ monitor shall be 25 percent O₂. Each CEM shall be provided with adequate access for inspection and shall be in operation when the MWC (Ref. 001-02, 002-02, and 003-02) is operating.
(9VAC5-80-850 and 9VAC5-40-7420)
6. **CEMS Quality Control Program** – A CEMS quality control program which meets the requirements of 40 CFR 60.13 and 40 CFR Part 60, Appendix F shall be implemented for all continuous monitoring systems, except that Relative Accuracy Test Audits (RATAs) may be required less frequently if approved by DEQ.
(9VAC5-80-850 and 9VAC5-40-7420)
7. **CEMS Valid Data Collection** – At a minimum, valid NO_x CEMS hourly averages shall be obtained as specified below for 75 percent of the operating hours per day for 90 percent of the operating days per calendar quarter that each MWC unit is combusting MSW.
 - a. At least 2 data points per hour shall be used to calculate each 1-hour arithmetic average.

- b. Each NO_x 1-hour arithmetic average shall be corrected to 7 percent O₂ on an hourly basis using the 1-hour arithmetic average of the O₂ CEMS data.

(9VAC5-80-890 and 9VAC5-40-8140 G)

- 8. **CEMS Data** – All valid NO_x CEMS data shall be used in calculating emission averages even if the minimum CEMS data requirements of Condition 7 are not met.

(9VAC5-80-890 and 9VAC5-40-8140 G)

TESTING

- 9. **Emission Testing** – Each municipal waste combustor (Ref. 001-02, 002-02, and 003-02) shall be constructed/modified/installed to allow for emissions testing upon reasonable notice at any time, using appropriate methods. This includes constructing the facility/equipment such that volumetric flow rates and pollutant emission rates are accurately determined by applicable test methods. The permittee shall provide sampling ports when requested at the appropriate locations and safe sampling platforms provided.

(9VAC5-80-850, 9VAC5-80-880, and 9VAC5-40-7490)

RECORDS

- 10. **On Site Records** – The permittee shall maintain records of emission data and operating parameters as necessary to demonstrate compliance with this permit. The content and format of such records shall be arranged with the Air Compliance Manager of the DEQ's NRO. These records shall include, but are not limited to;

- a. All 1-hour average NO_x emission concentrations as specified in Conditions 4 and 7.
- b. All 24-hour daily arithmetic average NO_x emission concentrations as specified in Condition 4.
- c. All annual NO_x emission concentrations as specified in Condition 4.
- d. Each calendar date for which the minimum number of hours of any of the NO_x data have not been obtained including reasons for not obtaining sufficient data and a description of corrective actions taken.
- e. The NO_x emission data, or operational data that have been excluded from the calculation of average emission concentrations or parameters, and the reasons for excluding the data.
- f. The permittee shall record the results of daily drift tests, quarterly accuracy determinations, percent operating time, and RATA for NO_x and O₂ CEMS, as required under 40 CFR Part 60, Appendix F, Procedure 1.
- g. Scheduled and unscheduled maintenance and operator training.

The records shall be maintained onsite in either paper copy or computer-readable format, unless the Air Compliance Manager of the DEQ's NRO approves an alternative format and shall be available on-site for inspection by DEQ for a period of at least five years.
(9VAC5-80-850, 9VAC5-80-900, and 9VAC5-40-7510)

NOTIFICATIONS

11. **Emission Controls** – The permittee shall submit to the Regional Air Compliance Manager of DEQ's NRO, a notification of the dates of the commencement and completion of the installation of the LNTM systems on each MWC (Ref. 001-02, 002-02, and 003-02), postmarked no later than 30 days after such dates, or no later than 30 days after the date of this permit, whichever is later.
(9VAC5-80-850, 9VAC5-80-900 and 9VAC5-7510)
12. **Emission Controls** – The permittee shall submit to the Regional Air Compliance Manager of DEQ's NRO, the date of the completion of the testing/optimization period for each MWC, postmarked no later than 30 days after such date, or no later than 30 days after the date of this permit, whichever is later.
(9VAC5-80-850, 9VAC5-80-900 and 9VAC5-7510)

REPORTING

13. **CEMS Reports** – The permittee shall furnish written reports to the Air Compliance Manager of the DEQ's NRO of excess emissions from any process monitored by a CEMS on a quarterly basis, postmarked no later than the 30th day following the end of the calendar quarter. These reports shall include, but are not limited to the following information:
 - a. The magnitude of excess emissions, any conversion factors used in the calculation of excess emissions, and the date and time of commencement and completion of each period of excess emissions;
 - b. Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the process, the nature and cause of the malfunction (if known), the corrective action taken or preventative measures adopted;
 - c. The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks, other quality assurance (as required in 40 CFR 60, Appendix F) and the nature of the system repairs or adjustments; and
 - d. When no excess emissions have occurred or the continuous monitoring systems have not been inoperative, repaired or adjusted, such information shall be stated in that report.
(9VAC5-80-850 and 9VAC5-40-7420)

14. **NO_x Emissions Reporting** – The permittee shall submit semi-annual reports to the Regional Air Compliance Manager of DEQ's NRO for each semi-annual period that emissions exceed the limits of Condition 4. The periods covering each semi-annual period shall be January 1 through June 30 and July 1 through December 31.
(9VAC5-80-900)
15. **NO_x Emissions Reporting** – The permittee shall submit the data reports required in Condition 14 no later than March 1 and September 1 of each year following the semiannual period in which the data were collected, unless otherwise approved by the Air Compliance Manager of the DEQ's NRO.
(9VAC5-80-900)

GENERAL CONDITIONS

16. **Permit Limitations** – Except to the extent that conditions in this permit may be more stringent, this permit does not supersede or replace any other valid permit, regulatory or statutory requirement. Furthermore, this approval to operate shall not relieve Covanta Alexandria/Arlington, Inc. of the responsibility to comply with all other local, state and federal regulations, including permit regulations.
(9VAC5-80-850)
17. **Federal Enforceability** – Once the permit is approved by the U.S. Environmental Protection Agency into the Commonwealth of Virginia State Implementation Plan, the permit is enforceable by EPA and citizens under the federal Clean Air Act.
(9VAC5-80-850)
18. **Permit Revision/Repeal** – The Board may revise (modify, rewrite, change or amend) or repeal this permit with the consent of Covanta Alexandria/Arlington, Inc., for good cause shown by Covanta Alexandria/Arlington, Inc., or on its own motion provided approval of the revision or repeal is accomplished in accordance with Regulations of the Board and the Administrative Process Act (§ 2.2-4000 *et seq.*). Such revision or repeal shall not be effective until the revision or repeal is approved by the U.S. Environmental Protection Agency following the requirements of 40 CFR Part 51 (Requirements for Preparation, Adoption, and Submittal of Implementation Plans).
(9VAC5-80-850)
19. **Failure to Comply** – Failure by Covanta Alexandria/Arlington, Inc. to comply with any of the conditions of this permit shall constitute a violation of a Permit of the Board. Failure to comply may result in a Notice of Violation and civil penalty. Nothing herein shall waive the initiation of appropriate enforcement actions or the issuance of orders as appropriate by the Board as a result of such violations. Nothing herein shall affect appropriate enforcement actions by any other federal, state, or local regulatory authority.
(9VAC5-80-850)

20. **Right of Entry** – The permittee shall allow authorized local, state, and federal representatives, upon the presentation of credentials:

- a. To enter upon the permittee's premises on which the facility is located or in which any records are required to be kept under the terms and conditions of this permit;
- b. To have access to and copy at reasonable times any records required to be kept under the terms and conditions of this permit or the State Air Pollution Control Board Regulations;
- c. To inspect at reasonable times any facility, equipment, or process subject to the terms and conditions of this permit or the State Air Pollution Control Board Regulations; and
- d. To sample or test at reasonable times.

For purposes of this condition, the time for inspection shall be deemed reasonable during regular business hours or whenever the facility is in operation. Nothing contained herein shall make an inspection time unreasonable during an emergency.

(9VAC5-170-130 and 9VAC5-80-850)

21. **Notification for Facility or Control Equipment Malfunction** – The permittee shall furnish notification to the Regional Air Compliance Manager of DEQ's NRO of malfunctions of the affected facility or related air pollution control equipment that may cause excess emissions for more than one hour. Such notification shall be made as soon as practicable but no later than four daytime business hours after the malfunction is discovered. The permittee shall provide a written statement giving all pertinent facts, including the estimated duration of the breakdown, within two weeks of discovery of the malfunction. When the condition causing the failure or malfunction has been corrected and the equipment is again in operation, the permittee shall notify the Regional Air Compliance Manager of DEQ's NRO in writing.
(9VAC5-20-180 C and 9VAC5-80-850)

22. **Violation of Ambient Air Quality Standard** – The permittee shall, upon reasonable request of the DEQ, reduce the level of operation or shut down a facility, as necessary to avoid violating any primary ambient air quality standard and shall not return to normal operation until such time as the ambient air quality standard will not be violated.
(9VAC5-20-180 I and 9VAC5-80-850)

23. **Maintenance/Operating Procedures** – At all times, including periods of start-up, shutdown, soot blowing, and malfunction, the permittee shall, to the extent practicable, maintain and operate the affected source, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions.

The permittee shall take the following measures in order to minimize the duration and frequency of excess emissions, with respect to municipal waste combustor (Ref. 001-02, 002-02, and 003-02) air pollution control equipment, and process equipment which affect such emissions:

- a. Develop a maintenance schedule and maintain records of all scheduled and non-scheduled maintenance.
- b. Maintain an inventory of spare parts.

- c. Have available written operating procedures for equipment. These procedures shall be based on the manufacturer's recommendations, as available.
- d. Train operators in the proper operation of all such equipment and familiarize the operators with the written operating procedures, prior to their first operation of such equipment. The permittee shall maintain records of the training provided including the names of trainees, the date of training and the nature of the training.
- e. Records of maintenance and training shall be maintained on site for a period of five years and shall be made available to DEQ personnel upon request.

(9VAC5-50-20 E and 9VAC5-80-850)

24. Permit Suspension/Revocation – This permit may be revoked if the permittee:

- a. Knowingly makes material misstatements in the permit application or any amendments to it;
- b. Fails to comply with the terms or conditions of this permit;
- c. Fails to comply with any emission standards applicable to a permitted emissions unit;
- d. Causes emissions from this facility which result in violations of, or interferes with the attainment and maintenance of, any ambient air quality standard;
- e. Fails to operate this facility in conformance with any applicable control strategy, including any emission standards or emission limitations, in the State Implementation Plan in effect at the time that an application for this permit is submitted;
- f. Fails to comply with the applicable provisions of Articles 6, 8 and 9 of 9VAC5 Chapter 80.

(9VAC5-80-1010)

25. Change of Ownership – In the case of a transfer of ownership of a stationary source, the new owner shall abide by any current permit issued to the previous owner. The new owner shall notify the Regional Air Compliance Manager of DEQ's NRO of the change of ownership within 30 days of the transfer.

(9VAC5-80-940)

26. Permit Copy – The permittee shall keep a copy of this permit on the premises of the facility to which it applies.

(9VAC5-80-860 D)



Commonwealth of Virginia

VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY

NORTHERN REGIONAL OFFICE
13901 Crown Court, Woodbridge, Virginia 22193
(703)583-3800 FAX (703) 583-3821
www.deq.virginia.gov

Matthew J. Strickler
Secretary of Natural Resources

David K. Paylor
Director
(804) 698-4000

Thomas A. Faha
Regional Director

February 8, 2019

Mr. Frank Capobianco
Facility Manager
Covanta Fairfax, Inc.
9898 Furnace Road
Lorton, Virginia 22079

Location: Fairfax County
Registration No.: 71920

Dear Mr. Capobianco:

Attached is a permit to operate a solid waste combustor facility in accordance with the provisions of the Commonwealth of Virginia State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution. This permit is for the purpose of implementing the "reasonably available control technology" (RACT) requirements of 9 VAC 5-40-7400, 9 VAC 5-40-7420 and 9 VAC 5-40-7430 of the Regulations of the Board. Except to the extent that conditions in this permit may be more stringent, this permit does not supersede or replace any other valid permit. Furthermore, this approval to operate shall not relieve Covanta Fairfax, Inc. (CFI) to comply with all other local, state, and federal permit regulations.

This permit contains legally enforceable conditions. Failure to comply may result in a Notice of Violation and civil penalty. Please read all conditions carefully.

At any time in the future, should CFI plan any modifications (within the context of the new source review program) of the facility covered by this permit, CFI shall have the right to apply to the Board for a new source review permit and the Board may consent to such modifications provided such modifications will meet all of the new source review permit program regulatory requirements in existence at that time.

Issuance of this permit is a case decision. The Regulations, at 9 VAC 5-170-200, provide that you may request a formal hearing from this case decision by filing a petition with the Board within 30 days after this permit is mailed or delivered to you. Please consult that and other relevant provisions for additional requirements for such requests.


Additionally, as provided by Rule 2A:2 of the Supreme Court of Virginia, you have 30 days from the date you actually received this permit or the date on which it was mailed to you, whichever occurred first, within which to initiate an appeal to court by filing a Notice of Appeal with:

Mr. David K. Paylor, Director
Department of Environmental Quality
P. O. Box 1105
Richmond, VA 23218

In the event that you receive this permit by mail, three days are added to the period in which to file an appeal. Please refer to Part Two A of the Rules of the Supreme Court of Virginia for additional information including filing dates and the required content of the Notice of Appeal.

If you have any questions concerning this permit, please contact the Northern Regional Office at (703) 583-3800.

Sincerely,



Thomas A. Faha
Regional Director

TAF/JBL/HGB/71920-RACT SOP (2-8-2019)

Attachment: Permit

cc: Joseph Walsh, Covanta (electronic file submission)
Riley Burger, EPA Region III
Manager/Inspector, Air Compliance Manager (electronic file submission)



Commonwealth of Virginia

VIRGINIA DEPARTMENT OF ENVIRONMENTAL QUALITY

NORTHERN REGIONAL OFFICE
13901 Crown Court, Woodbridge, Virginia 22193
(703) 583-3800 FAX (703) 583-3821
www.deq.virginia.gov

Matthew J. Strickler
Secretary of Natural Resources

David K. Paylor
Director
(804) 698-4000

Thomas A. Faha
Regional Director

STATIONARY SOURCE PERMIT TO OPERATE

In compliance with the Federal Clean Air Act and the Commonwealth of Virginia Regulations for the Control and Abatement of Air Pollution,

Covanta Fairfax, Inc.
9898 Furnace Road
Lorton, Virginia 22079
Registration No.: 71920

is authorized to operate

a municipal solid waste combustor facility

located at

9898 Furnace Road
Lorton, Virginia 22079
(Fairfax County)

in accordance with the Conditions of this permit.

Approved on February 8, 2019.

A handwritten signature in blue ink, reading "Thomas A. Faha".

Thomas A. Faha
Regional Director

Permit consists of 9 pages.
Permit Conditions 1 to 26.

INTRODUCTION/PURPOSE

This permit is, (i) for the purpose of implementing the “reasonably available control technology” (RACT) requirements of 9VAC5-40-7420 of the State Air Pollution Control Board Regulations for the Control and Abatement of Air Pollution (“Regulations”), and (ii) establishes control technology and other requirements for the control of nitrogen oxides (NO_x) emissions from Covanta Fairfax, Inc. (CFI) in the Northern Virginia Ozone Non-Attainment Area and the Ozone Transport Region in Virginia. These RACT requirements shall be the legal and regulatory basis for control of NO_x emissions from this facility. In addition, this facility may be subject to additional applicable requirements not listed in this permit.

Words or terms used in this permit shall have meanings as provided in 9VAC5-10-20 of the Regulations. The regulatory reference or authority for each condition is listed in parentheses () after each condition.

The availability of information submitted to the Department of Environmental Quality (DEQ) or the Board will be governed by applicable provisions of the Freedom of Information Act, §§ 2.2-3700 through 2.2-3714 of the Code of Virginia, § 10.1-1314 (addressing information provided to the Board) of the Code of Virginia, and 9VAC5-170-60 of the State Air Pollution Control Board Regulations. Information provided to federal officials is subject to appropriate federal law and regulations governing confidentiality of such information.

EQUIPMENT LIST

Equipment at this facility subject to RACT requirements consist of the following:

Emission Unit ID	Equipment Description	Rated Capacity	Pollutant(s)*
001-01	Ogden-Martin MSW Combustor with Martin-Stoker boiler system (Began commercial operation in June 1990)	343.75 MMBtu/hr (heat input)	NO _x
002-01	Ogden-Martin MSW Combustor with Martin-Stoker boiler system (Began commercial operation in June 1990)	343.75 MMBtu/hr (heat input)	NO _x
003-01	Ogden-Martin MSW Combustor with Martin-Stoker boiler system (Began commercial operation in June 1990)	343.75 MMBtu/hr (heat input)	NO _x
004-01	Ogden-Martin MSW Combustor with Martin-Stoker boiler system (Began commercial operation in June 1990)	343.75 MMBtu/hr (heat input)	NO _x

* Pollutant(s) listed for each specified emission unit is only as 9VAC5-40-7420 applies.

PROCESS REQUIREMENTS

1. **Emission Control** – Upon completion of the installation and optimization period per Conditions 2 and 3, respectively, nitrogen oxides (NO_x) emissions from each municipal waste combustor (MWC) (Ref. 001-01 through 004-01) shall be controlled by furnace design, proper operation, ammonia injection (selective non-catalytic reduction (SNCR)), and the Covanta proprietary low NO_x combustion system (LNTM). Until that time, the NO_x emissions shall be controlled by furnace design, proper operation, and ammonia injection (SNCR). The SNCR and LNTM system shall be provided with adequate access for inspection and shall be in operation when each municipal waste combustor (Ref. 001-01 through 004-01) is operating.
(9VAC5-80-850 and 9VAC5-40-7420)
2. **Emission Controls** – The permittee shall install the Covanta proprietary low NO_x combustion system (LNTM) on the MWCs (Ref. 001-01 through 004-01) on a staged basis. The installation shall be completed according to the following schedule;
 - a. The LNTM system installed on the first MWC no later than the end of the 2nd quarter 2019,
 - b. The LNTM system installed on the second MWC no later than the end of the 4th quarter 2019,
 - c. The LNTM system installed on the third MWC no later than the end of the 4th quarter 2020, and
 - d. The LNTM system installed on the fourth MWC no later than the end of the 4th quarter 2021.
(9VAC5-80-850 and 9VAC5-40-7420)
3. **Emission Controls** – Following the installation of each LNTM system on the MWCs, (Ref. 001-01 through 004-01) there shall be no more than a 180-day testing and optimization period for the respective unit. Completion of the testing/optimization period would mark the start of the revised NO_x emission limits as specified in Condition 4.
(9VAC5-80-850 and 9VAC5-40-7420)

EMISSION LIMITS

4. **Process Emission Limits** – No later than the testing and optimization of the LNTM system on each of the MWCs (Ref. 001-01 through 004-01), as referenced in Condition 3 above, NO_x emissions from such MWC shall not exceed the following:
 - a. Daily Average Nitrogen Oxides
110 ppmvd @ 7% O₂.
 - b. Annual Average Nitrogen Oxides
90 ppmvd @ 7% O₂.
 - c. The daily average is defined as the hourly rolling average of all hourly average emission concentrations (i.e. 24 hourly averages in a 24-hour period). The 24-hour average calculation should exclude those periods in which no waste was being combusted, when the MWC was not

on-line or during periods of startup, shutdown or malfunction.

- d. The annual average emissions shall be calculated on a daily basis using the daily average comprising all operating days in the year. Compliance for the annual average period shall be demonstrated daily by averaging the most recently completed daily average with the preceding yearly daily average emissions. The 24-hour average used for the annual average calculation shall begin at 12:00 midnight and continue to the following 12:00 midnight.

Compliance with these emission standards shall be determined by continuous emissions monitors (CEMS) or performance tests.

Compliance with the annual average nitrogen oxide emission limit for each MWC shall begin upon completion of 12 calendar months after the date of this permit, or 12 calendar months following the installation, testing and optimization of the LNTM system on the respective MWC, whichever is later for that unit.

(9VAC5-80-850 and 9VAC5-40-7420)

MONITORING

5. **CEMS** – A continuous emission monitoring system (CEMS) consisting of a nitrogen oxides (NO_x) pollutant concentration monitor, an oxygen (O₂) diluent monitor, and an automated data acquisition and handling system meeting the applicable design specifications of 40 CFR Part 60, Appendix B shall be installed to measure and record the emissions of NO_x from each MWC (Ref. 001-01 through 004-01) exhaust stack as ppmvd, corrected to 7% O₂. The CEMS shall be installed, calibrated, maintained, audited and operated in accordance with the requirements of 40 CFR 60.13, 40 CFR 60, Appendices B and F, as applicable, or DEQ approved procedures which are equivalent to the requirements of 40 CFR §60.13 and 40 CFR 60, Appendices B and F, as applicable. Data shall be reduced to one-hour averages and 24-hour rolling averages using procedures approved by the Air Compliance Manager of the DEQ's Northern Regional Office (NRO). The span value for the NO_x monitor shall be 125 percent of the maximum estimated hourly potential NO_x emissions of the MWC unit and the O₂ monitor shall be 25 percent O₂. Each CEM shall be provided with adequate access for inspection and shall be in operation when the MWC (Ref. 001-01 through 004-01) is operating.
(9VAC5-80-850 and 9VAC5-40-7420)
6. **CEMS Quality Control Program** – A CEMS quality control program which meets the requirements of 40 CFR §60.13 and 40 CFR Part 60, Appendix F shall be implemented for all continuous monitoring systems, except that Relative Accuracy Test Audits (RATAs) may be required less frequently if approved by DEQ.
(9VAC5-80-850 and 9VAC5-40-7420)
7. **CEMS Valid Data Collection** – At a minimum, valid NO_x CEMS hourly averages shall be obtained as specified below for 75 percent of the operating hours per day for 90 percent of the operating days per calendar quarter that each MWC unit is combusting MSW.
 - a. At least 2 data points per hour shall be used to calculate each 1-hour arithmetic average.

- b. Each NO_x 1-hour arithmetic average shall be corrected to 7 percent O₂ on an hourly basis using the 1-hour arithmetic average of the O₂ CEMS data.

(9 VAC 5-80-890 and 9VAC5-40-8140 G)

- 8. **CEMS Data** – All valid NO_x CEMS data shall be used in calculating emission averages even if the minimum CEMS data requirements of Condition 7 are not met.
(9VAC5-80-890 and 9VAC5-40-8140 G)

TESTING

- 9. **Emission Testing** – Each municipal waste combustor (Ref. 001-01 through 004-01) shall be constructed/modified/installed to allow for emissions testing upon reasonable notice at any time, using appropriate methods. This includes constructing the facility/equipment such that volumetric flow rates and pollutant emission rates are accurately determined by applicable test methods. The permittee shall provide sampling ports when requested at the appropriate locations and safe sampling platforms provided.
(9VAC5-80-850, 9VAC5-80-880, and 9VAC5-40-7490)

RECORDS

- 10. **On Site Records** – The permittee shall maintain records of emission data and operating parameters as necessary to demonstrate compliance with this permit. The content and format of such records shall be arranged with the Air Compliance Manager of the DEQ's NRO. These records shall include, but are not limited to;
 - a. All 1-hour average NO_x emission concentrations as specified in Conditions 4 and 7.
 - b. All 24-hour daily arithmetic average NO_x emission concentrations as specified in Condition 4.
 - c. All annual NO_x emission concentrations as specified in Condition 4.
 - d. Each calendar date for which the minimum number of hours of any of the NO_x data have not been obtained including reasons for not obtaining sufficient data and a description of corrective actions taken.
 - e. The NO_x emission data, or operational data that have been excluded from the calculation of average emission concentrations or parameters, and the reasons for excluding the data.
 - f. The permittee shall record the results of daily drift tests, quarterly accuracy determinations, percent operating time, and RATA for NO_x and O₂ CEMS, as applicable, as required under 40 CFR Part 60, Appendix F, Procedure 1.
 - g. Scheduled and unscheduled maintenance and operator training.

The records shall be maintained onsite in either paper copy or computer-readable format, unless the Air Compliance Manager of the DEQ's NRO approves an alternative format and shall be available on-site for inspection by DEQ for a period of at least five years.
(9VAC5-80-850, 9VAC5-80-900, and 9VAC5-40-7510)

NOTIFICATIONS

11. **Emission Controls** – The permittee shall submit to the Regional Air Compliance Manager of DEQ's NRO, a notification of the dates of the commencement and completion of the installation of the LNTM systems on each MWC (Ref. 001-01 through 004-01), postmarked no later than 30 days after such dates, or no later than 30 days after the date of this permit, whichever is later.
(9VAC5-80-850, 9VAC5-80-900 and 9VAC5-7510)
12. **Emission Controls** – The permittee shall submit to the Regional Air Compliance Manager of DEQ's NRO the date of the completion of the testing/optimization period for each MWC, postmarked no later than 30 days after such date, or no later than 30 days after the date of this permit, whichever is later.
(9VAC5-80-850, 9VAC5-80-900 and 9VAC5-7510)

REPORTING

13. **CEMS Reports** – The permittee shall furnish written reports to the Air Compliance Manager of the DEQ's NRO of excess emissions from any process monitored by a CEMS on a quarterly basis, postmarked no later than the 30th day following the end of the calendar quarter. These reports shall include, but are not limited to the following information:
 - a. The magnitude of excess emissions, any conversion factors used in the calculation of excess emissions, and the date and time of commencement and completion of each period of excess emissions;
 - b. Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the process, the nature and cause of the malfunction (if known), the corrective action taken or preventative measures adopted;
 - c. The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks, other quality assurance (as required in 40 CFR 60, Appendix F) and the nature of the system repairs or adjustments; and
 - d. When no excess emissions have occurred or the continuous monitoring systems have not been inoperative, repaired or adjusted, such information shall be stated in that report.
(9VAC5-80-850 and 9VAC5-40-7420)

14. **NO_x Emissions Reporting** – The permittee shall submit semi-annual reports to the Regional Air Compliance Manager of DEQ's NRO for each semi-annual period that emissions exceed the limits of Condition 4. The periods covering each semi-annual period shall be January 1 through June 30 and July 1 through December 31.
(9VAC5-80-900)
15. **NO_x Emissions Reporting** – The permittee shall submit the data reports required in Condition 14 no later than March 1 and September 1 of each year following the semiannual period in which the data were collected, unless otherwise approved by the Air Compliance Manager of the DEQ's NRO.
(9VAC5-80-900)

GENERAL CONDITIONS

16. **Permit Limitations** – Except to the extent that conditions in this permit may be more stringent, this permit does not supersede or replace any other valid permit, regulatory or statutory requirement. Furthermore, this approval to operate shall not relieve Covanta Fairfax, Inc. (CFI) of the responsibility to comply with all other local, state and federal regulations, including permit regulations.
(9VAC5-80-850)
17. **Federal Enforceability** – Once the permit is approved by the U.S. Environmental Protection Agency into the Commonwealth of Virginia State Implementation Plan, the permit is enforceable by EPA and citizens under the federal Clean Air Act.
(9VAC5-80-850)
18. **Permit Revision/Repeal** – The Board may revise (modify, rewrite, change or amend) or repeal this permit with the consent of CFI, for good cause shown by CFI, or on its own motion provided approval of the revision or repeal is accomplished in accordance with Regulations of the Board and the Administrative Process Act (§ 2.2-4000 *et seq.*). Such revision or repeal shall not be effective until the revision or repeal is approved by the U.S. Environmental Protection Agency following the requirements of 40 CFR Part 51 (Requirements for Preparation, Adoption, and Submittal of Implementation Plans).
(9VAC5-80-850)
19. **Failure to Comply** – Failure by CFI to comply with any of the conditions of this permit shall constitute a violation of a Permit of the Board. Failure to comply may result in a Notice of Violation and civil penalty. Nothing herein shall waive the initiation of appropriate enforcement actions or the issuance of orders as appropriate by the Board as a result of such violations. Nothing herein shall affect appropriate enforcement actions by any other federal, state, or local regulatory authority.
(9VAC5-80-850)
20. **Right of Entry** – The permittee shall allow authorized local, state, and federal representatives, upon the presentation of credentials:
 - a. To enter upon the permittee's premises on which the facility is located or in which any records are required to be kept under the terms and conditions of this permit;

- b. To have access to and copy at reasonable times any records required to be kept under the terms and conditions of this permit or the State Air Pollution Control Board Regulations;
- c. To inspect at reasonable times any facility, equipment, or process subject to the terms and conditions of this permit or the State Air Pollution Control Board Regulations; and
- d. To sample or test at reasonable times.

For purposes of this condition, the time for inspection shall be deemed reasonable during regular business hours or whenever the facility is in operation. Nothing contained herein shall make an inspection time unreasonable during an emergency.

(9VAC5-170-130 and 9VAC5-80-850)

21. **Notification for Facility or Control Equipment Malfunction** – The permittee shall furnish notification to the Regional Air Compliance Manager of DEQ's NRO of malfunctions of the affected facility or related air pollution control equipment that may cause excess emissions for more than one hour. Such notification shall be made as soon as practicable but no later than four daytime business hours after the malfunction is discovered. The permittee shall provide a written statement giving all pertinent facts, including the estimated duration of the breakdown, within two weeks of discovery of the malfunction. When the condition causing the failure or malfunction has been corrected and the equipment is again in operation, the permittee shall notify the Regional Air Compliance Manager of DEQ's NRO in writing.
(9VAC5-20-180 C and 9VAC5-80-850)

22. **Violation of Ambient Air Quality Standard** – The permittee shall, upon reasonable request of the DEQ, reduce the level of operation or shut down a facility, as necessary to avoid violating any primary ambient air quality standard and shall not return to normal operation until such time as the ambient air quality standard will not be violated.
(9VAC5-20-180 I and 9VAC5-80-850)

23. **Maintenance/Operating Procedures** – At all times, including periods of start-up, shutdown, soot blowing, and malfunction, the permittee shall, to the extent practicable, maintain and operate the affected source, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions.

The permittee shall take the following measures in order to minimize the duration and frequency of excess emissions, with respect to each municipal waste combustor (Ref. 001-01 through 004-01) air pollution control equipment, and process equipment which affect such emissions:

- a. Develop a maintenance schedule and maintain records of all scheduled and non-scheduled maintenance.
- b. Maintain an inventory of spare parts.
- c. Have available written operating procedures for equipment. These procedures shall be based on the manufacturer's recommendations, as available.
- d. Train operators in the proper operation of all such equipment and familiarize the operators with the written operating procedures, prior to their first operation of such equipment. The permittee

shall maintain records of the training provided including the names of trainees, the date of training and the nature of the training.

- e. Records of maintenance and training shall be maintained on site for a period of five years and shall be made available to DEQ personnel upon request.

(9VAC5-50-20 E and 9VAC5-80-850)

24. Permit Suspension/Revocation – This permit may be revoked if the permittee:

- a. Knowingly makes material misstatements in the permit application or any amendments to it;
- b. Fails to comply with the terms or conditions of this permit;
- c. Fails to comply with any emission standards applicable to a permitted emissions unit;
- d. Causes emissions from this facility which result in violations of, or interferes with the attainment and maintenance of, any ambient air quality standard;
- e. Fails to operate this facility in conformance with any applicable control strategy, including any emission standards or emission limitations, in the State Implementation Plan in effect at the time that an application for this permit is submitted;
- f. Fails to comply with the applicable provisions of Articles 6, 8 and 9 of 9VAC5 Chapter 80.

(9VAC5-80-1010)

25. Change of Ownership – In the case of a transfer of ownership of a stationary source, the new owner shall abide by any current permit issued to the previous owner. The new owner shall notify the Regional Air Compliance Manager of DEQ's NRO of the change of ownership within 30 days of the transfer.

(9VAC5-80-940)

26. Permit Copy – The permittee shall keep a copy of this permit on the premises of the facility to which it applies.

(9VAC5-80-860 D)

Attachment B

Excerpt from Ozone Transport Commission (“OTC”) Response to
Comments – Municipal Waste Combustor Stakeholder Process

Comments from Ozone Transport Commission (OTC) Municipal Waste Combustor (MWC) Stakeholders and OTC Responses

1. **Joe Walsh (Covanta):** Is there an email to send comments to?

OTC response: ccooper@nescaum.org

2. **MHB:** Has OTC or OTC member states considered whether recent pricing for urea affects the results of the study?

OTC response: The workgroup recognizes that the cost of consumables, including reagents, and material and labor related to NOx control has increased since the performance of the engineering studies that the workgroup referenced in developing its cost effectiveness estimates. The cost effectiveness estimates were developed with the goal of using those values, or range of values, to compare with pollution control RACT threshold values sometimes utilized by the states in judging the cost effectiveness of a proposed control strategy. Therefore the existing estimates allow a more even comparison to cost effectiveness thresholds that have been in place for some time to allow the reader to better judge the relative value of cost effectiveness estimates cited in the report. It is anticipated that unit specific RACT analysis performed in accordance with the applicable state's RACT procedure would be performed using the latest cost information to compare with the state's RACT threshold.

3. **George Drew (Covanta):** Has the MWC workgroup looked at other Covanta designs, such as Martin stoker or RDF combustion? If not, can that be reviewed as part of this project?

OTC response: The workgroup reviewed publicly available data for all MWC units located in the OTR. The bulk of the report concentrated on MWCs where there have been recent engineering studies or completed NOx reduction projects to assess commercially available NOx reduction technologies, the applicability and effectiveness of those reduction technologies, and the estimated cost effectiveness of those technologies. Additional analysis to address additional differences in MWC designs would require more unit specific NOx reduction project information than the workgroup was able to locate. The workgroup identified a number of NOx reduction technologies that are commercially available and applicable to many MWC designs. The report contains a brief discussion for a number of generic MWC designs and, where applicable, provides some information about the applicability of various NOx control for those generic MWC designs.

4. **George Drew (Covanta):** is this recommendation based on RACT criteria?

OTC response: The goal of the workgroup was to identify commercially available, technically feasible NOx reduction technologies applicable to large MWCs. Where engineering studies were available, cost effectiveness values were estimated. Presumptive NOx RACT rates were proposed, coinciding with the selected NOx reduction technologies and the associated cost effectiveness. It is anticipated that the proposed presumptive RACT rates could be utilized by a state for use in conducting unit

16. Michael Van Brunt (Covanta):

Thank you for the opportunity to participate in the OTC's December 14, 2021 stakeholder meeting regarding the Stationary and Area Sources Committee Municipal Waste Combustor (MWC) Workgroup Report, dated June 2021 (the "Report"). The Report summarized research and recommendations related to NO_x emissions from MWCs within the OTC region. Specifically, the Report identified existing NO_x reduction efforts undertaken at various MWCs, either voluntarily or in response to regulatory rule adoptions, with a specific focus on facilities located in Maryland and Virginia. The Report concludes, in part, that Covanta's Low NO_x (LNTM) proprietary technology can be deployed at our MWCs to achieve significant NO_x emission reductions. As discussed further below, Covanta owns and/or operates a variety of combustion technologies that require case-by-case evaluation of the effectiveness and feasibility of LNTM and other NO_x emission reduction technologies.

The following are our comments on the Report.

The limitations of Covanta Low NO_x (LNTM) should be more fully characterized in the Report.

Covanta's proprietary LNTM technology involves the staging of combustion air within the combustion chamber, along with the use of selective non-catalytic reduction (SNCR) to achieve lower NO_x emissions, as described in the Report. Specifically, the Report addresses Covanta's LNTM technology as implemented at the Covanta Fairfax (Lorton, VA), Covanta Alexandria (Alexandria, VA) and Montgomery County (Dickerson, MD) MWCs, along with references to the Hillsborough FL, Bristol, CT and Essex County, NJ MWCs. Based on public sources of information related to these facilities, the Report concludes that "information indicates that Covanta run facilities across a wide range of sizes and manufacturers, can be retrofitted with the proprietary Covanta LNTM technology and achieve significant [NO_x] reductions".

Covanta owns and/or operates MWC's located both within and outside of the OTC region. Our MWCs include multiple technology types as outlined in Tables 1 and 2 in the attached Appendix A. LNTM is currently operated on only two of those technologies.

Some of the remaining technologies may be amenable to LNTM; however, the efficacy of LNTM has not yet been demonstrated in practice. Differences related to combustion air flows, flue gas velocities, length and width of the combustion grate and furnace, heat transfer potential, number and location of auxiliary burners, etc. can have a significant impact on both the initial formation of NO_x in the furnace, as well as the effectiveness of combustion air staging in reducing that formation. For these technologies, we believe that it is premature to recommend a numerical limit that has been demonstrated through LNTM.

Other MWC technologies, including rotary combustors in place at two of our facilities in Pennsylvania, cannot be retrofitted with our current LNTM technology due to their unique equipment configuration. In addition, the Aireal grate technology deployed at the Susquehanna Resource Management Complex (Harrisburg, PA) has insufficient waste agitation and underfire air (combustion air below the grate) distribution to accommodate a LNTM retrofit. Our Resource Derived Fuel (RDF) units utilize air to disperse the waste onto the combustion grate which can cause temperature differentials within the combustion zone.

Still other MWC technologies already have combustion conditions roughly analogous to those developed under LNTM conditions, yet do not currently meet the limits the OTC is considering for

recommendation. We believe that there may be opportunities to reduce NOx emissions from these technologies following different approaches. As such, we have already committed to a voluntary effort with the PADEP to conduct an SNCR trial on one of the rotary combustors at our Delaware Valley facility in Chester, PA; however, we do not yet know the NOx concentrations we will be able to achieve in practice.

Given that LN™ has only been proven at two of the MWC technologies we operate, we recommend that the OTC clarify the potential application of LN™ as follows:

“Information indicates that the proprietary Covanta LN™ technology has achieved significant NOx reductions across a wide range of sizes for certain grate and boiler technology combinations. NOx reductions may be possible at other technologies or through other means but have not yet been demonstrated.”

OTC Response: The goal of the OTC’s MWC workgroup activity was to evaluate existing publicly available information for the purpose of developing recommended presumptive RACT limits for existing MWCs located in the OTR. These presumptive RACT limits were to represent the emission control capability of commercially available control technologies that could be retrofit on the existing MWCs in a cost-effective manner. The report identified a number of commercially available control technologies, both singly and in conjunction with other control technologies, that have the potential to achieve NOx emission reductions in retrofit installation for a variety of MWC sizes and configurations. It was not the intention of the workgroup to indicate that any individual technology example was capable of meeting the presumptive RACT limits on any given unit, but rather that its effectiveness had been demonstrated in industry.

The report includes a brief discussion of the generic types of MWCs found in the OTR. The report also includes discussion of available and applicable NOx control technologies that may be considered for retrofit application on those generic MWCs. The more detailed discussion of the Covanta trademark LN technology was very helpful to the workgroup and showcases the level of work and commitment by Covanta to control NOx emissions from its MWCs.

The presumptive RACT values proposed in the report represent NOx control capabilities that have been demonstrated to be technically feasible and within a range of cost effectiveness values utilized by some states in their NOx RACT evaluations. The workgroup feels that the proposed presumptive RACT values are technologically and economically feasible across a wide range of existing MWCs and may be helpful to states in their conduct of NOx RACT evaluations for individual MWC units located in their state.

While the workgroup does not feel that the existing language in the report implies that the Covanta trademark LN technology is the only retrofit NOx control technology available to any Covanta MWC, or that its control capabilities would be the same for all individual units, the workgroup does not have any issue with adding text that indicates the Covanta trademark LN is not universally applicable to all Covanta MWCs.

As indicated during the stakeholder meeting in December 2021, the OTC conducted a RACT-type analysis of the various MWC’s operating in the region. By rule, RACT analyses are to consider both technical feasibility and cost for each alternative evaluated. Specifically, the Report excerpts cost data from the NOx RACT analysis prepared for the Covanta Fairfax MWC and submitted to the Virginia

Attachment C

Babcock Power Waste to Energy NOx Feasibility Study Prepared for
Wheelabrator Technologies Baltimore Waste to Energy, Baltimore,
Maryland, BPE Project No. 100825 (February 20, 2020)



BabcockPower

E N V I R O N M E N T A L

a Babcock Power Inc. company

WASTE TO ENERGY NO_x FEASIBILITY STUDY

PREPARED FOR:

WHEELABRATOR TECHNOLOGIES
BALTIMORE WASTE TO ENERGY FACILITY
BALTIMORE, MARYLAND

BPE PROJECT NO. : 100825

BPE DOCUMENT NO.:
100825-0908400100
FINAL REVISION

FEBRUARY 20, 2020

TABLE OF CONTENTS

1.0 INTRODUCTION	4
2.0 EXISTING FACILITY OPERATIONS	4
2.1 BOILER DESIGN.....	4
2.2 EXISTING NO _x CONTROL TECHNOLOGIES & EMISSIONS PERFORMANCE	6
3.0 POTENTIAL NO_x CONTROL TECHNOLOGIES	6
3.1 EXISTING SNCR	6
3.1.1 Urea Breakdown and Activation Reactions.....	7
3.1.2 NO _x Reduction Reactions.....	8
3.1.3 NO _x Formation Reactions.....	8
3.2 ADVANCED SNCR (ASNCR).....	9
3.3 FGR-SNCR.....	10
3.4 FGR-ASNCR.....	10
3.5 HYBRID SNCR-SCR	11
3.6 DeNO _x CATALYTIC FILTER BAGS.....	12
3.7 TAIL-END SCR SYSTEMS.....	12
3.7.1 Traditional Tail-End SCR.....	13
3.7.2 Regenerative SCR (RSCR)	14
4.0 TECHNICAL FEASIBILITY OF NO_x CONTROL TECHNOLOGIES.....	15
4.1 EXISTING SNCR	15
4.2 ADVANCED SNCR	15
4.3 FGR-SNCR.....	16
4.4 FGR-ASNCR.....	17
4.5 HYBRID SNCR-SCR	18
4.6 DeNO _x CATALYTIC FILTER BAGS.....	19
4.7 TAIL-END SCR SYSTEMS.....	19
4.7.1 Traditional Tail-End SCR.....	21
4.7.2 Regenerative SCR (RSCR)	21
5.0 ESTIMATED CAPITAL AND OPERATING COSTS	23
5.1 EXISTING SNCR	23
5.2 ADVANCED SNCR	23
5.3 FGR-SNCR.....	24
5.4 FGR-ASNCR.....	24
5.5 TAIL-END SCR SYSTEMS.....	25
5.5.1 Traditional Tail-End SCR with Existing ESP ^k	25
5.5.2 Traditional Tail-End SCR with New PJFF	26
5.5.3 Regenerative SCR (RSCR) with Existing ESP ^k	26
5.5.4 Regenerative SCR (RSCR) with New PJFF.....	27

5.6	ESTIMATED ANNUAL OPERATING COSTS.....	29
5.7	CATALYST REPLACEMENT COST	29
6.0	ESTIMATED PROJECT TIMELINE	31
6.1	CONSTRUCTION APPROACH FOR NEW PJFF OPTIONS.....	31
7.0	REFERENCES	32
APPENDIX A	PRELIMINARY SCHEDULE.....	A-1
APPENDIX B	ARRANGEMENT DRAWINGS	B-1
APPENDIX C	REFERENCE LISTS.....	C-1

1.0 INTRODUCTION

The purpose of this study is to provide a feasibility analysis for additional control of NO_x emissions from the Wheelabrator Baltimore Waste-to-Energy (WTE) Facility. The three (3) Municipal Waste Combustors (MWCs) at Wheelabrator Baltimore converts a maximum of 2,250 tons per day (750 tpd per MWC) of post-recycled municipal solid waste from Baltimore area homes and businesses as a local, sustainable fuel to generate as much as 64.5 gross (52 net) MW of electricity for sale to the local utility in addition to supplying steam to downtown Baltimore city businesses.

In this study, Babcock Power Environmental (BPE) details existing facility operations and performance and provides an overview of currently available technologies to enhance current NO_x emission levels. Each technology is then analyzed for technical feasibility. Capital and operating costs, along with an estimated timeline for installation are also included for those technologies deemed technically feasible.

BPE is not a subject matter expert on Selective Non-Catalytic Reduction (SNCR) systems. BPE therefore contracted with Fuel Tech, Inc. as a part of this study to provide a more comprehensive analysis of SNCR and Advanced SNCR (ASNCR) system capabilities. Discussions in this study on SNCR and ASNCR technology and performance are the work of Fuel Tech, Inc.

This NO_x feasibility study addresses the NO_x control technology processes, predicted performance, and plant arrangement. Detailed engineering, design, and construction of essential project parameters such as electrical work, civil work (foundations, pilings, site preparation), and balance of plant for integrating the various NO_x control technologies into existing plant have not been technically evaluated as a part of this feasibility study. However, costs for these have been considered per industry standards in the estimation of capital costs [1].

2.0 EXISTING FACILITY OPERATIONS

2.1 Boiler Design

Wheelabrator Baltimore WTE Facility consists of three (3) MWCs with Sterling power boilers supplied by the Babcock & Wilcox Company. The facility has been operating since 1983. Each MWC boiler was designed to process 750 tons per Day (TPD) of municipal solid waste (MSW), having a high heating value of 5,200 Btu/lbm, and generates 193,600 lbm/hr of superheated steam at 850 psia and 830°F. An economizer heats the feedwater temperature from 290°F to 500°F. The stoker on this MWC is a Von Roll reciprocating design. The height, width, and depth of the boiler's furnace are 88 feet (measured in the middle of the furnace from top of stoker to the roof tubes), 26.5 feet, and 19 feet 11 inches respectively. The bullnose on the rear wall at the middle elevation of the furnace redirects flue gas upward toward the front of the furnace and through the waterwall platens. Each furnace is equipped with twelve (12) waterwall platens located across the width of the furnace front wall. The waterwall platens provide additional surface area for heat absorption to moderate gas temperature entering the superheater to minimize high temperature corrosion of the superheater tubes. The flue gas flows across the

superheater tubes in the direction east to west. It then flows down across and over the vertical boiler bank tubes and then across and up through the economizer's vertical tubes.

The flue gas flow is pushed towards the rear wall, reducing residence time and limiting chemical coverage for SNCR urea injection.




Figure 1: Wheelabrator Baltimore Municipal Waste Combustor

2.2 Existing NO_x Control Technologies & Emissions Performance

At the Baltimore facility, each of the three (3) MWCs is currently equipped with a Selective Non-Catalytic Reduction (SNCR) system supplied by Fuel Tech. Section 3.1 provides a high-level description of the SNCR process, along with some critical SNCR process parameters.

The existing SNCR systems have been optimized to meet the NO_x Reasonably Available Control Technology (RACT) limit of 150 ppmvd at 7% O₂ (average), which became effective on May 1, 2019. The existing systems will also be able to meet the 30-day rolling average limit of 145 ppmvd 7% O₂ that will become effective on May 1, 2020. The 150 ppmvd limit has been met to date without evidence of excess ammonia that could potentially cause a visible ammonium chloride plume.

The SNCR system has injectors located at Elevation 82'-3" with one (1) injector per corner, one (1) injector per side wall, and two (2) injectors on the rear wall for a total of eight (8) in each MWC furnace. The injectors are equipped with variable spray angle tips. Although the injectors are fixed, changing the point of chemical release by changing injector tip angle and adjusting atomizing air and/or dilution water flow provides additional flexibility to optimize system further. Specifically, if the temperature is higher than anticipated, larger droplets will delay the chemical evaporation and the reaction will take place at a lower temperature environment thus optimizing the performance of the SNCR system.

3.0 POTENTIAL NO_x CONTROL TECHNOLOGIES

BPE and Fuel Tech have identified several potential NO_x control technologies that were evaluated as part of this feasibility analysis. The following section outlines the identified technologies in general terms. The feasibility of those technologies as they relate to the Baltimore facility is detailed in Section 4.0.

3.1 Existing SNCR

As discussed in Section 2.2, each of the three (3) units is currently equipped with a Selective Non-Catalytic Reduction (SNCR) system. Urea (a nitrogen-based reducing agent, or reagent) is injected into the post-combustion flue gas. The SNCR process occurs within the furnace, which acts as the reaction chamber. The reagent is injected via nozzles mounted on the walls of the furnace. The heat of the boiler provides energy for the reaction, which reduces the NO_x molecules into molecular nitrogen (N₂) and water vapor (H₂O). Note that the NO_x is represented as NO since it is the predominant form of NO_x within the boiler. The temperature window for effective SNCR performance is a function of the baseline NO_x but typically ranges between 1600°F and 2000°F.

The successful implementation of the urea based SNCR technology is predicated on the ability to introduce urea as a liquid spray (a mixture of 50% urea solution and dilution water as carrier) into the boiler using specialized injectors. These spray droplets travel through the furnace until they evaporate with NO_x reduction reactions start only after the chemical has been released. The SNCR reactions are all gas phase and the term "reaction temperature" is used interchangeably

with temperature at the point of chemical release. This reflects the location where the chemical starts to react. Residence time refers to the time available for reaction after chemical release while the reducing agent is still within the appropriate chemical and thermal environment.

Figure 2 below illustrates the mechanics of urea injection into a boiler.





Figure 2: SNCR System with Multiple Levels of Injection


There are close to 100 chemical reactions involving more than 30 species in the SNCR mechanism that utilizes urea as a reducing agent. The overall reaction, however, can be expressed as follows:



Chain radical species such as O, H, and OH are required for the reactions to proceed. While NO_x reduction and formation reactions take place continuously, the temperature and the concentration of the OH radicals are the determining factors as to which reaction path will dominate. The activation, reduction and formation reactions are listed below:


3.1.1 Urea Breakdown and Activation Reactions

Urea in itself does not react with NO_x, but under high temperature conditions generates NH₂ and NCO. These are the species that react with NO_x.



3.1.2 NO_x Reduction Reactions

NH₂ and NCO react with NO_x, stripping off an oxygen atom and reducing it to molecular nitrogen.



3.1.3 NO_x Formation Reactions

NH₂ and NCO react with hydroxyl radicals and generate NO_x.



Although application specific, typically at high temperatures above approximately 2050°F), the NO_x formation reactions dominate while at lower temperatures the NO_x reduction reactions become predominant. At temperatures below 1500°F, the chemical kinetics slow down considerably, and the activation reactions proceed at a very slow rate. Not only is NO_x not reduced, but the NH₃ is not converted to NH₂ quickly enough resulting in high ammonia slip as a byproduct of the injection. Figure 3 below shows a generic depiction of NO_x reduction and ammonia slip vs. temperature.




Figure 3: NO_x Reduction and Ammonia Slip vs. Temperature

3.2 Advanced SNCR (ASNCR)

An Advanced-SNCR (ASNCR) system utilizes acoustic or laser-based means of producing near real-time maps of furnace temperature conditions that are then used to control the location and manner of injection for NO_x control. In some cases, the temperature monitoring is the primary control signal used to control urea and/or dilution water flow. In other cases, the temperature monitoring is used to select injectors within an injection zone for special operations.

Typically, urea based SNCR systems have logic designed to control operations based on unit load, CEMS NO_x, upper furnace temperature, and ammonia slip data. The Advanced SNCR system provides additional flexibility, utilizing Computational Fluid Dynamics (CFD) modeling and Chemical Kinetic Modeling (CKM) technology in concert with near real-time furnace temperature maps to modify individual injection selection or urea flow rates.

SNCR “performance” can be measured in many ways, and all are important to varying degrees. The achievable NO_x reduction and ammonia slip are the foremost measures of performance. The chemical utilization is also critical to the operating cost of the system, as are the amount of dilution water and injection air used. Finally, the ability of the system to operate dynamically and effectively over a wide load range is also significant.

In simplified terms, the temperature profile can be mapped over an existing control scheme to activate only the injectors that are expected to provide the best performance. This can be managed in the short-term by responding to apparent conditions in the furnace. A schematic illustrating temperature-based injector selection is shown in Figure 4. It has also been possible to measure variations in the furnace and develop algorithms to predict expected conditions in the near future. These algorithms include predictions of furnace gas concentrations and temperature changes that can be anticipated to improve chemical use and minimize balance of plant impacts.




Figure 4: Schematic Illustrating Temperature-Based Injector Selection

The optimized injection strategy can be determined by CFD and CKM modeling and field evaluation.

3.3 FGR-SNCR

The FGR-SNCR option incorporates Flue Gas Recirculation (FGR) into the SNCR design.

In this option, a portion of the flue gas from combustion is recirculated from the ID fan inlet duct and is then re-injected back into the furnace through the over-fire air system. FGR is used to replace a portion of the secondary air flow, this reduces use of ambient air and O₂ concentration or stoichiometric excess ambient air while still maintaining the secondary air gas flow needed for mixing in the furnace.

The addition of FGR provides additional NO_x emission reduction in several ways:

- Lowers combustion temperatures in the furnace.
- Improves mixing in the furnace; and
- Reduces excess ambient air during the combustion process.

NO_x formation is the inevitable result of combustion. NO_x is formed by three potential mechanisms. The first mechanism entails the high-temperature oxidation of the nitrogen found in the combustion air, and NO_x formed in this manner is called thermal NO_x. The second mechanism refers to the oxidation of the nitrogen component in the fuel, and NO_x formed in this manner is called fuel NO_x. The final mechanism forms what is called prompt NO_x, and is based on reactions between hydrocarbon radicals and molecular nitrogen in the flame zone. Prompt NO_x is a minor contributor to the overall NO_x, while fuel NO_x on the other hand, contributes between 50 and 80% of the overall NO_x emissions. The formation of thermal NO_x is described by the Zeldovich Equation:

$$[\text{NO}] = K_1 e^{(-K_2/T)} [\text{N}_2][\text{O}_2]^{1/2} t \quad (9)$$

where, T = temperature, t = time, and K₁ and K₂ are constants.

According to the above equation, NO_x can be reduced by lowering the average flame temperature as well as the average oxygen concentration. This can be accomplished by adding recirculated flue gas to the combustion air, thus lowering the flame temperature and diluting the local oxygen concentration.

3.4 FGR-ASNCR

It is also possible to combine the FGR technology described in Section 3.3 with the ASNCR technology described in Section 3.2. The implementation of ASNCR by adding additional independent zones of injection and an acoustic pyrometer can provide additional NO_x reduction while controlling the ammonia slip.

3.5 Hybrid SNCR-SCR

The Hybrid SNCR-SCR option utilizes two treatment stages: an SNCR treatment stage followed by an SCR treatment stage. There is a common misconception that, in a hybrid arrangement, the reagent is over-injected in the SNCR stage. In a stand-alone SNCR application, the reducing agent is released at higher temperatures to minimize ammonia slip formation. In hybrid applications, the ammonia slip becomes the reducing agent over the catalyst. As such, the SNCR process is no longer restricted by temperature, and injection at lower temperature is customary to the extent that unit geometry allows it and there is no risk of chemical impingement on the boiler surfaces.

Releasing the chemical at a cooler temperature accomplishes three (3) objectives: it allows the SNCR to achieve lower target NO_x limits, minimizes NO_x formation reactions, and improves chemical utilization. In addition, due to the lower temperature of chemical release, a controlled, but higher concentration of ammonia is available to feed the catalyst. The excess ammonia slip from the first stage then reacts in the presence of the downstream in-duct catalyst located downstream in the flue gas path. In some cases, a static mixer is installed at the economizer outlet to provide the additional mixing required to achieve good NH₃/NO_x distribution across the face of the catalyst.

The combination of these two technologies also allows for a higher NO_x reduction and improved chemical utilization versus a standalone SNCR system. For a standalone SNCR, higher SNCR NO_x reductions are theoretically possible, with the limiting factors being the ability to treat a large percentage of the total flue gas and being restricted by NH₃ slip limitations. Perhaps the most advantageous aspect of combining the two technologies is that by having the catalyst behave as an ammonia “mop,” one removes the second limitation and increases the potential NO_x reduction efficiency of the SNCR.

Installing an in-duct catalyst downstream of an SNCR has an enabling effect on SNCR performance. The SCR catalyst is typically installed in a high dust environment at the boiler economizer outlet. Urbas explains that “SNCR NO_x reduction occurs in a defined temperature window, roughly bell-shaped, with maximum SNCR NO_x reduction occurring at the top, or plateau of the bell. In a commercial ‘stand-alone’ SNCR, the system is operated within the slope area on the right side of the temperature window curve. In this region, the hot side of the performance maximum, ammonia slip is very low or nonexistent. This is often an operating constraint imposed by the source owner. In contrast, the SNCR component of the hybrid system operates best at the plateau, which is in a lower temperature region. In this region, SNCR NO_x reductions are maximized and some ammonia slip is produced. The ammonia slip that is produced is available for additional NO_x reductions with a downstream catalyst system. When operated in this manner, SNCR NO_x reduction is maximized (compared to its stand-alone performance) and additional NO_x reductions are realized from the catalyst, which is fueled by the SNCR generated ammonia slip [2].” Although this temperature window is a function of the baseline NO_x, it typically ranges between 1600°F and 2000°F. The “hot side of the performance maximum,” as described above, typically equates to chemical release temperatures in the 2000°F range. The SNCR component of hybrid systems are capable of operating at nominal temperatures in the 1800°F range (and

slightly lower). Refer to Figure 3 for an illustration of the bell-shaped temperature curve discussed above. The operating temperature range of the SCR catalyst is generally between 550°F and 750°F. The actual minimum and maximum temperatures depend on the flue gas constituents, catalyst design requirements, and boiler operation.

A hybrid SNCR-SCR also has a lower capital cost than a full-scale SCR. Given typical conditions, the ductwork modifications needed for a hybrid SNCR-SCR and additional component weights can be accommodated by the existing structural steel without the need for new foundations while far less catalyst is used. In addition, the pressure drop of the system is typically considerably less than for a standalone SCR.


3.6 DeNO_x Catalytic Filter Bags

In lieu of typical Pulse Jet Fabric Filter (PJFF) bags, DeNO_x catalytic filter bags can be utilized with ammonia injection to reduce NO_x in a similar fashion to traditional SCR catalyst. These combination bags remove both dust and gaseous compounds simultaneously. A typical DeNO_x catalytic filter bag is comprised of one to three layers of fabric; one lined with a PTFE membrane and each including its own unique catalytic formula. DeNO_x filter bags provide good resistance to catalyst poisoning, and service life, and pressure drop are both comparable to conventional fabric filters. Typical minimum operating temperatures for catalytic filter bags range from 356°F [3] to 430°F [4] depending on flue gas constituents and catalyst formulation. Note that this range of minimum operating temperatures is not specific to the WTE industry.

3.7 Tail-End SCR Systems

A Tail-End system positions the SCR downstream of all other air pollution control equipment installed on a unit. A major benefit of this installation location is that many of the flue gas constituents that would be damaging to the catalyst have been removed prior to the SCR reactor inlet. However, the installation location results in flue gas temperatures below the acceptable range for catalytic reduction, and the flue gas consequently must be reheated via natural gas or oil burners or steam coil heaters.

The Tail-end SCR process converts the NO_x contained in the flue gas into nitrogen and water with the use of ammonia as the reduction agent. The basic reactions are the following:



The following side reactions may occur on a small scale:



The flue gas entering the SCR System typically contains SO₂, a portion of which will be catalytically oxidized to SO₃, as shown below:



The NO_x reduction process requires specifically formulated catalyst to achieve the necessary reaction rates at the available Tail-End SCR operating temperatures, i.e., greater than 450°F. The NO_x reduction efficiency of the catalyst increases with rising temperature. At very high gas temperatures, above ~800°F, the catalyst can be damaged due to sintering. Additional consideration must be taken in the catalyst design to prevent the formation of ammonium bisulfate (ABS) from SO₃ and ammonia, a sticky salt that reduces catalyst activity by fouling the catalyst surface. ABS formation only becomes problematic for operation at low temperatures (below the ABS dew point). ABS condensation in the catalyst is a reversible reaction. If the catalyst is heated regularly to typically 320-350°C (608-662°F), the ABS will evaporate, regaining catalyst activity [5].

3.7.1 Traditional Tail-End SCR

A Traditional Tail-End SCR operates in much the same way as a high-dust SCR. However, the flue gas temperature at tail-end locations is typically expected to be between 300°F and 330°F. In order to increase the temperature of the flue gas, the SCR is equipped with a gas-gas heat exchanger (GGH), followed by an in-duct burner or steam coil heater to provide the energy required to raise the flue gas temperature to levels required for effective catalyst performance (see Figure 5). This arrangement increases the flue gas temperature for optimal performance by the catalyst, and then the GGH recovers the energy by using the heated gas at the SCR outlet to help increase the temperature of the cooler incoming gas.

Typically, there is leakage across the GGH. Additionally, the heat recovery is approximately 60%.




Figure 5: Traditional Tail-End SCR Arrangement

In a retrofit, most facilities are not able to overcome the additional pressure loss across the SCR and GGH with existing ID fans. In general, a new booster fan is provided for each reactor to bear the increased draft loss associated with this equipment. In lieu of a new booster fan, replacement or modification of the existing ID fans may also be considered.

3.7.2 Regenerative SCR (RSCR)

An RSCR system is designed to reduce NO_x , CO and VOCs as a tail-end unit. Similar to the traditional tail-end SCR discussed above, the flue gas temperature is too low to reduce NO_x and oxidize CO/VOC emissions. To increase the temperature of the flue gas, the RSCR system is equipped with either natural gas burners, oil burners, or steam coil heaters to increase the temperature to an acceptable range for the catalytic reduction. To recover the added heat, the RSCR utilizes a heat recovery bed comprised of >95% thermal efficient ceramic media and flue gas directional changes to transfer the heat between canisters.

The RSCR reactor is configured in a canister pair with a heat retention chamber connecting the two canisters, as shown in Figure 6 and Figure 7 below. Each canister has an inlet and outlet damper which directs the flow through the canister pair.

Once the RSCR system is at steady state, the incoming low temperature flue gas will absorb heat from the inlet heat recovery bed to achieve temperatures suitable for emission reduction prior to entering the catalyst. As the flue gas passes through one layer of catalyst, it continues to increase in temperature by passing through the burner flame/steam coil between canisters. As the flue gas exits the second layer of catalyst, it passes through the outlet heat recovery bed where the ceramic thermal media recovers the heat added to the inlet flue gas. The heat recovery beds have greater than 95% thermal efficiency which minimizes the amount of external energy required to offset the heat loss through the system.




Figure 6: RSCR Flow Sequence Cycle One [15]




Figure 7: RSCR Flow Sequence Cycle Two [15]

As discussed in Section 3.7.1, most facilities cannot overcome the additional pressure loss across the RSCR with existing ID fans in a retrofit. In general, a new booster fan is provided for each reactor to bear the increased draft loss associated with this equipment. In lieu of a new booster fan, replacement or modification of the existing ID fans may also be considered.

4.0 TECHNICAL FEASIBILITY OF NO_x CONTROL TECHNOLOGIES

The technical feasibility of each of the technologies discussed in Section 3.0 above was evaluated based on the existing equipment arrangement, system performance, and site constraints of the Baltimore facility. For the purposes of the feasibility study, all values presented in this section were based on a single point steam flow of 191,840 lb/hr, not a range of values. For detailed design, a full fuel analysis, heat input, and fuel throughput range should be analyzed to confirm that the values presented herein are applicable for the entire boiler load range.

4.1 Existing SNCR

CFD models show a large recirculation zone that pushes the flue gas towards the rear wall. This recirculation zone is a result of the geometry of the lower furnace arches and the waterwall platens. The velocity contours suggest that the flue gas velocity is in the 10 to 14 m/s range, leading to reduced residence time and increasing the potential for ammonia slip formation.

The SNCR performance of the Baltimore MWCs is impacted by the presence of the waterwall platens and pendant superheater in the furnace. In order to minimize the risk of impingement on these surfaces and control the ammonia slip, the injectors are placed at a lower elevation thus releasing chemical at higher temperature somewhat limiting the achievable NO_x reduction.

The existing SNCR system can consistently control NO_x to levels below 150 ppmvd @ 7% O₂ on a 24-hour block average and 145 ppmvd @ 7% O₂ on a 30-day rolling average. The existing SNCR system may be capable of maintaining a controlled NO_x level of 135 ppmvd @ 7% O₂ on a 24-hour block average and 130 ppmvd at 7% O₂ on a 30-day rolling average while limiting the ammonia slip to approximately 5 ppmvd to avoid a visible ammonium chloride plume. However, the exact magnitude of these values must be confirmed via further tuning. As the City of Baltimore has a 0 visible plume limit, the amount of ammonia slip leaving the system is a critical process parameter. The capture rate of any ammonia slip in the particulate collection system is extremely limited with the existing ESP. This option is technically feasible with further field optimization and tuning.

Overall improvement of the remaining technologies is evaluated against a baseline of the further-optimized controlled NO_x level of 135 ppmvd @ 7% O₂ on a 24-hour block average and 130 ppmvd at 7% O₂ on a 30-day rolling average.

4.2 Advanced SNCR

Taking into account the presence of the recirculation zone and the need to avoid waterwall platen and superheater impingement from urea injection, injectors will need to be placed at multiple (at least two) elevations for the ASNCR concept to be viable. The average temperature at the 4th floor elevation is 2050°F, so placing injectors below the 4th floor will have the potential to increase NO_x or at least degrade the chemical utilization. The chemical coverage may be improved by adding more injectors on the rear wall at the 4th floor, and also by adding some injectors on the front wall at a slightly higher elevation. The front wall injectors may be releasing a small amount

of chemical within the recirculation zone, but these droplets are expected to be fully evaporated by the time they reach the waterwall platens. To eliminate any risk of impingement, the injectors will be placed based on guidance from the CFD and chemical spray modeling that will be done during the design phase. These injectors will be releasing chemical at lower temperature allowing for lower target NO_x levels. The acoustic pyrometer will provide the temperature profile across the entire furnace cross section. It should be noted that when implementing the ASNCR process, the ability to release chemical at a lower temperature is not so much a result of placing injectors at much higher elevations, but rather taking advantage of local, low temperatures across the cross-sectional area and biasing chemical toward that section of the furnace. Similarly, certain injectors will be removed from service if they are spraying in an area where the temperature falls above a design value while other injectors will be operating at different chemical and dilution water flows.

The optimum injector locations cannot be specified at this time as Fuel Tech has not performed the CFD and chemical spray modeling on these units. Based on experience, however, a 5% improvement in chemical coverage is feasible, leading to a target NO_x of 110 ppmvd @ 7% O₂ on a 24-hour block average and 105 ppmvd at 7% O₂ on a 30-day rolling average while the ammonia slip is kept at the 5 ppm range. It should be noted that without the acoustic pyrometer, this lower level of controlled NO_x would not be feasible at low slip. The anticipated chemical consumption, allowing for baseline swings and higher temperatures, ranges between 35 and 40 gph. An Advanced SNCR (ASNCR) system may be capable of maintaining a controlled NO_x level of 110 ppmvd @ 7% O₂ on a 24-hour block average and 105 ppmvd at 7% O₂ on a 30-day rolling average while limiting the ammonia slip to 5 ppmvd by incorporating an acoustic pyrometer and by the automatic addition/redistribution of injectors at different elevations as guided by CFD modeling.

This option is technically feasible with future CFD and chemical spray modeling where particular attention will be paid to injector placement so that there is no risk of chemical impingement on the superheater and waterwall platens and other boiler surfaces. An improvement of 25 ppmvd at 7% O₂ on a 30-day rolling average can be realized over the optimized existing SNCR.

4.3 FGR-SNCR

The FGR-SNCR option was evaluated using a boiler heat transfer model. FGR rate was limited to 15% of the total flue gas from combustion because of superheat attemperator spray flow rates considerations. The boiler model showed higher FGR rates would increase superheater heat pick up. FGR rates were limited to not increase attemperator spray flow above the attemperator system capacity. FGR allowed stoichiometric excess ambient air to be reduced from 80 -100% down to 60%.

The flue gas for the FGR system will be extracted from the ID fan inlet duct through an FGR fan. The FGR fan will re-inject the flue gas into the over-fire air ports. Some modifications to the units will be needed to install the ductwork and FGR fan. See Appendix B for the Proposed Flue Gas Recirculation Addition modifications. Duct routing must be verified during a detailed analysis to confirm final arrangement feasibility. Additional local analysis of the steel supporting the new

ductwork and fan would also be required to determine the extents of any required steel reinforcements. Reinforcements are assumed to be minimal and a nominal tonnage was included in the cost evaluation. It is anticipated that no changes would be required to main steel and existing columns.

The FGR-SNCR option is designed jointly by BPE and Fuel Tech. Fuel Tech has applied SNCR on municipal solid waste combustors equipped with FGR. SNCR systems have been installed on units equipped with FGR worldwide. These applications include multi-pass furnace units such as the Covanta design and single pass furnace units such as the Volund or CNIM designs. FGR tends to impact the thermal and chemical environment of the flue gas by lowering the temperature and baseline NO_x , and increasing the CO concentration. Multi-pass furnace units tend to provide longer residence time at temperatures conducive to SNCR than single pass furnace units such as Wheelabrator Baltimore. These parameters are all taken into consideration during the evaluation of the SNCR process and selection of injector locations.

BPI has provided Fuel Tech with an estimate of operating conditions if FGR were to be implemented. The baseline NO_x for the purpose of this study is assumed to be 190 ppmvd at 7% O_2 , however the exact magnitude and/or range must be confirmed during detailed design. The temperature at the bullnose elevation is expected to be 25°F lower than the base case, while the operating O_2 is 1.4% lower on a dry basis than the base case. This lower oxygen may give rise to a slightly higher CO concentration at the point of chemical release, but overall the thermal and chemical environment is not expected to change significantly. Since the acoustic pyrometer will not be in use under this condition, injectors cannot be placed at higher elevations (lower temperature of chemical release) to ensure that the ammonia slip stays under control. Guided by the CFD, however, injectors can be repositioned at the 4th floor elevation thus improving the chemical coverage in excess of 60%.

Based on the performance attained by the existing SNCR system, an FGR-SNCR system should be capable of maintaining a controlled NO_x emissions level of 120 ppmvd @ 7% O_2 on 24- hour block average and 115 ppmvd at 7% O_2 on a 30-day rolling average while limiting the ammonia slip to 5 ppmvd after redistribution of injectors as guided by CFD modeling and starting from a lower baseline NO_x . Since the injectors will only be redistributed at the 4th floor elevation to optimize chemical coverage and will not be placed at a higher elevation due to ammonia slip concerns, the risk of chemical impingement on the superheater platens will be negligible as in the case with the existing SNCR system.

This option is technically feasible from both an arrangement and performance perspective with future CFD modeling. An improvement of 15 ppmvd at 7% O_2 on a 30-day rolling average can be realized over the optimized existing SNCR.

4.4 FGR-ASNCR

As mentioned in Section 4.3, the installation of FGR on the Baltimore combustors has the potential of reducing the baseline NO_x to 190 ppmvd at 7% O_2 . The implementation of ASNCR by

adding additional zones of injection and an acoustic pyrometer can provide significant reduction while controlling the ammonia slip. Assuming the same 5% improvement in chemical coverage used for the stand alone ASNCR, a target NO_x of 100 ppm_{dv} at 7% O₂ while the ammonia slip is kept at the 5 ppm range is expected to be achievable. The anticipated chemical consumption, allowing for baseline swings and higher temperatures, ranges between 30 and 35 gph. An FGR/ASNCR system should be capable of maintaining a controlled NO_x level of 105 ppm_{dv} @ 7% O₂ on a 24-hour block average and 100 ppm_{dv} at 7% O₂ on a 30-day rolling average while limiting the ammonia slip to 5 ppm_{dv}. This is accomplished by incorporating an acoustic pyrometer and by the addition/redistribution of injectors at different elevations as guided by CFD modeling while starting from a lower NO_x baseline.

This option is technically feasible from both an arrangement and performance perspective with future CFD modeling. An improvement of 30 ppm_{dv} at 7% O₂ on a 30-day rolling average can be realized over the optimized existing SNCR.

4.5 Hybrid SNCR-SCR

As in the case of Advanced SNCR, injectors can be repositioned to achieve better chemical coverage and injectors can be added at slightly higher elevations to target those flue gas temperatures that provide higher utilization without creating concerns about ammonia slip. Based on the geometry of these units, and out of concern for impingement on the front waterwall platens, the SNCR NO_x reduction will be limited to an approximately 10 to 15% increase above the reduction achieved by the existing “as-is” SNCR system by not limiting the slip and without reducing the chemical utilization.

The design of the catalyst component must consider facility requirements for ammonia slip and allowable additional pressure loss. Multiple catalyst vendors were consulted regarding their previous experience with hybrid arrangements, potential issues, catalyst poisons, and typical catalyst life in a high-dust municipal solid waste (MSW) application. Some vendors had no direct experience at all with this arrangement and were unable to provide insight. Those with experience indicate that deactivation is very high in a high-dust environment, and therefore the vendor would be unable to provide any performance guarantees for this arrangement.

For waste to energy facilities firing municipal solid waste, lead and other trace metals are present in the flyash. Lead has been reported to “cause serious catalytic poisoning by either chemical reaction, or by the introduction of a barrier between the gas phase and the active sites [6].” Other publications also suggest that in waste combustion, catalyst must be placed downstream of particulate removal devices in order to prevent fouling [7].

A recent study analyzed SCR catalysts after placing them in a slipstream from an MSW combustion plant. In the most deactivated catalyst, there was a reduction in activity of 94% over a period of 1,951 hours [6].

BPE was unable to locate references of any full-scale Hybrid SNCR-SCR systems installed in the United States in the MSW combustion industry. Due to high deactivation rates of the catalyst and

lack of reference installations, the Hybrid SNCR-SCR option is not considered technically feasible for the Baltimore facility.

4.6 DeNO_x Catalytic Filter Bags

Several challenges exist with the DeNO_x catalytic filter bag option. The addition of a PJFF will most certainly result in an increase in system pressure loss. ESP installations typically require a pressure drop of approximately 0.5 inches of water column [8] at minimum. PJFF installations typically require a pressure drop of around 4 to 10 inches of water column [9]. While the pressure drop across DeNO_x catalytic filter bags is comparable to traditional PJFF bags, the resulting increase in pressure loss from the exchange of the existing ESPs for new PJFFs will require the upgrade or replacement of the existing ID fans; the currently installed fans are not capable of overcoming the additional loss.

Temperature presents another challenge for catalytic filter bags at the Wheelabrator Baltimore facility. In the current system arrangement, each of the ESPs is located downstream of a Spray Dryer Absorber (SDA). The USEPA states that “optimal temperatures for SO₂ removal for dry sorbent injection systems range from 150°C to 180°C (300°F to 350°F) [10].” Data from the facility indicates that from 2016 to 2018, ESP outlet temperatures ranged from 298°F to 313°F. Typical minimum operating temperatures for catalytic filter bags range from 356°F [3] to 430°F [4]. As these filter bags contain catalyst, similar concerns regarding ammonium bisulfate (ABS) exist when operating below the ABS dew point (see Section 3.7). Increase of the SDA operating temperature in order to satisfy the catalytic filter bag temperature requirement would sacrifice SO₂ removal and ability to meet the required SO₂ limit.

Additionally, the USEPA indicates that, as temperatures approach 350°F, the effectiveness of powdered activated carbon (PAC) reduces rapidly; an increase in ESP inlet temperature from 300°F to 350°F during one study reduced mercury removal from approximately 90% to 10 to 20% [11]. In fact, the ability of most PAC formulations to adsorb mercury begins to deteriorate at 333°F, with a more rapid deterioration beginning at 350°F [12].

Due to operating temperature requirements, the DeNO_x Catalytic Filter Bag option is not considered technically feasible for the Baltimore facility.

4.7 Tail-End SCR Systems

System Arrangement Considerations

Potential locations for the tail-end SCR systems at grade are very limited. Sufficient space is not available between the outlet of the ESPs and the inlet of the ID fans at grade. The only available locations for the SCRs at grade are a significant distance from each respective flue gas path and would require a substantial amount of ductwork to and from each SCR. This carries with it not only a large material cost (in ductwork, steel, and foundations), but also an increase in additional pressure drop across the system. For these reasons, this layout is considered to be impractical.

Appendix B includes arrangement drawings detailing this option for the RSCRs (the larger of the tail-end options).

In order to overcome the lengthy ductwork runs of locating the SCR at grade, placement above the existing ESPs or new PJFFs was considered. This location is more physically feasible. Appendix B includes arrangement drawings detailing this option for both Traditional Tail-End SCR and RSCRs. Additional evaluations must be performed to determine final feasibility. These evaluations must look at the existing foundations and steel structures as well as ensuring there is adequate space for new foundations and steel required to support the new equipment while maintaining proper access to existing equipment for maintenance. BPE has located several traditional SCR in a similar fashion (essentially framing them above existing equipment) and has found this to be a viable option when space is limited.

As discussed in Sections 3.7.1 and 3.7.2, installation of a traditional tail-end SCR or RSCR results in increased total system pressure loss. The existing ID fans do not have enough capacity to overcome this increase. The booster fan for each SCR should be located at grade, but this option requires a significant amount of ductwork between the SCR and the booster fans. BPE believes that replacement of the existing ID fans with new fans capable of overcoming the additional pressure loss is a more practical option for both tail-end options due to the facility space constraints.

For the purposes of this study, both options are investigated in the interest of comprehensiveness.

All Tail-End systems have been evaluated at two (2) upstream conditions:

- Existing upstream ESP remains in service.
- Existing upstream ESP is removed from service and replaced with a PJFF.

BPE Regenerative SCR (RSCR) systems have been installed almost exclusively downstream of ESPs but have not been installed on a Municipal Waste Combustor.

The option of replacing the ESP with a PJFF is being considered with SCR feasibility analysis given that USEPA will be revising the MWC standards in future years that could require ESP replacement. In this case, it would be practical to install PJFF along with new SCR to avoid significant engineering construction difficulties and costs with replacing ESPs after SCR installation.

Installation of tail-end systems over the existing ESPs also presents several arrangement obstacles. The Baltimore facility requires full access to the ESP roof for maintenance activities, including replacement of collection plates, rigid frame discharge electrodes and transformer/rectifier (TR) sets. In order to access the aforementioned items, the ESP roof must be removed. Installing a tail-end system over the existing ESPs eliminates the ability for the plant to continue their current method of maintenance. Additional maintenance methods such as monorails can be difficult in nature due to side clearances and drop zones and material handling

with multiple ESPs installed in parallel. For this study, BPE has assumed a TR set height of roughly 9.5 feet above the ESP roof based on scaling available drawings. BPE has allowed for 11.5 feet between the top of the TR set and the bottom of the outlet duct for the traditional tail-end SCR option and 18.5 feet between the top of the TR set and the bottom of the ductwork for the RSCR option. Note that for the traditional tail-end SCR option the main SCR support steel would be located an additional 11.5 feet higher than the bottom of the duct, which could then be hung from the same steel. If additional clearance was required, layouts with offset ductwork could be looked at such that the ducts were not directly over the TR sets. The above clearances also assumed the new equipment to be no higher than the top of the existing SDA inlet duct. BPE feels that with between 11.5 feet and 18.5 feet of clearance there is adequate room for support steel, monorails, and equipment removal. Final determination of equipment elevations, clearances, layouts, and maintenance requirements would need to be evaluated in more depth in the next phase to confirm.

System Inlet and Outlet NO_x

An SCR Inlet NO_x of 212 ppmvd @ 7% O₂ is assumed for the Tail-End systems. Outlet NO_x values are based on the Best Available Control Technology (BACT) Review [13] and Final Permit [14] for the Palm Beach Renewable Energy Facility No. 2 (PBREF-2) WTE plant located in West Palm Beach, Florida. The evaluation and permit establish the BACT for NO_x emissions from MWC each unit as 50 ppmvd @ 7% O₂ (24-hour block arithmetic mean) and 45 ppmvd @ 7% O₂ (12-month rolling average) with a Tail-End SCR installed. An ammonia slip value of 10 ppmvd @ 7% O₂ is also based on the PBREF-2 BACT Review [13] and Final permit [14].

4.7.1 Traditional Tail-End SCR

For both the upstream ESP and upstream PJFF conditions, each of the three (3) SCRs requires two (2) initial catalyst layers in a three (3) module wide by four (4) module deep arrangement. Space for one (1) future spare layer is also provided. Catalyst with a pitch of 4.9 mm is assumed under both conditions. The duct burner or steam coil heater must heat the flue gas to 500°F for optimal catalyst performance.

This option is technically feasible from both an arrangement and performance perspective with the caveats noted in Section 4.7 above.

Refer to Appendix B for arrangement drawings for the Traditional Tail-End SCR.

4.7.2 Regenerative SCR (RSCR)

For the upstream ESP condition, each of the three (3) RSCRs requires three (3) reactors (three (3) pairs of canisters) with a 5.9 mm pitch catalyst, with a total of 64 catalyst modules provided per unit.

For the upstream PJFF condition, each of the three (3) RSCRs requires two (2) reactors (two (2) pairs of canisters) with a 3.3 mm pitch catalyst, with a total of 48 catalyst modules provided per unit.

Note that the difference in catalyst pitch between the upstream ESP condition and the upstream PJFF condition is due to the higher dust capture efficiency of the PJFF. A grain loading of 0.03 – 0.04 gr/dSCF was assumed for the upstream ESP condition, while a grain loading of 0.006 gr/dSCF was assumed for the upstream PJFF condition.

The duct burner or steam coil heater must heat the flue gas to 465°F for optimal catalyst performance, however, for SO₃ approaching 0.3 ppmvd the temperature must be around 575°F in order to avoid ABS formation. The economics of operation may justify allowing the ABS to form and then be decomposed. It should be noted that separate catalyst suppliers were consulted for the Traditional Tail-End and RSCR options. This resulted in different operating temperatures for each technology. The ideal operating temperature for a chosen technology would be evaluated and determined during the detailed design phase of a project.

This option may be considered technically feasible from both an arrangement and performance perspective subject to additional analysis to determine final feasibility with respect to adequacy of the existing foundations and steel structures. Further analysis must also ensure that adequate space for new foundations and steel required to support the new equipment is available, while maintaining proper access to existing equipment for maintenance (see Section 4.7 above). BPE has worked on multiple projects where foundation mini piles, foundation bridges, etc., have been used to reinforce existing foundations and bridge over obstructions in order to support new steel in tight locations. Based on past experience, it is believed that this is a workable solution to the additional load and steel structure required to support the new tail end equipment.

Refer to Appendix B for arrangement drawings for all RSCR options.

5.0 ESTIMATED CAPITAL AND OPERATING COSTS

Although many of the technologies discussed in this study are technically feasible, the cost of each technology must be weighed against the relative improvement of NO_x reduction to determine financial feasibility. As mentioned previously, detailed engineering, design, and construction of essential project parameters such as electrical work, civil work (foundations, pilings, site preparation), and balance of plant for integrating the various NO_x control technologies into existing plant have not been technically evaluated as a part of this feasibility study. However, costs for these have been considered per industry standards in the estimation of capital costs. Estimated Budget pricing for each technically feasible option is presented in Sections 5.1 through 5.5. Expected annual operating costs for reagent, steam, and significant power consumptions are also presented in Section 5.6.

5.1 Existing SNCR

Estimated Budget Price for Startup, Optimization, and Training ^e

\$85,200.

Eighty-Five Thousand Two Hundred Dollars

5.2 Advanced SNCR

Estimated Budget Price for Materials, Equipment, and Installation Including:

Equipment Design and Project Team Labor ^f

Startup, Optimization, and Training ^f

Baseline Testing and CKM/CFD Modeling ^e

Replace and Upgrade SNCR Metering Modules ^e

Six (6) NO_xOUT Injectors for 2nd Injection Level ^e

Acoustic Monitoring System ^e

Six (6) Boiler Tube Panels for New Injectors ^f

Boiler Tube Panels for Acoustic Monitoring System ^f

Piping Valves and Specialties ^f

Instrumentation ^f

\$8,665,162.

Eight Million Six Hundred Sixty-Five Thousand One Hundred and Sixty-Two Dollars

5.3 FGR-SNCR

Estimated Budget Price for Materials, Equipment, and Installation Including:

Equipment Design and Project Team Labor ^f
Startup, Optimization, and Training ^f
Baseline Testing and CKM/CFD Modeling ^e
Ductwork ^f
Structural Steel ^f
FGR Fans ^e
Expansion Joints and Dampers ^f
Piping Valves and Specialties ^f
Instrumentation ^f

\$5,829,591.

Five Million Eight Hundred Twenty- Nine Thousand Five Hundred and Ninety-One Dollars

5.4 FGR-ASNCR

Estimated Budget Price for Materials, Equipment, and Installation Including:

Equipment Design and Project Team Labor ^f
Startup, Optimization, and Training ^f
Baseline Testing and CKM/CFD Modeling ^e
Replace and Upgrade SNCR Metering Module ^e
Six (6) NOxOUT Injectors for 2nd Injection Level ^e
Acoustic Monitoring System ^e
Six (6) Boiler Tube Panels for New Injectors ^f
Boiler Tube Panels for Acoustic Monitoring System ^f
Ductwork ^f
Structural Steel ^f
FGR Fans ^e
Expansion Joints and Dampers ^f
Piping Valves and Specialties ^f

Instrumentation ^e

\$12,993,524.

Twelve Million Nine Hundred Ninety -Three Thousand Five Hundred and Twenty-Four
Dollars

5.5 Tail-End SCR Systems

For the traditional tail-end SCR and the regenerative SCR (RSCR), feasibility was investigated for both preserving the existing ESPs as well as replacing the existing ESPs with a PJFFs. As noted in Section 4.7, additional evaluations must be performed to determine final feasibility. This includes evaluation of existing foundations and steel structures and to ensure adequate space for new foundations and steel required to support the new equipment while maintaining proper access to existing equipment for maintenance. BPE has worked on multiple projects where foundation mini piles, foundation bridges, etc., have been used to reinforce existing foundations and bridge over obstructions in order to support new steel in tight locations. Based on past experience, it is believed that this is a workable solution to the additional load and steel structure required to support the new tail end equipment.

Pricing for all tail-end SCR systems (both traditional and RSCR) assumes 19% aqueous ammonia as reagent based on BPE's historical installations.

5.5.1 Traditional Tail-End SCR with Existing ESP ^k

Estimated Budget Price for Materials, Equipment, and Installation Including:

Equipment Design and Project Team Labor ^f

Physical Flow Model ^f

Startup, Optimization, and Training ^f

Traditional Tail-End SCR ^f

Catalyst ^e

Steam Coil Heaters ^{f,j}

Ductwork ^f

Structural Steel ^f

Gas to Gas Heat Exchanger ^f

Aqueous Ammonia System ^f

ID Fans ^f

Expansion Joints and Dampers ^f

Piping Valves and Specialties ^f

Instrumentation ^f

\$60,574,340.

Sixty Million Five Hundred Seventy-Four Thousand Three Hundred and Forty Dollars

5.5.2 Traditional Tail-End SCR with New PJFF

Estimated Budget Price for Materials, Equipment, and Installation Including:

Equipment Design and Project Team Labor ^f

Physical Flow Model ^f

Startup, Optimization, and Training ^f

Traditional Tail-End SCR ^f

Catalyst ^e

Steam Coil Heaters ^{f,j}

Ductwork ^f

Structural Steel ^f

Gas to Gas Heat Exchanger ^f

Aqueous Ammonia System ^f

ID Fans ^f

PJFF ^f

Expansion Joints and Dampers ^f

Piping Valves and Specialties ^f

Instrumentation ^f

\$92,929,377.

Ninety-Two Million Nine Hundred Twenty-Nine Thousand Three Hundred and Seventy-Seven Dollars

5.5.3 Regenerative SCR (RSCR) with Existing ESP ^k

Estimated Budget Price for Materials, Equipment, and Installation Including:

Equipment Design and Project Team Labor ^f

Startup, Optimization, and Training ^f

Regenerative SCR - 6 Canister ^f

Catalyst ^e

Ductwork ^f
Structural Steel ^f
Aqueous Ammonia System ^f
ID Fans ^f
Expansion Joints and Dampers ^f
Piping Valves and Specialties ^f
Instrumentation ^f

\$76,278,652.

Seventy-Six Million Two Hundred Seventy-Eight Thousand Six Hundred and Fifty-Two
Dollars

5.5.4 Regenerative SCR (RSCR) with New PJFF

Estimated Budget Price for Materials, Equipment, and Installation Including:

Equipment Design and Project Team Labor ^f
Startup, Optimization, and Training ^f
Regenerative SCR - 4 Canister ^f
Catalyst ^e
Ductwork ^f
Structural Steel ^f
Aqueous Ammonia System ^f
ID Fans ^f
PJFF ^f
Expansion Joints and Dampers ^f
Piping Valves and Specialties ^f
Instrumentation ^f

\$92,161,155.

Ninety-Two Million One Hundred Sixty-One Thousand One Hundred and Fifty-Five
Dollars

Notes on Budget Pricing

- a. Pricing is Indicative Budget Pricing +/- 20%
- b. Budget pricing shown is for three units
- c. Pricing does not have a validity date due to budget pricing
- d. Freight to Wheelabrator Baltimore Facility Site is included
- e. Supplier solicited budget pricing
- f. Recent, scaled, or allowance pricing
- g. Installation estimates are based on 1.00 to 1.25 times material pricing, 4% to 5% total project cost for civil and site activities, and 4% to 5% total project costs for demolition (BPE, [1], Wheelabrator).
- h. Pricing does not include Taxes
- i. Pricing does not include permitting costs
- j. BPE has traditionally supplied natural gas or oil-fired burners. However, BPE is capable of designing this system with steam coil heaters.
- k. Pricing does not include additional costs associated with maintenance modifications required for ESP access.
- l. Pricing does not include Wheelabrator internal project costs.

Material

The prices established herein are subject to adjustment in favor of seller to the extent of increases in applicable taxes, duties, tariffs, and/or similar charges that apply to seller or are otherwise to be borne by seller and become applicable after the date of this order but prior to delivery of all goods and/or services to the purchaser. Recent steel and aluminum tariffs imposed by the United States may impact seller's cost and/or schedule of procurement underlying this proposal/agreement. Seller shall promptly notify purchaser of any change to its price and/or schedule as a result of these changes outside its control and purchaser shall be responsible for the impact of such changes.

5.6 Estimated Annual Operating Costs

The expected annual operating costs for reagent, steam, and significant power consumptions for those technologies deemed technically feasible are outlined in Table 1 below.

Table 1: Expected Annual Operating Costs for NO_x Control Technologies¹

Technology	Urea (50 wt%) ^{2,3}	Aqueous Ammonia (19 wt%) ⁴	Steam ^{2,3}	Lost Electrical Revenue ^{2,3,5}	
Existing SNCR ⁶	\$695,000				
Advanced SNCR	\$995,000				
FGR-SNCR	\$735,000			0.3 MW	\$80,000
FGR-ASNCR	\$955,000			0.3 MW	\$80,000
RSCR over Existing ESP		\$500,000 ⁷	\$320,000	1.3 MW	\$355,000
RSCR over New PJFF		\$500,000 ⁷	\$285,000	1.3 MW	\$355,000
Traditional Tail-End SCR ⁸		\$500,000 ⁷	\$1,280,000	1.3 MW	\$355,000

Table 2: Wheelabrator Costs³

Urea ⁹	\$1.19	per gallon
Aqueous Ammonia (19 wt%) ⁴	\$0.78	per gallon
Power ¹⁰	\$33.15	per MW
Turbine/Generator Conversion Rate ¹¹	9.06 klbs	per MW

¹ All annual operating costs assume availability of the Baltimore Facility of 92%.

² Expected annual operating costs and expected lost electrical revenue presented as total cost for all three (3) MWC units.

³ Power pricing for lost electrical revenue, urea price per gallon, and cost of diverting steam provided by Wheelabrator. See Table 2 for data.

⁴ Aqueous ammonia price per gallon based on October 2019 correspondence with Airgas Specialty Products [19].

⁵ Lost electrical revenue due to fan auxiliary power increase with new technology installation.

⁶ With further optimization and tuning.

⁷ Assuming existing SNCR is taken out of service.

⁸ Traditional Tail-End SCR operating costs are comparable for installation over both existing ESP and new PJFF.

⁹ Cost in 2020.

¹⁰ Average rate budgeted for 2020. To determine lost electrical revenue with installation of SCR.

¹¹ For estimating lost electrical generation for diverting steam for SCR reheat.

Table 3: Expected Urea & Aqueous Ammonia Usage

Technology	Urea (50 wt%) ^{12,13}	Aqueous Ammonia (19 wt%)
Existing SNCR ¹⁴	72 gal/hr	
Advanced SNCR	105 gal/hr	
FGR-SNCR	77 gal/hr	
FGR-ASNCR	100 gal/hr	
RSCR over Existing ESP		80 gal/hr ¹⁵
RSCR over New PJFF		80 gal/hr ¹⁵
Traditional Tail-End SCR ¹⁶		80 gal/hr ¹⁵

5.7 Catalyst Replacement Cost

For tail-end systems, catalyst must be replaced at the end of its life. Estimated replacement costs for tail-end systems are:

Table 4: Catalyst Replacement Cost for Tail-End SCR Systems

Technology	Replacement Cost ¹⁷	Frequency ¹⁸
RSCR over Existing ESP	\$3,000,000	16,000 hours
RSCR over New PJFF	\$1,600,000	16,000 hours
Traditional Tail-End SCR ¹⁶	\$700,000	24,000 hours

¹² Expected annual operating costs and expected lost electrical revenue presented as total cost for all three (3) MWC units.

¹³ Power pricing for lost electrical revenue, urea price per gallon, and cost of diverting steam provided by Wheelabrator. See Table 2 for data.

¹⁴ With further optimization and tuning.

¹⁵ Assuming existing SNCR is taken out of service.

¹⁶ Traditional Tail-End SCR operating costs are comparable for installation over both existing ESP and new PJFF.

¹⁷ Catalyst replacement costs shown are material costs only. Installation, labor, and catalyst disposal or regeneration cost are not included.

¹⁸ Replacement necessary at end of catalyst life, indicated in "Frequency" column.

6.0 ESTIMATED PROJECT SCHEDULE

High-level estimated project schedules were developed for all options deemed feasible in this study. The schedules do not include time for obtaining state and local permits and approvals. Permitting may add 6-12+ months to the schedule for tail-end SCR systems given the extensive nature of these types of retrofits. Preliminary schedules are presented in Appendix A for the following options:

- Existing SNCR
- Advanced SNCR (ASNCR)
- FGR-SNCR
- FGR-ASNCR
- Tail-End SCR Systems
 - Traditional Tail-End SCR with Existing ESP
 - Traditional Tail-End SCR with New PJFF
 - Regenerative SCR (RSCR) with Existing ESP
 - Regenerative SCR (RSCR) with New PJFF

6.1 Construction Approach for New PJFF Options

The preliminary schedules in Appendix A take the construction of new PJFFs into consideration.

For all Tail-End SCR systems (both traditional and RSCR) with new PJFFs, the suggested approach is to build the new PJFF and tail-end equipment and support structure for Unit 3 first, locating it to the north of the existing Unit 3 ESP. Once major construction is complete, a tie in outage will be used to tie the Unit 3 boiler to the new PJFF and tail-end SCR equipment. The Unit 3 ESP can then be demolished and construction of the new Unit 2 PJFF and tail-end equipment can be installed in its place. This methodology would continue towards the south until all existing units are tied into their new PJFF and tail-end SCR components. This essentially shifts all particulate control equipment north by one unit.

7.0 REFERENCES

- [1] U.S. Energy Information Administration, "Capital Cost Estimates for Utility Scale Electricity Generating Plants," Washington, DC, November 2016.
- [2] Urbas, Jerry B., "Hybrid Selective Non-Catalytic Reduction (SNCR) / Selective Catalytic Reduction (SCR) Demonstration for the Removal of NO_x from Boiler Flue Gases," 1999.
- [3] Haldor Topsoe, "CataFlex," [Online]. Available: <https://www.topsoe.com/chan-pin/cui-hua-ji/cataflex.htm>. [Accessed 24 June 2019].
- [4] W.L. Gore & Associates, Inc., "GORE DeNO_x Catalytic Filter Bags," [Online]. Available: https://www.gore.com/system/files/2018-07/GORE_DeNOx_Catalytic_Filter_Bags_Data-Sheet.pdf. [Accessed 24 June 2019].
- [5] A. R. Nielsen, K. Beldring, T. Slabiak and H. Jensen-Holm, "SCR DeNO_x catalyst experience from waste-to-energy plants," January 2018.
- [6] J. Brandin and C. Odenbrand, "Deactivation and Characterization of SCR Catalysts Used in Municipal Waste Incineration Applications," *Catalysis Letters*, vol. 148, no. 1, pp. 312-327, 2018.
- [7] National Research Council, Waste Incineration and Public Health, Washington, DC: The National Academies Press, 2000.
- [8] United States Environmental Protection Agency, EPA Air Pollution Control Cost Manual, Research Triangle Park, NC, 2002, pp. 3-33 - 3-34.
- [9] Air & Waste Management Association (AWMA), Air Pollution Engineering Manual, New York: Van Nostrand Reinhold, 1992.
- [10] United States Environmental Protection Agency, *Air Pollution Control Fact Sheet - Flue Gas Desulfurization (FGD) - Wet, Spray Dry, and Dry Scrubbers*, 2003.
- [11] United States Environmental Protection Agency, "Control of Mercury Emissions from Coal Fired Electric Utility Boilers: An Update," Research Triangle Park, 2005.
- [12] Sankey, Mark R.; Golden, Michelle; Koza, Donald, Bechtel Power Corp., "Challenges to Mercury Emissions Compliance at New and Existing Coal Fired Power Plants," *Power Engineering*, vol. 117, no. 8, 2013.
- [13] Florida Department of Environmental Protection, "Technical Evaluation & Preliminary Determination - DEP File No. 0990234-017-AC (PSD-FL-413)," 15 November 2010. [Online]. Available: <http://arm-permit2k.dep.state.fl.us/psd/0990234/U00000317.pdf>. [Accessed 01 October 2019].
- [14] Florida Department of Environmental Protection, "Air Permit No. 0990234-032-AC/PSD-FL-413C," 29 December 2014. [Online]. Available: <https://arm->

permit2k.dep.state.fl.us/adh/prod/pdf_permit_zip_files/0990234.032.AC.F_pdf.zip.
[Accessed 01 October 2019].

- [15] R. Abrams and R. Faia, "RSCR System to Reduce NO_x Emissions from Boilers," in *17th Annual North American Waste to Energy Conference*, Chantilly, VA, 2009.
- [16] U.S. Energy Information Administration, "Maryland Natural Gas Industrial Price," [Online]. Available: <https://www.eia.gov/dnav/ng/hist/n3035md3m.htm>. [Accessed 1 August 2019].
- [17] ARC, "Amager Ressource Center," [Online]. Available: <https://www.a-r-c.dk/amager-bakke#r%C3%B8grensning>. [Accessed 04 October 2019].
- [18] International Solid Waste Association (ISWA), "Waste to Energy State of the Art Report, 6th Edition," 2012.
- [19] R. Johnston, Airgas Specialty Products, *Re: New Entry: Request a Quote*, Personal Email, 2019.

APPENDIX A PRELIMINARY SCHEDULE


	Month	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26
Existing SNCR																											
Engineering		█																									
Procurement		█																									
Startup & Commissioning			█																								
ASNCR																											
Engineering		█	█	█																							
Procurement				█	█	█	█																				
Pre Outage Construction							█	█	█																		
Outage Construction (Tie-In)										█	█																
Startup & Commissioning												█															
FGR + SNCR																											
Engineering		█	█	█	█																						
Procurement				█	█	█	█	█	█	█																	
Pre Outage Construction										█	█	█	█														
Outage Construction (Tie-In)														█	█												
Startup & Commissioning																█	█	█									
FGR + ASNCR																											
Engineering		█	█	█	█																						
Procurement				█	█	█	█	█	█	█																	
Pre Outage Construction										█	█	█	█														
Outage Construction (Tie-In)														█	█												
Startup & Commissioning																█	█	█									
Tail End SCR over ESP																											
Engineering		█	█	█	█	█	█	█	█																		
Procurement				█	█	█	█	█	█	█	█	█	█	█	█	█											
Pre Outage Construction													█	█	█	█	█	█	█	█	█	█	█	█			
Outage Construction (Tie-In)																								█			
Startup & Commissioning																									█	█	█
Tail End SCR with PJFF																											
Engineering		█	█	█	█	█	█	█																			
Procurement				█	█	█	█	█	█	█	█	█	█	█	█	█											
Pre Outage Construction												█	█	█	█	█	█	█	█	█	█	█	█	█	█		
Outage Construction (Tie-In)																█			█						█		
Demo ESPs																█	█			█	█					█	
Startup & Commissioning																█	█	█		█	█	█				█	█
RSCR over ESP																											
Engineering		█	█	█	█	█	█																				
Procurement				█	█	█	█	█	█	█																	
Pre Outage Construction										█	█	█	█	█	█	█											
Outage Construction (Tie-In)																	█										
Startup & Commissioning																		█									
RSCR with PJFF																											
Engineering		█	█	█	█	█	█																				
Procurement				█	█	█	█	█	█	█	█	█	█	█													
Pre Outage Construction											█	█	█	█	█	█	█	█	█	█	█	█					
Outage Construction (Tie-In)														█				█					█				
Demo ESPs															█	█			█	█				█	█		
Startup & Commissioning															█	█			█	█				█	█		

APPENDIX B ARRANGEMENT DRAWINGS


The table below summarizes the arrangement drawings provided in this Appendix for a number of the options presented in this study.

Table 5: Arrangement Drawings

Document Number	Description
100825-0926750100	Proposed RSCR Addition – RSCR at Grade
100825-0926750110	Proposed RSCR Addition – RSCR above Precipitators
100825-0926750111	Proposed RSCR Addition – RSCR above Precipitators – Elevation View Looking North
100825-0926750120	Proposed RSCR – Fabric Filter Addition – Elevation View Looking North
100825-0926750121	Proposed RSCR – Fabric Filter Addition – Plan View A-A
100825-0926750122	Proposed RSCR – Fabric Filter Addition – Plan Section B-B
100825-0926750123	Proposed RSCR – Fabric Filter Addition – Elevation View C-C
100825-0926750130	Proposed Flue Gas Recirculation Addition
100825-0926750140	SCR, Airheater & Fabric Filter Addition – Elevation View Looking North
100825-0926750141	SCR, Airheater & Fabric Filter Addition – Plan View A-A
100825-0926750142	SCR, Airheater & Fabric Filter Addition – Plan Section B-B
100825-0926750143	SCR, Airheater & Fabric Filter Addition – Elevation View C-C
100825-0926750150	SCR & Airheater Addition – Above Existing Precipitator – Elevation View Looking North



PRELIMINARY
7/9/19


							Copyright 2019 - All Rights Reserved - BABCOCK POWER ENVIRONMENTAL INC. (hereinafter "COMPANY") This drawing contains COMPANY confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, without the express written permission of COMPANY. EXCEPT AS EXPRESSLY STATED IN ANY WRITTEN CONTRACT - ALL WARRANTIES RELATING TO THIS DRAWING, INCLUDING ANY WARRANTIES OF MERCHANTABILITY OR FITNESS, ARE DISCLAIMED. All intellectual property and other rights are retained by COMPANY, unless expressly conveyed in a written contract. THIS DRAWING IS NOT APPROVED FOR CONSTRUCTION UNLESS IT CONTAINS DATE AND SIGNATURE OF APPROVAL AND THE COMPANY RESERVES THE RIGHT TO CORRECT ANY ERRORS OR OMISSIONS PRIOR TO ACTUAL START OF WORK.			THIRD ANGLE PROJECTION 		DRAWN A. Crowley DATE 06/20/2019 CHECKED DATE APP'D DATE SCALE 1/32" = 1 ft.		ENVIRONMENTAL INC. PROPOSED RSCR ADDITION RSCR AT GRADE WHEELABRATOR TECHNOLOGIES BALTIMORE NOX FEASIBILITY STUDY BALTIMORE, MARYLAND DWG. NO. 100825-0926750100 REV. NO. P0	
REVISION		NO.	BY	CHK	DATE	APP'D	DATE	RELEASED & APPROVED		DATE					

IFI


BABCOCK POWER ENVIRONMENTAL INC.

PROPOSED RSCR ADDITION
RSCR AT GRADE

WHEELABRATOR TECHNOLOGIES BALTIMORE
NOx FEASIBILITY STUDY
BALTIMORE, MARYLAND




PRELIMINARY
7/9/19

							Copyright 2019 - All Rights Reserved - BABCOCK POWER ENVIRONMENTAL INC. (hereinafter "COMPANY"). This drawing contains COMPANY confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, without the express written permission of COMPANY, EXCEPT AS EXPRESSLY STATED IN ANY WRITTEN CONTRACT - ALL WARRANTIES RELATING TO THIS DRAWING, INCLUDING ANY WARRANTIES OF MERCHANTABILITY OR FITNESS, ARE DISCLAIMED. All intellectual property and other rights are retained by COMPANY, unless expressly conveyed in a written contract. THIS DRAWING IS NOT APPROVED FOR CONSTRUCTION UNLESS IT CONTAINS DATE AND SIGNATURE OF APPROVAL AND THE COMPANY RESERVES THE RIGHT TO CORRECT ANY ERRORS OR OMISSIONS PRIOR TO ACTUAL START OF WORK.	THIRD ANGLE PROJECTION 		DRAWN A. Crowley DATE 06/20/19 CHECKED	ENVIRONMENTAL INC. PROPOSED RSCR ADDITION RSCR ABOVE PRECIPITATORS	
							DO NOT SCALE USE DIMENSIONS ONLY	DATE APP'D	WHEELABRATOR TECHNOLOGIES BALTIMORE NOX FEASIBILITY STUDY BALTIMORE, MARYLAND			
							DATE 1/32	SCALE IN. = 1 FT.	DWG. NO. 100825-0926750110		REV. NO. P0	
REVISION							RELEASED & APPROVED	DATE				
NO.							BY	CHK				
DATE							APP'D	DATE				

BABCOCK POWER ENVIRONMENTAL INC.


PROPOSED RSCR ADDITION
RSCR ABOVE PRECIPITATORS

WHEELABRATOR TECHNOLOGIES, BALTIMORE
NOx FEASIBILITY STUDY
BALTIMORE, MARYLAND



DWG. NO. 100825-0926750111

PRELIMINARY
11/5/19

Copyright 2019 - All Rights Reserved - BABCOCK POWER ENVIRONMENTAL INC. (hereinafter "COMPANY"). This drawing contains COMPANY confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, without the express written permission of COMPANY. EXCEPT AS EXPRESSLY STATED IN ANY WRITTEN CONTRACT - ALL WARRANTIES RELATING TO THIS DRAWING, INCLUDING ANY WARRANTIES OF MERCHANTABILITY OR FITNESS, ARE DISCLAIMED. All Intellectual property and other rights are retained by COMPANY, unless expressly conveyed in a written contract. THIS DRAWING IS NOT APPROVED FOR CONSTRUCTION UNLESS IT CONTAINS DATE AND SIGNATURE OF APPROVAL AND THE COMPANY RESERVES THE RIGHT TO CORRECT ANY ERRORS OR OMISSIONS PRIOR TO ACTUAL START OF WORK. RELEASED & APPROVED _____ DATE _____						THIRD ANGLE PROJECTION 		DO NOT SCALE USE DIMENSIONS ONLY		DRAWN A. Crowley DATE 06/20/19 CHECKED DATE APP'D DATE SCALE 1/16" = 1 FT.	DWG. NO. 100825-0926750111 REV. NO. P1
ADDED TR SETS, RAISED RSCR.	P1	AC	-	-	-						
REVISION	NO.	BY	CHK	DATE	APP'D	DATE					

IFI


**BABCOCK POWER
ENVIRONMENTAL INC.**

PROPOSED RSCR ADDITION
RSCR ABOVE PRECIPITATOR
ELEVATION VIEW LOOKING NORTH


WHEELABRATOR TECHNOLOGIES, BALTIMORE

NOx FEASIBILITY STUDY

BALTIMORE, MARYLAND



PRELIMINARY
6/26/19


						Copyright 2019 - All Rights Reserved - BABCOCK POWER ENVIRONMENTAL INC. (hereinafter "COMPANY"). This drawing contains COMPANY confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, without the express written permission of COMPANY, EXCEPT AS EXPRESSLY STATED IN ANY WRITTEN CONTRACT - ALL WARRANTIES RELATING TO THIS DRAWING, INCLUDING ANY WARRANTIES OF MERCHANTABILITY OR FITNESS, ARE DISCLAIMED. All Intellectual property and other rights are retained by COMPANY, unless expressly conveyed in a written contract. THIS DRAWING IS NOT APPROVED FOR CONSTRUCTION UNLESS IT CONTAINS DATE AND SIGNATURE OF APPROVAL AND THE COMPANY RESERVES THE RIGHT TO CORRECT ANY ERRORS OR OMISSIONS PRIOR TO ACTUAL START OF WORK.				DRAWN A. Crowley DATE 06/24/19 CHECKED		ENVIRONMENTAL INC. PROPOSED RSCR - FABRIC FILTER ADDITION ELEVATION VIEW LOOKING NORTH		
								DO NOT SCALE USE DIMENSIONS ONLY		DATE APP'D		WHEELABRATOR TECHNOLOGIES BALTIMORE NOX FEASIBILITY STUDY BALTIMORE, MARYLAND		
REVISION						NO.	BY	CHK	DATE	APP'D	DATE	SCALE 1/8" = 1' FT.	DWG. NO. 100825-0926750120	REV. NO. P0
						RELEASED & APPROVED		DATE						

IFI

**BABCOCK POWER
ENVIRONMENTAL INC.**

PROPOSED RSCR - FABRIC FILTER ADDITION
ELEVATION VIEW LOOKING NORTH


WHEELABRATOR TECHNOLOGIES, BALTIMORE
NOx FEASIBILITY STUDY
BALTIMORE, MARYLAND



DWG. NO. 100825-0926750121

PLAN VIEW A-A
(120-C,2)

PRELIMINARY
6/26/19


						Copyright 2019 - All Rights Reserved - BABCOCK POWER ENVIRONMENTAL INC. (hereinafter "COMPANY")		THIRD ANGLE PROJECTION		DRAWN A. Crowley DATE 06/24/19 CHECKED DATE		ENVIRONMENTAL INC.		
						This drawing contains COMPANY confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, without the express written permission of COMPANY. EXCEPT AS EXPRESSLY STATED IN ANY WRITTEN CONTRACT - ALL WARRANTIES RELATING TO THIS DRAWING, INCLUDING ANY WARRANTIES OF MERCHANTABILITY OR FITNESS, ARE DISCLAIMED.						PROPOSED RSCR - FABRIC FILTER ADDITION PLAN VIEW A-A		
						All intellectual property and other rights are retained by COMPANY, unless expressly conveyed in a written contract.		DO NOT SCALE USE DIMENSIONS ONLY		DATE APP'D		WHEELABRATOR TECHNOLOGIES BALTIMORE		
						THIS DRAWING IS NOT APPROVED FOR CONSTRUCTION UNLESS IT CONTAINS DATE AND SIGNATURE OF APPROVAL AND THE COMPANY RESERVES THE RIGHT TO CORRECT ANY ERRORS OR OMISSIONS PRIOR TO ACTUAL START OF WORK.				DATE		NOX FEASIBILITY STUDY BALTIMORE, MARYLAND		
REVISION						NO.	BY	CHK	DATE	APP'D	DATE	SCALE IN. = 1 FT.	DWG. NO. 100825-0926750121	REV. NO. P0
						RELEASED & APPROVED		DATE						

IFI

**BABCOCK POWER
ENVIRONMENTAL INC.**


PROPOSED RSCR - FABRIC FILTER ADDITION
PLAN VIEW A-A


WHEELABRATOR TECHNOLOGIES, BALTIMORE
NOx FEASIBILITY STUDY
BALTIMORE, MARYLAND



PLAN SECTION B-B
(120-E,2)

PRELIMINARY
6/26/19


						<p>Copyright 2019 - All Rights Reserved - BABCOCK POWER ENVIRONMENTAL INC. (hereinafter "COMPANY").</p> <p>This drawing contains COMPANY confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, without the express written permission of COMPANY. EXCEPT AS EXPRESSLY STATED IN ANY WRITTEN CONTRACT - ALL WARRANTIES RELATING TO THIS DRAWING, INCLUDING ANY WARRANTIES OF MERCHANTABILITY OR FITNESS, ARE DISCLAIMED.</p> <p>All intellectual property and other rights are retained by COMPANY, unless expressly conveyed in a written contract.</p> <p>THIS DRAWING IS NOT APPROVED FOR CONSTRUCTION UNLESS IT CONTAINS DATE AND SIGNATURE OF APPROVAL AND THE COMPANY RESERVES THE RIGHT TO CORRECT ANY ERRORS OR OMISSIONS PRIOR TO ACTUAL START OF WORK.</p>	<p>THIRD ANGLE PROJECTION</p> 	<p>DO NOT SCALE USE DIMENSIONS ONLY</p>	<p>DRAWN A. Crowley</p>		<p>IF1</p>	<p>ENVIRONMENTAL INC.</p> <p>PROPOSED RSCR - FABRIC FILTER ADDITION PLAN SECTION B-B</p>		<p>DWG. NO. 100825-0926750122</p>	<p>REV. NO. P0</p>
									<p>DATE 06/24/19</p>	<p>WHEELABRATOR TECHNOLOGIES BALTIMORE</p>					
									<p>DATE APP'D</p>	<p>NOx FEASIBILITY STUDY</p>					
									<p>DATE</p>	<p>BALTIMORE, MARYLAND</p>					
									<p>SCALE IN. = 1 FT.</p>						
REVISION						NO.	BY	CHK	DATE	APP'D	DATE				
						RELEASED & APPROVED			DATE						




J




PRELIMINARY
7/15/19

							Copyright 2019 - All Rights Reserved - BABCOCK POWER ENVIRONMENTAL INC. (hereinafter "COMPANY")		THIRD ANGLE PROJECTION 		DRAWN A. Crowley		ENVIRONMENTAL INC.		
							This drawing contains COMPANY confidential and proprietary information and cannot be used, disclosed or displayed in whole or in part, without the express written permission of COMPANY. EXCEPT AS OTHERWISE SPECIFIED IN THIS CONTRACT - ALL WARRANTIES RELATING TO THIS DRAWING INCLUDING ANY WARRANTIES OF MERCHANTABILITY OR FITNESS, ARE DISCLAIMED.				DATE 07/15/19 CHECKED		SCR, AIRHEATER AND FABRIC FILTER ADDITION ELEVATION VIEW LOOKING NORTH		
							All Intellectual property and other rights are retained by COMPANY, unless expressly conveyed in a written contract.				DATE APP'D		WHEELABRATOR TECHNOLOGIES BALTIMORE		
							THIS DRAWING IS NOT APPROVED FOR CONSTRUCTION UNLESS IT CONTAINS DATE AND SIGNATURE OF APPROVAL AND THE COMPANY RESERVES THE RIGHT TO CORRECT ANY ERRORS OR OMISSIONS PRIOR TO ACTUAL START OF WORK.		DO NOT SCALE USE DIMENSIONS ONLY		DATE		NOx FEASIBILITY STUDY BALTIMORE, MARYLAND		
							RELEASED & APPROVED _____				SCALE 3/32" = 1' ft.		DWG. NO. 100825-0926750140		
REVISION							DATE						REV. NO. PO		
	NO.	BY	CHK	DATE	APP'D	DATE									



PLAN SECTION B-B
(140-E,2)

PRELIMINARY
7/15/19

						Copyright 2019 - All Rights Reserved - BABCOCK POWER ENVIRONMENTAL INC. (hereinafter "COMPANY"). This drawing contains COMPANY confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, without the express written permission of COMPANY. EXCEPT AS EXPRESSLY STATED IN ANY WRITTEN CONTRACT - ALL WARRANTIES RELATING TO THIS DRAWING, INCLUDING ANY WARRANTIES OF MERCHANTABILITY OR FITNESS, ARE DISCLAIMED. All intellectual property and other rights are retained by COMPANY, unless expressly conveyed in a written contract. THIS DRAWING IS NOT APPROVED FOR CONSTRUCTION UNLESS IT CONTAINS DATE AND SIGNATURE OF APPROVAL AND THE COMPANY RESERVES THE RIGHT TO CORRECT ANY ERRORS OR OMISSIONS PRIOR TO ACTUAL START OF WORK.	THIRD ANGLE PROJECTION 		DRAWN A. Crowley DATE 07/15/19 CHECKED DATE APP'D DATE SCALE 3/32 IN. = 1 FT.		ENVIRONMENTAL INC. SCR, AIRHEATER AND FABRIC FILTER ADDITION PLAN SECTION B-B WHEELABRATOR TECHNOLOGIES BALTIMORE NOX FEASIBILITY STUDY BALTIMORE, MARYLAND DWG. NO. 100825-0926750142 REV. NO. P0		
REVISION						RELEASED & APPROVED	DATE						
NO.	BY	CHK	DATE	APP'D	DATE								

IFI


**BABCOCK POWER
ENVIRONMENTAL INC.**

SCR, AIRHEATER AND FABRIC FILTER ADDITION
PLAN SECTION B-B

WHEELABRATOR TECHNOLOGIES, BALTIMORE

NOx FEASIBILITY STUDY

BALTIMORE, MARYLAND



DWG. NO. 100825-0926750143

PLAN VIEW

VIEW C-C
(140-E,8)

PRELIMINARY
7/15/19

IFI

BABCOCK POWER ENVIRONMENTAL INC.

SCR, AIRHEATER AND FABRIC FILTER ADDITION
ELEVATION VIEW C-C

WHEELABRATOR TECHNOLOGIES, BALTIMORE

NOx FEASIBILITY STUDY

BALTIMORE, MARYLAND


DWG. NO. 100825-0926750143

REV. NO. P0

Copyright 2019 - All Rights Reserved - BABCOCK POWER ENVIRONMENTAL INC.
(hereinafter "COMPANY").
This drawing contains COMPANY confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, without the express written permission of COMPANY. EXCEPT AS EXPRESSLY STATED IN ANY WRITTEN CONTRACT - ALL WARRANTIES RELATING TO THIS DRAWING, INCLUDING ANY WARRANTIES OF MERCHANTABILITY OR FITNESS, ARE DISCLAIMED.
All intellectual property and other rights are retained by COMPANY, unless expressly conveyed in a written contract.

THIS DRAWING IS NOT APPROVED FOR CONSTRUCTION UNLESS IT CONTAINS DATE AND SIGNATURE OF APPROVAL AND THE COMPANY RESERVES THE RIGHT TO CORRECT ANY ERRORS OR OMISSIONS PRIOR TO ACTUAL START OF WORK.

THIRD ANGLE PROJECTION



DO NOT SCALE
USE DIMENSIONS ONLY

DRAWN
A. Crowley
DATE 07/15/19
CHECKED


DATE
APP'D

DATE
3/32

SCALE
IN. = 1 FT.


REVISION	NO.	BY	CHK	DATE	APP'D	DATE

RELEASED & APPROVED _____ DATE _____



SIDE ELEVATION
LOOKING PLANT NORTH

PRELIMINARY
11/5/19

							Copyright 2019 - All Rights Reserved - BABCOCK POWER ENVIRONMENTAL INC. (hereinafter "COMPANY") This drawing contains COMPANY confidential and proprietary information and cannot be used, duplicated or disclosed in whole or in part, without the express written permission of COMPANY. EXCEPT AS EXPRESSLY STATED IN ANY WRITTEN CONTRACT - ALL WARRANTIES RELATING TO THIS DRAWING, INCLUDING ANY WARRANTIES OF MERCHANTABILITY OR FITNESS, ARE DISCLAIMED. All Intellectual property and other rights are retained by COMPANY, unless expressly conveyed in a written contract. THIS DRAWING IS NOT APPROVED FOR CONSTRUCTION UNLESS IT CONTAINS DATE AND SIGNATURE OF APPROVAL AND THE COMPANY RESERVES THE RIGHT TO CORRECT ANY ERRORS OR OMISSIONS PRIOR TO ACTUAL START OF WORK.							THIRD ANGLE PROJECTION 		DRAWN A. CROWLEY DATE 02-AUG-19 CHECKED DATE APP'D DATE SCALE 3/32 IN. = 1 FT.		ENVIRONMENTAL INC. SCR & AIRHEATER ADDITION ABOVE EXISTING PRECIPITATOR ELEVATION VIEW LOOKING NORTH WHEELABRATOR TECHNOLOGIES BALTIMORE NOX FEASIBILITY STUDY BALTIMORE, MARYLAND		DWG. NO. 100825-0926750150 REV. NO. P1	
ADDED TR SETS, RAISED SCR & A.H.							P1		AC		--		--		--		--		RELEASED & APPROVED DATE		
REVISION							NO.		BY		CHK		DATE		APP'D		DATE				

IFI

BABCOCK POWER ENVIRONMENTAL INC.
SCR & AIRHEATER ADDITION
ABOVE EXISTING PRECIPITATOR
ELEVATION VIEW LOOKING NORTH
WHEELABRATOR TECHNOLOGIES, BALTIMORE
NOx FEASIBILITY STUDY
BALTIMORE, MARYLAND

APPENDIX C REFERENCE LISTS

Reference lists for catalyst vendors who have tail-end experience with MWCs are presented on the following pages.

Waste Incineration



Country	End User	Plant	Size	DeNOx	Catalyst	Start-Up Year
Belgium	Bruxelles Energie	Municipal Waste Plant - 3 lines	200,000 Nm ³ /hr	83%	DNX-930	2005
China	Dow Corning	Chemical Waste Incinerator	286,000 Nm ³ /hr	93%	DNX-949	2013
China	Qingdao Haiwan Chemical Co., Ltd.	Chemical Waste Incinerator	37,400 Nm ³ /hr	88%	DNX-939	2019
China	Shandong New Synthesis Amino Acid	Waste Incineration	13,400 Nm ³ /hr	96%	DNX-LD3	2015
China	Shandong Qingyuan	Waste Incineration	22,500 Nm ³ /hr	90%	DNX-LD4	2016
China	Toure Shanghai	Hazardous Waste Incineration	60,000 Nm ³ /hr	90%	DNX-LD3	2017
China	Urban Management Committee of Yiw	Waste Incineration Plant	175,000 Nm ³ /hr	67%	DNX LD-939	2018
China	Wanhua Chemical Group Co., Ltd	Wanhua Yantai IPN Incinerator	39,800 Nm ³ /hr	99%	DNX LD-949	2019
China	Zhejiang Feida Sci. and Tech. Co. Ltd.	Feixi Waste Incineration Units	---	50%	DNX LD-939	2020
China	Xian Tao Waste Incineration	Units 1-2	152,000 Nm ³ /hr	60%	LD-939	2018
Czech Republic	Palivony Kombinát	Off-gas Incinerator (SNOX)	54,000 Nm ³ /hr	95%	DNX-932	1993
Denmark	Amager Resourcecenter	Municipal Waste Plant - 2 lines	267,000 Nm ³ /hr	95%	DNX-LD5	2016
Finland	Lahti Energia OY	Kymijärvi Unit 2	221,000 Nm ³ /hr	90%	DNX-939	2011
France	IDEX Fassa Environnement	Dinan Units 1-2	46,100 Nm ³ /hr	77%	DNX-939	2012
France	Siom de la Valee Chevreuse	Incineration Plant Line 1	90,000 Nm ³ /hr	70%	DNX-939	2008
France	Siom de la Valee Chevreuse	Incineration Plant Line 2	54,000 Nm ³ /hr	77%	DNX-930	2007
France	Sitom 19	Brive Incineration Plant	51,000 Nm ³ /hr	47%	DNX-LD4	2014
France	SVDU	Usine d'Incineration, Cve de S	31,000 Nm ³ /hr	60%	DNX-959	2017
France	Syvedac, Sirac	Incineration Plant - 2 Lines	60,700 Nm ³ /hr	50%	DNX-940	2005
Ireland	Eli Lilly	Incinerator	10,000 Nm ³ /hr	78%	DNX-930	2006
Italy	Accam SpA	Incineration Plant	67,000 Nm ³ /hr	67%	DNX LD-939	2018
Italy	AEM Gestioni	Incineration Plant	42,000 Nm ³ /hr	79%	DNX-LD3	2015
Italy	Alto Vincente Ambiente	Incineration Plant - Line 2	34,000 Nm ³ /hr	86%	DNX-939	2011
Italy	Alto Vincente Ambiente	Incineration Plant - Line 3	49,300 Nm ³ /hr	86%	DNX-939	2011
Italy	Alto Vincente Ambiente	Incineration Plant	32,000 Nm ³ /hr	93%	DNX-LD3	2015
Italy	Brianza Energia Ambiente	Incineration Plant - 2 Lines	49,000 Nm ³ /hr	70%	DNX-LD3	2016
Italy	Core	Incineration Plant - Units A-C	25,000 Nm ³ /hr	59%	DNX-959	2010
Italy	Provincia Autonoma di Bolzano	Incineration Plant	117,000 Nm ³ /hr	85%	DNX-930	1996
Italy	REA Rifuti Energia Ambiente	Incineration Plant - Line A+B	68,000 Nm ³ /hr	94%	DNX-930	2007
Italy	Undisclosed, (Area Impianti)	Waste Incineration, 2 Lines	84,300 Nm ³ /hr		DNX-939	2012
Libya	SIPSA Engineering	Chem. Weapon Destruction	5,400 Nm ³ /hr	50%	DNX-949	2011
Middle East	Undisclosed client	One Unit	34,700 Nm ³ /hr	80%	DNX-920	2005
Romania	SNP Petrochem S.A. Arpechim	Gas Incineration	140,000 Nm ³ /hr	99%	DNX-940	2004
Saudi Arabia	Sadara Chemical Company	Waste Gas Incineration, Units	147,000 Nm ³ /hr	43%	DNX-949	2015
Spain	Union Wuimico Farmaceutica, A.A., Uq	Pharmaceutical Plant	9,000 Nm ³ /hr	90%	DNX-950	1998
Thailand	Asahi Kasei	Industrial Waste Incineration	591,000 Nm ³ /hr	98%	DNX-949	2011
Thailand	Ministry of Industrial Works	Waste Incinerator	45 tons/day	90%	DNX-930	2004
The Netherlands	AVR Afvalverwerking	Incineration Plant	70,000 Nm ³ /hr	92%	DNX-929	2009
The Netherlands	BMC, Moerdijk	Chicken Manure Incineration	240,000 Nm ³ /hr	71%	DNX-939	2012
The Netherlands	ESKA Graphic Board B.V.	Hoogezand Paper Mill	21,700 Nm ³ /hr	86%	DNX-LD3	2016
The Netherlands	Lyondell Basell	Waste Incinerator	156,000 Nm ³ /hr	88%	DNX LD-939	2019
The Netherlands	SITA ReEnergy	Incineration Plant	67,000 Nm ³ /hr	80%	DNX-949	2007
UK	Suez	Suez Eco Park Surrey	40,800 Nm ³ /hr	48%	DNX HD-864	2019
USA	Clean Harbors	Eldorado, Arkansas Facility	103,000 Nm ³ /hr	95%	DNX LD-939	2018
USA	Clean Harbors	Incinerator Haz. Waste	103,000 Nm ³ /hr	95%	DNX LD-939	2015
USA	OxyVinyls	Incinerator - 2 Units	36,000 Nm ³ /hr		DNX-930	2002
USA	OxyMar	Incinerator - 2 Units	36,000 Nm ³ /hr		DNX-930	2002
USA	White Mountain Energy	SOG Incinerator	87,000 Nm ³ /hr	86%	DNX-958	2004

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
1.	MVA Spittelau	SGP	Heizbetriebe Wien	AUT	Municipal Waste, Tail End	39 m ³	1989
2.	Ceilcote	SGP	MGC Plasma AG	CHE	Hazardous Waste	2 m ³	1990
3.	MVA Heidelberg	SGP	UNI-Bauamt Heidelberg	DEU	Hospital Waste, Low Temp.	3 m ³	1990
4.	MVA Spittelau Dioxin	SGP	Heizbetriebe Wien	AUT	Municipal Waste, Tail End	22 m ³	1991
5.	Knoll	SGP		CHE	Waste, High Dust	2 m ³	1992
6.	MVA Flötzersteig	AEE	Heizbetriebe Wien	AUT	Municipal Waste, Tail End	52 m ³	1992
7.	MVA Burgkirchen	SHL	ZAS	DEU	Waste, Tail End	24 m ³	1993
8.	München Nord	BASF	Stadtwerke München	DEU	Waste, Tail End	49 m ³	1993
9.	MVA Rotterdam	SGP	AVR	NLD	Municipal Waste, Low Temp.	321 m ³	1993 / 95
10.	Bayer Dormagen	BASF	Lentjes	DEU	Hazardous Waste, Tail End	32 m ³	1994
11.	MVA Schwandorf	BASF	Lentjes	DEU	Municipal Waste	130 m ³	1994
12.	Nijmegen	BASF	KRC	NLD	Municipal Waste, Tail End	35 m ³	1994
13.	MVA Mannheim K1-3	BASF	EVT	DEU	Municipal Waste, Tail End	86 m ³	1994
14.	MVA Essen Karnap	BASF	EVT	DEU	Municipal Waste, Tail End	140 m ³	1994
15.	ZVSMM Schwabach	BASF	Lurgi	DEU	Chemical Waste	9 m ³	1994
16.	RSMV Ciba Geigy	BASF	Ciba Geigy	CHE	Hazardous Waste	12 m ³	1995
17.	BASF Residue Incin. N800	BASF	BASF	DEU	Hazardous Waste, Low Dust	233 m ³	1995
18.	MVA Wels	AEE	WAV	AUT	Municipal Waste, Tail End	20 m ³	1995
19.	MVA Leudelingen	BASF		LUX	Municipal Waste, Tail End	16 m ³	1995
20.	MHKW Darmstadt	BASF		DEU	Municipal Waste	100 m ³	1995
21.	Wuppertal	BASF		DEU	Municipal Waste, Low Temp.	154 m ³	1995
22.	Bayer Bülrig	BASF	Bayer AG	DEU	Chemical Waste	43 m ³	1995
23.	Bayer Uerdingen	BASF	Bayer AG	DEU	Chemical Waste	12 m ³	1995
24.	SYSAV	BASF	Sysav	SWE	Municipal Waste	11 m ³	1995
25.	ROW Wesseling	BASF	ROW	DEU	Waste	24 m ³	1995
26.	Schwarzheide	BASF	Integral	DEU	Hazardous Waste, Tail End	29 m ³	1995
27.	MVA Iserlohn	BASF		DEU	Municipal Waste	87 m ³	1995

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
28.	SMVA Lonza	AEE	Lonza AG	CHE	Residue, Tail End	25 m ³	1995
29.	KVA Thurgau	AEE	Verband KVA Thurgau	CHE	Municipal and Industrial Waste, Tail End	33 m ³	1996
30.	MVA Bielefeld	BASF		DEU	Municipal Waste	204 m ³	1996
31.	CZ Süd	BASF	BASF	DEU	Residue, Tail End	3 m ³	1996
32.	Höchst	BASF	Hoechst AG	DEU	Hazardous Waste	21 m ³	1996
33.	KVA St. Gallen	BASF	AEE	CHE	Municipal Waste, Tail End	11 m ³	1996
34.	MHKW Ludwigshafen	BASF		DEU	Municipal Waste	78 m ³	1996
35.	MVA Flingern	BASF		DEU	Municipal Waste, Tail End	106 m ³	1996
36.	MHKW Bamberg	BASF		DEU	Municipal Waste	21 m ³	1996
37.	HKW München Nord	BASF		DEU	Municipal Waste	63 m ³	1996
38.	MKW Weissenhorn	BASF		DEU	Municipal Waste	41 m ³	1996
39.	MVA Zavin	AEE		NLD	Hospital Waste, Low Temp.	7 m ³	1996
40.	Colombes	Integral		FRA	Waste, Tail End	20 m ³	1996
41.	CIBA Geigy	Smogless		ITA	Waste	6 m ³	1997
42.	MVA Mannheim IV	BASF		DEU	Municipal Waste, Tail End	46 m ³	1997
43.	MVA Zagreb	Hafner		HRV	Waste	4 m ³	1997
44.	GMVA Niederrhein	BASF		DEU	Municipal Waste	58 m ³	1997
45.	RMVA Köln	BASF		DEU	Municipal Waste	115 m ³	1997
46.	MVA Lenzing	Integral		AUT	Waste, Tail End	29 m ³	1997
47.	BASF N806	BASF	BASF	DEU	Hazardous Waste, Low Dust	24 m ³	1997
48.	MVA Constanti	BASF	AE-Energietechnik	ESP	Hazardous Waste, Low Dust	29 m ³	1998
49.	MVA Wuppertal	Integral		DEU	Municipal Waste, Low Temp., Additional Delivery	51 m ³	1998
50.	KVA Basel	BASF		CHE	Municipal Waste, Low Dust	58 m ³	1998
51.	MVA Würzburg	BASF		DEU	Municipal Waste, High Dust	16 m ³	1998
52.	MVA Buchs	BASF	AE	CHE	Municipal Waste, Tail End	54 m ³	1998
53.	SMVA Ostrava	AE-Energietechnik		CZE	Hazardous Waste, Tail End	9 m ³	1999
54.	BASF N806	BASF	BASF	DEU	Hazardous Waste, Low Dust	8 m ³	1999

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
55.	MVA Niederurnen	BASF		CHE	Municipal Waste	57 m ³	1999
56.	Thermoselect Karlsruhe	BASF	Steuler	DEU	Waste	9 m ³	1999
57.	TRV-Wesseling	BASF		DEU	Industrial- and Hazardous Waste	13 m ³	1999
58.	Genf Linie 5, 6, 3	BASF	SIG / AE-Energietechnik	CHE	Municipal Waste, Low Dust	139 m ³	2000/01
59.	Dalmine	Integral		ITA	Waste, Tail End	13 m ³	2000
60.	Rhodia	BASF	Rhodia	DEU	Hazardous/Liquide Waste	14 m ³	2000
61.	BASF N810	BASF	BASF	DEU	Hazardous Waste, Low Dust, Additional Delivery	29 m ³	2001
62.	ROW-Wesseling TRV	BASF	ROW	DEU	Industrial- and Hazardous Waste, Additional Delivery	13 m ³	2001
63.	MVA Fribourg	BASF		CHE	Waste, Tail End	33 m ³	2001
64.	Creteil	BASF	ELEX	FRA	Municipal Waste, Tail End	48 m ³	2001
65.	HIMTEC	BASF		ITA	Industrial Waste, Tail End	5 m ³	2001
66.	CO-Catalyst Rotterdam	AE-Energietechnik	AVR	NLD	Municipal Waste, Tail End, CO Oxidation	6 m ³	2001
67.	MVA Bamberg	BASF		DEU	Municipal Waste, Tail End	7 m ³	2001
68.	MVA Zavin	BASF	Steuler	NLD	Hospital Waste, Low Temperature, Additional Delivery	3 m ³	2001
69.	Thermoselect Karlsruhe	BASF	EnBW	DEU	Waste	7 m ³	2001
70.	MVA Würzburg	BASF	BBP Environment	DEU	Municipal Waste, High Dust	34 m ³	2002
71.	TRV Wesseling	BASF		DEU	Industrial- and Hazardous Waste, Additional Delivery	13 m ³	2002
72.	Halmstads Renhallnings AB	BASF	BBP Environment	SWE	Municipal Waste, Tail End	19 m ³	2002
73.	Bayer Antwerpen	BASF	Bayer AG	BEL	Industrial Waste, Tail End	13 m ³	2002
74.	KVA Turgi	BASF	GV Region Baden-Brugg	CHE	Municipal Waste, Tail End	11 m ³	2002
75.	GMVA Oberhausen	BASF		DEU	Municipal Waste, Tail End	19 m ³	2002
76.	MVA Malmö	BASF	LAB	SWE	Municipal Waste, Tail End	30 m ³	2002
77.	KVA Thurgau	BASF	CTU	CHE	Municipal Waste, Tail End, Additional Delivery	8 m ³	2002
78.	Nijmegen	BASF		NLD	Municipal Waste, Tail End, Additional Delivery	6 m ³	2002
79.	Genf Linie 5	BASF	CTU	CHE	Municipal Waste, Low Dust, Additional Delivery	55 m ³	2002
80.	T.A. Lauta	AE	STEAG	DEU	Municipal Waste, Tail End, Low Temp.	47 m ³	2003
81.	RSMVA Basel	BASF	Valorec Services AG	CHE	Residue, Additional Delivery	12 m ³	2003

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
82.	EBS WSO 4	Integral	Fernwärme Wien	AUT	Sludge, Municipal Waste	22 m ³	2003
83.	Nimes	Integral		FRA	Waste, Tail End	9 m ³	2003
84.	Le Havre	Integral		FRA	Waste, Tail End	13 m ³	2003
85.	TRV Niklasdorf	AEE		AUT	Waste, Tail End	12 m ³	2003
86.	Nijmegen Line 2	BASF		NLD	Municipal Waste, Tail End, Additional Delivery	11 m ³	2003
87.	MVA Constanti	BASF		ESP	Hazardous Waste, Low Dust, Additional Delivery	10 m ³	2003
88.	KVA St. Gallen	BASF		CHE	Municipal Waste, Tail End, Additional Delivery	9 m ³	2003
89.	TBA Arnoldstein	AEE	KRV	AUT	Municipal Waste, Tail End, Low Temp.	14 m ³	2003
90.	DOMO Caproleuna	BASF		DEU	Residue, Tail End	3 m ³	2003
91.	Höchst	BASF	Höchst	DEU	Hazardous Waste, Additional Delivery	11 m ³	2003
92.	TRV Wesseling	BASF		DEU	Industrial- and Hazardous Waste, Additional Delivery	13 m ³	2004
93.	Colleferro Unit 1 & 2		Termokimik	ITA	Municipal Waste, Tail End	36 m ³	2004
94.	Genf Linie 6	BASF	SIG / CTU	CHE	Municipal Waste, Low Dust, Additional Delivery	72 m ³	2004
95.	ICDI Charleroi	HRC		BEL	Municipal Waste, Low Dust	7 m ³	2004
96.	KVA Basel	BASF		CHE	Municipal Waste, Low Dust	29 m ³	2004
97.	WAV II Wels	LAB GmbH	Energie AG Oberösterreich	AUT	Municipal Waste, Tail End	41 m ³	2005
98.	Sammel SCR Simmering	Envirgy	Fernwärme Wien	AUT	Sludge, Hazardous Waste, Tail End, Low Temp.	125 m ³	2005
99.	Ostrava	SPOVO	SPOVO	CZE	Hazardous Waste, Tail End, Low Temp. Additional Delivery	3 m ³	2005
100.	Saint Ouen Unit 1-3	BASF	LAB / SYCTOM	FRA	Municipal Waste, Tail End	219 m ³	2005
101.	Brest		Termokimik	FRA	Municipal Waste, Tail End	14 m ³	2005
102.	MSWI Bordeaux	BASF	ASTRIA / HRC	FRA	Municipal Waste, Tail End	85 m ³	2005
103.	CVDU Nice	BASF	LAB	FRA	Municipal Waste, Tail End, Dioxin	157 m ³	2005
104.	MVA Malmö	BASF	LAB	SWE	Municipal Waste, Tail End, Additional Delivery	22 m ³	2005
105.	Tirnadrid	Integral		ESP	Municipal Waste, Tail End, Low Temp.	133 m ³	2005
106.	Rennes	BASF	Von Roll	FRA	Municipal Waste, Tail End	23 m ³	2005
107.	Nantes	BASF	Von Roll	FRA	Municipal Waste, Tail End	34 m ³	2005
108.	Coueron / Nantes	BASF	LAB	FRA	Municipal Waste, Tail End	12 m ³	2005

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
109.	Recycling Komb. Rotterdam	BASF	Steuler	NLD	Residue, Tail End	13 m ³	2005
110.	BASF Incineration plant	BASF	BASF	DEU	Residue, Raw gas, NOx- + CO-removal	5 m ³	2005
111.	Chaumont	HRC	SHMVD Chaumont	FRA	Municipal Waste, Tail End	13 m ³	2005
112.	Constanti	BASF		ESP	Residue, Low Dust, Additional Delivery	20 m ³	2005
113.	Kimhae	BASF	SPECO	KOR	Municipal Waste, Tail End, Additional Delivery	5 m ³	2005
114.	BASF CZ Süd	BASF	BASF	DEU	Residue, Tail End, Additional Delivery	3 m ³	2005
115.	Steuler	BASF	Steuler	DEU	Waste, Tail End	6 m ³	2005
116.	Sangju	BASF	David Chemical	KOR	Waste, Tail End, Additional Delivery	3 m ³	2005
117.	Genf Linie 5	BASF	SIG	CHE	Municipal Waste, Low Dust, Additional Delivery	72 m ³	2006
118.	MSW Ludres	Hamon	Nancy Energie	FRA	Waste, Tail End, Low Temperature	40 m ³	2006
119.	CENON	Hamon	UIOM de Cenon	FRA	Municipal Waste, Tail End	20 m ³	2006
120.	Rhodia	BASF	Rhodia	DEU	Hazardous/Liquide Waste, Additional Delivery	14 m ³	2006
121.	Kimhae	BASF	SPECO	KOR	Municipal Waste, Tail End, Additional Delivery	5 m ³	2006
122.	NANYA	BASF	Lucky Lotus Corp.	TWN	Industrial Waste Additional Delivery	2 m ³	2006
123.	Ferrara	Alstom	Hera	ITA	Municipal Waste, Tail End, Low Temp.	54 m ³	2006
124.	MVA Flötzersteig	Integral	Fernwärme Wien	AUT	Municipal Waste, Tail End, Low Temp.	71 m ³	2006
125.	MVA Pfaffenau	Integral	WKU / Envirgy	AUT	Municipal Waste, Tail End, Low Temp.	68 m ³	2007
126.	Dunkerque	BASF	Dunkerque Grand Littoral / Von Roll	FRA	Municipal Waste, Tail End	9 m ³	2007
127.	Issy-les-Moulineaux	BASF	SYCTOM / Von Roll	FRA	Municipal Waste, Tail End, Low Temp.	163 m ³	2007
128.	Forli	Alstom	Hera	ITA	Municipal Waste, Tail End, Low Temp.	44 m ³	2007
129.	BMC Moerdijk	AEE	BMC Moerdijk BV	NLD	Chicken litter, Tail End	20 m ³	2007
130.	AMSA Silla 2	Termokimik	AMSA	ITA	Municipal Waste, Tail End, Low Temperature	171 m ³	2007
131.	BASF CZ Süd II	BASF	BASF	DEU	Residue Incineration	4 m ³	2007
132.	MVA AVS 4825	BASF		DEU	Residue Incineration	9 m ³	2007
133.	VA-Schottland	BASF	LTB	DEU	Residue Incineration	3 m ³	2007
134.	MVA Prag Linie 1-4 Prague-Malešice	BASF	Pražské služby	CZE	Municipal Waste, Low Dust	236 m ³	2007
135.	Constanti	BASF		ESP	Residue, Low Dust, Additional Delivery	10 m ³	2007

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
136.	Dadae MSWI	SPECO		KOR	Municipal Waste, Additional Delivery	8 m ³	2007
137.	Myungji MSWi	SPECO		KOR	Municipal Waste, Additional Delivery	25 m ³	2007
138.	Constanti	BASF	Gestio De Residus Especials De Catalunya, S.A.	ESP	Residue, Low Dust, Additional Delivery	10 m ³	2007
139.	MSW Antibes	Hamon	Veolia	FRA	Municipal Waste, Tail End	37 m ³	2007
140.	MVA Malmö	BASF	LAB	SWE	Municipal Waste, Additional Delivery	63 m ³	2007
141.	MVA Twence	BASF	LAB	NLD	Municipal Waste, Tail End	50 m ³	2007
142.	MVA Marseille	BASF	LAB	FRA	Municipal Waste, Tail End	29 m ³	2007
143.	Lamballe	BASF	Marguin	FRA	Municipal Waste	8 m ³	2007
144.	Icheon MSWI	Dongbu	Dongbu	KOR	Municipal Waste	16 m ³	2007
145.	Padova Line 2+3	Termokimik		ITA	Municipal Waste Low Temperature	55 m ³	2008/2009
146.	Borsodchem NYRT	BASF	Borsodchem ZRT	HUN	Municipal Waste, Tail End	15 m ³	2008
147.	Rohdia Residue Boiler 5	BASF	Rhodia	FRA	Residue Incineration	96 m ³	2008
148.	Jeonggwan MSWI	SPECO	SPECO	KOR	Municipal Waste	6 m ³	2008
149.	Bazenheid	ELEX	Bazenheid	CHE	Municipal Waste, Tail End	51 m ³	2008
150.	Eunpyung MSWI	Eco En Top		KOR	Municipal Waste	5 m ³	2008
151.	Myungji MSWI	SPECO	SPECO	KOR	Municipal Waste Additional Delivery	25 m ³	2008
152.	Haewundae MSWI	Busan Environmental Corp	Busan Environmental Corp	KOR	Municipal Waste, Additional Delivery	17 m ³	2008
153.	MVA Zistersdorf	BASF	Von Roll	AUT	Municipal Waste Tail End	41 m ³	2008
154.	Mida Crotone	Hafner	Mida S.r.l.	ITA	Municipal Waste, Tail End	7 m ³	2008
155.	TBA Arnoldstein	KRV	KRV	AUT	Municipal Waste Low Temperature, Additional Delivery	6 m ³	2008
156.	Yangju MSWI Plant	SPECO	SPECO	KOR	Municipal Waste	13 m ³	2008
157.	Pangyo MSWI Plant	SPECO	SPECO	KOR	Municipal Waste	7 m ³	2008
158.	Masan MSWI Plant	SPECO	SPECO	KOR	Municipal Waste	5 m ³	2008
159.	Ferrara	Alstom	HERA	ITA	Municipal Waste, Tail End, Low Temp. Additional Delivery	44 m ³	2008
160.	Rimini	Alstom	HERA	ITA	Municipal Waste, Tail End, Low Temperature	44 m ³	2008
161.	Genf	BASF	Usine de Cheneviers	CHE	Municipal Waste, Low Dust, Additional Delivery	72 m ³	2008
162.	MVA Dürnrohr Linie 3	Envirgy	AVN	AUT	Municipal Waste, Tail End	35 m ³	2009

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
163.	Mallorca P 3095	BASF	TIRME SA	ESP	Municipal Waste, Tail End	45 m ³	2009
164.	Gwangmyeong	Blue Bird	Blue Bird	KOR	Waste Heat Boiler	9 m ³	2009
165.	MSW Giubiasco	BASF	Von Roll	DEU	Municipal Waste, Tail End	30 m ³	2009
166.	Kuri MSWI	SPECO	SPECO	KOR	Municipal Waste, Low Dust	18 m ³	2009
167.	Daejeon MSWI	SPECO	SPECO	KOR	Municipal Waste	6 m ³	2009
168.	Dadae MSWI	MSWI Dadae	MSWI Dadae	KOR	Municipal Waste, Additional Delivery	9 m ³	2009
169.	TBA Arnoldstein	KRV	KRV	AUT	Municipal Waste Low Temperature, Additional Delivery	8 m ³	2009
170.	NANYA	BASF	Lucky Lotus Corp.	TWN	Industrial Waste Additional Delivery	3 m ³	2009
171.	MVA Dordrecht	BASF	LAB	NLD	Municipal Waste	65 m ³	2009
172.	MVA Göteborg	BASF	LAB	SWE	Municipal Waste	39 m ³	2009
173.	Constanti	BASF		ESP	Residue, Low Dust, Additional Delivery	3 m ³	2009
174.	MSW Reims	Hamon	Hamon	FRA	Municipal Waste, Tail End Low Temperature	31 m ³	2009
175.	Ulsan MSWI	Halla Energy & Environment		KOR	Municipal Waste, Additional Delivery	10 m ³	2009
176.	Mapo MSWI	Kolon		KOR	Municipal Waste, Additional Delivery	27 m ³	2009
177.	Chaumont	HRC	SHMVD Chaumont	FRA	Municipal Waste, Tail End, Additional Delivery	13 m ³	2009
178.	TABA Leudelange	BASF	Von Roll / Sidor	LUX	Municipal Waste, Tail End Low Temperature	47 m ³	2010
179.	Sivom Mulhouse	Hamon	Sivom	FRA	Municipal Waste, Tail End	61 m ³	2010
180.	MSW Sangju	BASF	David Chemical	KOR	Municipal Waste	3 m ³	2010
181.	MSWI Kimhae	SPECO		KOR	Municipal Waste, Additional Delivery	10 m ³	2010
182.	MSWI Chungju	SPECO		KOR	Municipal Waste, Additional Delivery	7 m ³	2010
183.	MSWI Yongin	Kolon E&C	Yongin City	KOR	Municipal Waste, Additional Delivery	7 m ³	2010
184.	MSWI Rennes	BASF	Veolia	FRA	Municipal Waste, Tail End, Additional Delivery	10 m ³	2010
185.	RHKW Linz	Integral	Linz AG	AUT	Municipal Waste, Tail End	40 m ³	2010
186.	Rhodia	BASF	Rhodia	FRA	Residue Waste, Additional Delivery	26 m ³	2010
187.	Sungseo MSWI # 3	Sungseo		KOR	Municipal Waste	21 m ³	2010
188.	MSW Le Mans	BASF	Veolia	FRA	Municipal Waste	26 m ³	2010
189.	Mistral Spilimbergo	Hafner	Hafner/Mistral Spilimbergo	ITA	Hospital Waste	7 m ³	2010

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
190.	T.A. Lauta	BASF	T.A.Lauta GmbH	DEU	Municipal Waste, Tail End, Low Temp., Additional Delivery	16 m ³	2010
191.	MSW Harlingen	BASF		DEU	Municipal Waste, Tail End	37 m ³	2010
192.	Mataro Line 1+2	Fuel Tech	TEM UTE Constructora	ITA	Municipal Waste	23 m ³	2010
193.	Rhodia	BASF	Rhodia	FRA	Residue Incineration, Additional Delivery	26 m ³	2010
194.	Cenon	BASF	Veolia	FRA	Municipal Waste, Tail End, Additional Delivery	20 m ³	2010
195.	San Vittore Linie 2+3	ATS Air Treatment System	MSWI San Vittore	ITA	Municipal Waste, Tail End	65 m ³	2010/2011
196.	Forli	Hera	Hera	ITA	Municipal Waste, Tail End, Additional Delivery	21 m ³	2011
197.	HDO Incineration Freeport	BASF	BASF	USA	Residue, Additional Delivery	36 m ³	2011
198.	San Vittore Linie 1	ATS Air Treatment System	MSWI San Vittore	ITA	Municipal Waste, Tail End	23 m ³	2011
199.	MVA Moskau MSZ3	Condor	EVN	RUS	Municipal Waste, Tail End	30 m ³	2011
200.	Iksan DHP	Samyoung Plant Co., Ltd.	Samyoung Plant Co., Ltd.	KOR	Waste Incineration (RDF&Coal)	15 m ³	2011
201.	Namyangju MSWI	Ilshin Environmental Co.	Ilshin Environmental Co.	KOR	Waste Incineration	7 m ³	2011
202.	LWI BASF YPC Nanjing	BASF	BASF YPC	CHN	Residue Incineration	13 m ³	2011
203.	Dunkerque - Spare Layer 2011	BASF	Von Roll	FRA	Waste Incineration, Additional Delivery	4 m ³	2011
204.	MSWI Ulsan (New Line)	Tong Yang Magic Co., Ltd.	Tong Yang Magic Co., Ltd.	KOR	Waste Incineration	10 m ³	2011
205.	MSW Flamoal	BASF	LAB	NLD	Municipal Waste, Tail End	20 m ³	2011
206.	MSWI Kimpo	Donglim Eng. Co.	Donglim Eng. Co.	KOR	Municipal Waste	8 m ³	2011
207.	MSWI Dadae	Kolon	Kolon	KOR	Municipal Waste, Additional Delivery	8 m ³	2011
208.	MSWI Myungji	Kolon	Kolon	KOR	Municipal Waste, Additional Delivery	25 m ³	2011
209.	MSWI Haewundae	Kolon	Kolon	KOR	Municipal Waste, Additional Delivery	17 m ³	2011
210.	Colombes Ligne 2 & Ligne 3	INTEGRAL	SIAAP	FRA	Sewage Sludge Incineration	10 m ³	2011
211.	MSWI Kyungju	Tong Yang Magic Co., Ltd.	Tong Yang Magic Co., Ltd.	KOR	Municipal Waste	9 m ³	2011
212.	MSWI Torino	BASF	LAB	ITA	Waste Incineration, Tail End, Low Temp.	181 m ³	2011
213.	RDF MSWI Busan	KIC	KIC	KOR	Municipal Waste	29 m ³	2011
214.	MSWI Icheon	Dongbu	Dongbu	KOR	Municipal Waste, Additional Delivery	16 m ³	2012
215.	RVA Castrop Rauxel	BASF	Thermtec	DEU	Residue Incineration	3 m ³	2012
216.	KVA Zürich Hinwil	BASF	Hitachi Zosen Inova	CHE	Municipal Waste, Low Temp.	111 m ³	2012

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
217.	T.A. Lauta	BASF	T.A.Lauta GmbH	DEU	Municipal Waste, Tail End, Low Temp.	15 m ³	2012
218.	JGC C&C China project	JGC C&C	Tongfang	CHN	Municipal Waste	105 m ³	2012
219.	RSMVA Basel	BASF	RSMVA Basel	CHE	Residue, Additional Delivery	12 m ³	2012
220.	BASF Bologna	BASF	BASF	ITA	Residue Incineration	5 m ³	2012
221.	CVE d'Halluin Unit 1-3	BASF	Elex	FRA	Municipal Waste, Tail End	26 m ³	2012
222.	Acerra	A2A		ITA	Municipal Waste	26 m ³	2012
223.	Ivry Unit 1+2	BASF	Novergie	FRA	Municipal Waste, Low Dust, Dioxin/Furan, Additional Delivery	156 m ³	2012
224.	MSWI Dadae	Kolon	Busan City	KOR	Municipal Waste, Additional Delivery	8 m ³	2012
225.	MSWI Myungji	Kolon	Busan City	KOR	Municipal Waste, Additional Delivery	25 m ³	2012
226.	H&H Bozen	BASF	H&H Umwelttechnik GmbH	ITA	Municipal Waste	31 m ³	2012
227.	MVA Prag	Zauner	Pražské služby	CZE	Municipal Waste, Low Dust, Additional Delivery	7 m ³	2012
228.	Rhodia	BASF	Rhodia	DEU	Residue Waste, Additional Delivery	17 m ³	2012
229.	EEW Delfzijl	E.ON Delfzijl NL	E.ON Delfzijl NL	NLD	Municipal Wast	20 m ³	2012
230.	Verbrennung DE #1	CTP	Tridelta Thermprozess	DEU	Hazardous Waste	4 m ³	2012
231.	Giubiasco	BASF	Hitachi Zosen Inova	ITA	Municipal Waste, Tail End, Additional Delivery	15 m ³	2012/2013
232.	AMSA	A2A	AMSA	ITA	Waste Incineration, Low Temp., Additional Delivery	87 m ³	2012/2013
233.	Ivry Unit 3+4	BASF	Novergie	FRA	Municipal Waste, Low Dust, Dioxin/Furan, Additional Delivery	156 m ³	2013
234.	MSW Lyon Nord	BASF	Sita	FRA	Municipal Waste, Tail End	51 m ³	2013
235.	MVA Prag	Zauner	Pražské služby	CZE	Municipal Waste, Low Dust, Additional Delivery	15 m ³	2013
236.	Anyang MSWI	Coreco Co.	Anyang MSWI	KOR	Municipal Waste	10 m ³	2013
237.	MSW Ludres	Hamon Environmental s.a.r.l.	Nancy Energie	FRA	Municipal Waste, Tail End, Low Temperature with Regeneration	20 m ³	2013
238.	Acerra 2013	A2A	A2A	ITA	Municipal Waste Incineration with Dioxin	26 m ³	2013
239.	Lasse	BASF	Veolia	FRA	Municipal Waste, Tail End	10 m ³	2013
240.	MVA Spittelau	STRABAG AG	Wien Energie	AUT	Municipal Waste, Tail End, Low Temperature	81 m ³	2013
241.	Pluzunet	BASF	CNIM/LAB	FRA	Municipal Waste Incineration, Additional Delivery	7 m ³	2013
242.	Sangju MSWI	Sangju	Sangju	KOR	Waste Incineration, Additional Delivery	3 m ³	2013
243.	Orlen Unit K6	Babcock Noell	PKN	POL	Residue Oil Boiler	61 m ³	2013

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
244.	MSWI Colleferro	Thermokimik		ITA	Municipal Waste Incineration	29 m ³	2013
245.	ACN Plant	BASF		CHN	Residue Incineration	15 m ³	2013
246.	MSWI Bordeaux Spare Layer 2013	BASF		FRA	Waste Incineration, dioxine, Tail End	14 m ³	2013
247.	MSWI Bordeaux Spare Layer 2014	BASF		FRA	Waste Incineration, dioxine, Tail End	29 m ³	2013
248.	MSWI Yongin #2 + #3 Repl.	Kolon Env.Co./Yongin City	Kolon Env.Co./Yongin City	KOR	Waste Incineration	13 m ³	2013
249.	Dioxin Kat Israel	BASF		DEU	Residue Incineration plant	3 m ³	2013
250.	Acerra part 2 - 2013	A2A	A2A	ITA	Municipal Waste Incineration with Dioxin	26 m ³	2014
251.	MVA Prag Spare Layer	Zauner		CZE	Municipal Waste Incinerator, Low Dust	30 m ³	2014
252.	MSWI Mapo	Kolon	MSWI Kolon	KOR	Municipal Waste Incinerator, Additional Delivery	27 m ³	2014
253.	Rhodia	BASF	Rhodia	FRA	Residue Incinerator, Additional Delivery	17 m ³	2014
254.	HDO Incineration Freeport	BASF	BASF	USA	Residue Incineration	36 m ³	2014
255.	West Palm Beach Unit 1, 2, 3	Babcock & Wilcox	Solid Waste Authority of Palm Beach	USA	Municipal Waste, Tail End	95 m ³	2014
256.	Creteil	BASF	CIE	FRA	Municipal Waste, Tail End, Additional Delivery	24 m ³	2014
257.	MSW Haidian	BASF		CHN	Municipal Waste, Tail End	47 m ³	2014
258.	Schwarzheide	BASF	BASF	DEU	Residue Incinerator, Additional Delivery	10 m ³	2014
259.	CVDU Nice	BASF	LAB	FRA	Municipal Waste, Tail End, Dioxin Additional Delivery	24 m ³	2014
260.	Borsodchem	BASF	Borsodchem ZRT	HUN	Municipal Waste, Tail End Additional Delivery	8 m ³	2014
261.	MSW Chotikov	Zauner Anlagenbau GmbH	Skládka Chotíkov	CZE	Municipal Waste, Tail End, Dioxin	29 m ³	2014
262.	Mistral Spilimbergo	Mistral FVG S.R.L.	Mistral FVG S.R.L.	ITA	Hospital Waste, Additional Delivery	3 m ³	2014
263.	MSWI Gyeongsan	EG Corp.		KOR	Municipal Waste Incinerator	5 m ³	2014
264.	MSWI New Cheongju	EG Corp.		KOR	Municipal Waste Incinerator	4 m ³	2014
265.	Saint Ouen	BASF		FRA	Waste Incinerator, Tail End	25 m ³	2014
266.	KVA Hagenholz	BASF	KVA Hagenholz	CH	Municipal waste incineration, Low Dust	50 m ³	2014
267.	Saint Ouen	BASF		FRA	Waste Incinerator, Tail End	24 m ³	2014
268.	MSWI Modena	ATS	MSWI Modena	ITA	Waste Incineration Tail End	17 m ³	2014
269.	BASF N800	BASF	BASF	DEU	Residue Waste Incineration Low Dust; Additional Delivery	117 m ³	2014
270.	MSWI Eunpyung	UET Engineering Co.	Eunpyung MSWI	KOR	Waste Incineration; Additional Delivery	5 m ³	2014

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
271.	Sarpi Dorog	BASF		HUN	Residue Incinerator	8 m ³	2014
272.	BASF C 19.8700	BASF	BASF	CHN	Residue Waste Incineration	4 m ³	2015
273.	BASF C 19.8730	BASF	BASF	CHN	Residue Waste Incineration	5 m ³	2015
274.	MSWI Icheon	Dongbu Construction	Icheon City	KOR	Municipal Waste; Additional Delivery	16 m ³	2015
275.	JGC China / BN Project	JGC Catalysts & Chemicals Ltd.	Tongfang	CHN	Waste Incineration Tail End	59 m ³	2015
276.	Orlen K4	Babcock Noell GmbH	PKN	PL	Residue Oil Boiler	61 m ³	2015
277.	KVA Hagenholz Linie 2	BASF	KVA Hagenholz	CH	Waste Incineration, Low Dust	51 m ³	2015
278.	Dijon	BASF		FRA	Waste Incinerator; Tail End	26 m ³	2015
279.	Saint Ouen	BASF		FRA	Waste Incineration Tail End; Additional Delivery	24 m ³	2015
280.	Colleferro	Termokimik Corp.	C.T.E. Colleferro	ITA	Municipal Waste Incinerator; Additional Delivery	10 m ³	2015
281.	Schwarzheide	BASF	BASF	DEU	Residue Incineration, Additional Delivery	10 m ³	2015
282.	Creteil	BASF	CIE	FRA	Municipal Waste, Tail End, Additional Delivery	24 m ³	2015
283.	Nice Ligne 3-4	BASF	LAB	FRA	Municipal waste incineration, Tail End	30 m ³	2015
284.	Sukmoon DHP	KOLON Env. Service Co.		KOR	Waste Wood & RDF	21 m ³	2015
285.	Amsa 3rd Layer	A2A	A2A	IT	Municipal waste incineration, low temp.	28 m ³	2015
286.	Beijing Chaoyang MSWI	Beijing Golden State		CHN	Municipal waste incineration	66 m ³	2015
287.	MSWI Myungji	Busan City		CHN	Municipal waste incineration, Additional Delivery	26 m ³	2015
288.	Filago	Ecolombardia 4 / Boldrocchi Ecologia		IT	Municipal waste incinerator, low temperature	74 m ³	2015
289.	Daegu RDF	Donglim Engineering		KOR	Waste incineration	17 m ³	2015
290.	Ulsan SRF	Donglim Engineering		KOR	Waste Incineration	13 m ³	2015
291.	Mulhouse	BASF		FRA	Waste Incineration Tail End; Additional Delivery	61 m ³	2015
292.	Rhodia Spare Layer	BASF	Rhodia	FRA	Residue incineration; Additional Delivery	32 m ³	2015
293.	Taizhou Delixi Waste Incinerator	Changzhou Elex Environmental		CHN	Hazardous Waste Incineration	11 m ³	2015
294.	Saint Ouen Repl.	BASF		FRA	Waste Incineration Tail End; Additional Delivery	97 m ³	2016
295.	Benesse Maremne	BASF		FRA	Municipal waste incineration	12 m ³	2016
296.	Chengdu Wanxing MSWI	Shanghai ZOSUM Engineering Co., Ltd.		CHN	Municipal waste incineration	86 m ³	2016
297.	BASF Pasadena	BASF		USA	Residue incineration plant	9 m ³	2016

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
298.	Orlen K2	Babcock Noell	PKN	PL	Residue Oil Boiler	49 m ³	2016
299.	BASF Pasadena 2nd + 3rd Layer	BASF	BASF	USA	Residue incineration plant, Additional Delivery	18 m ³	2016
300.	Rhodia Spare Layer	BASF		FRA	Residue incineration, Spare layer	21 m ³	2016
301.	Mucha RIP	Yara Taiwan		TWN	Waste Incineration, Dioxin removal	29 m ³	2016
302.	MSWI Rouen Unit 1-3	BASF		FRA	Waste incineration Tail end	38 m ³	2016
303.	San Vittore L1 Additional Layer		Termomeccanica Ecologia	ITA	Waste Incineration Tail End; Additional D	4.86	2016
304.	Jeonju Power SRF	EG Corp.	Samchullyes Co.	KOR	Municipal waste incineration	26 m ³	2016
305.	MSWI Bordeaux	BASF	Astria	FRA	Waste Incineration, Dioxine, Tail End, low temp.; Additional Delivery	43 m ³	2016
306.	MSWI Tornino Spare Layer		IREN Energia	IT	Waste Incineration; Additional Delivery	89 m ³	2016
307.	Aplex Cremator	Aplex Cremator	Aplex	KOR	Cremator	5 m ³	2016
308.	Nox Vent Treatment DOW	DOW Olefinverbund GmbH	DOW Olefinverbund GmbH		Residue incineration plant; Additional Delivery	4 m ³	2016
309.	HDO Incineration Freeport	BASF	BASF	USA	Residue incineration; Additional Delivery	36 m ³	2016
310.	Constanti	Envirotherm GmbH	SARPI	DEU	Residue incineration; Additional Delivery	3 m ³	2016
311.	Colombes Ligne 2	Le Gaz Integral	Le SIAAP	FRA	Waste Incineration; Additional Delivery	5 m ³	2016
312.	CTO Project	Tialoc (Shanghai) Environmental, Ltd	-	CHN	Waste gas furnace	8 m ³	2016
313.	KVA Thurgau	BASF	Elex	CH	Waste Incineration Tail End	42 m ³	2016
314.	Asuwei MSWI	Shanghai Dingtu Env.		CHN	Waste Incineration	119 m ³	2016
315.	Wenzhou Yongqiang MSWI	Shanghai Dingtu Env.	Weiming	CHN	Waste Incineration	74 m ³	2016
316.	Dabrowa Gornicza	Envirotherm	SARPI	PL	Waste tail end	8 m ³	2016
317.	Lyon Süd	BASF		FRA	Waste Incineration, Tail End, Low Temp.	10 m ³	2016
318.	MSW Le Mans	BASF	Veolia	FRA	Waste incineration tail end low temp.; Additional Delivery	5 m ³	2016
319.	Saint Ouen Repl.	BASF		FRA	Waste Incineration Tail End; Additional Delivery	49 m ³	2017
320.	Aplex Cremator (low dust)	Aplex Cremator	Aplex	KOR	Crematory	5 m ³	2017
321.	BASF C520	BASF		DEU	Residue waste incineration	3 m ³	2017
322.	Pohang RDF	Aerix Co.	Pohang City	KOR	Municipal Solid Waste Incinerator	11 m ³	2017
323.	Soprano Ron	Hamon Environmental s.a.r.l.	Sita Rekem	FRA	Municipal Waste; Additional Delivery	15 m ³	2017
324.	Kwangju SRF	KC Cottrell	Korea District Heating Coop.	KOR	Municipal Solid Waste Incinerator, Additional Delivery	25 m ³	2017

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
325.	MSWI Saint Thibault des Vignes Ligne 1+2		Suez Environment	IT	Waste incineration	77 m ³	2017
326.	MSWI Shunyi	Changzhou Elex Env.	Changzhou Elex Env.	CHN	Waste Incineration	25 m ³	2017
327.	AMSA 3rd Layer part 2&3		A2A S.p.A.	IT	Municipal waste incineration	56 m ³	2017
328.	Issy-les-Monlineaux	BASF		FRA	Waste Incineration Tail End; Additional Delivery	20 m ³	2017
329.	MSWI Torino Spare Layer		IREN S.p.A.	IT	Waste incineration	29 m ³	2017
330.	MSWI Prague	Zauner	Prazske Sluzby	CZE	Waste incineration low dust; Additional Delivery	237 m ³	2017
331.	Constanti	Envirotherm	SARPI	DEU	Residue Incineration; Additional Delivery	19 m ³	2017
332.	Beijing Huairou MSWI	Shanghai ZOSUM Engineering Co., Ltd.	Shanghai ZOSUM Engineering Co.Ltd.	CHN	Waste Incineration	15 m ³	2017
333.	Dabrowa Gornicza	Envirotherm		PL	Waste Incineration Tail End; Additional Delivery	8 m ³	2017
334.	Colombes Ligne	Le Gaz Integral	SIAPP	FRA	Waste Incineration Tail End; Additional Delivery	5 m ³	2017
335.	Yantai Wanhua TDI Incinerator	Shanghai Dingtu		CHN	Liquid hazardous waste incineration	27 m ³	2017
336.	Cixi Zhongmao MSWI	Shanghai Dingtu		CHN	Municipal Solid Waste Incinerator	55 m ³	2017
337.	Aplex Cremator High Dust	Aplex Cremator	Aplex	KOR	Crematory	10 m ³	2017
338.	Baoan 1st + 2nd Phase MSWI	Shanghai Dingtu		CHN	Municipal Solid Waste Incinerator	130 m ³	2017
339.	Nanshan 1st Phase MSWI/	Shanghai Dingtu		CHN	Municipal Solid Waste Incinerator	21 m ³	2017
340.	Aplex Cremator (Low dust)	Aplex Cremator	Aplex	KOR	Crematory; Additional Delivery	10 m ³	2017
341.	Bordeaux	BASF	Astria	FRA	Waste Incineration, Tail End, Additional Delivery	43 m ³	2017
342.	Oschatz Thermal Oxidizer	Yara Environmental Protection (Qingdao) Co. Ltd	Oschatz	CHN	Waste liquids, Tail End	10 m ³	2017
343.	Currenta SCR-1	Envirotherm	Currenta	DEU	Residue Waste Incineration, Tail End	22 m ³	2017
344.	KVA Zürich Hinwil	BASF	KEZO Zweckverband Kehrichtverwertung Zürcher Oberland	CH	Waste, low temp. Additional Delivery	28 m ³	2017
345.	Haeraeus Bitterfeld	BASF	Steuler	DEU	Silicone-Oil incineration	6 m ³	2018
346.	Cangnan MSWI	Shanghai Dingtu Environmental		CHN	Municipal Solid Waste Incinerator	52 m ³	2018
347.	Qingzhou MSWI	Shanghai Dingtu Environmental		CHN	Municipal Solid Waste Incinerator	36 m ³	2018
348.	Linyi MSWI	Shanghai Dingtu Environmental		CHN	Municipal Solid Waste Incinerator	44 m ³	2018
349.	Taian MSWI	Shanghai Dingtu Environmental		CHN	Municipal Solid Waste Incinerator	45 m ³	2018
350.	Rhodia	BASF	Rhodia	FRA	Hazardous/Liquide Waste	13 m ³	2018
351.	Currenta SCR II Leverkusen	Andritz	Currenta	DEU	Residue Waste Incineration, Tail End	39 m ³	2018

Curr.No.	Project	Client	End user / Engineering company	Plant location	Application	Shipped quantity	Delivery date
352.	MSWI Lujiashan Repl.	Shanghai Dingtu Environmental Engineering		CHN	Municipal Waste Incinerator	26 m ³	2018
353.	Orlen K4/K5/K6/K7	PKN Orlen	PKN Orlen	POL	Residue Oil Boiler	61 m ³	2018
354.	NOx Vent Treatment DOW	DOW Olefinverbund GmbH	DOW Olefinverbund GmbH	DEU	Residue incineration plant, Additional Delivery	4 m ³	2018
355.	Jiangbei MSWI	Shanghai Dingtu		CHN	Waste Incineration Tail End, Additional Delivery	44 m ³	2018
356.	RuiAn MSWI	Shanghai Dingtu	Weiming	CHN	Waste Incineration Tail End	57 m ³	2018
357.	Coueron-Nantes	BASF	Veolia	FRA	Waste Incineration Tail End, Additional Delivery	6 m ³	2018
358.	Shougang Lujiashan MSWI (3 Lines)	Shanghai Dingtu	Beijing Shougang	CHN	Waste Incineration Tail End	79 m ³	2018
359.	Rhodia - Spare Layer 2+3/2018	BASF	Rhodia	FRA	Liquide Waste Incineration	34 m ³	2018
360.	Aplex Cremator (high dust)	Aplex Cremator	Aplex	KOR	Crematory, Additional Delivery	10 m ³	2018
361.	Aplex Cremator (low dust)	Aplex Cremator	Aplex	KOR	Crematory, Additional Delivery	10 m ³	2018
362.	Currenta SCR	Currenta		DEU	Toxic Waste, Low Dust	22 m ³	2018
363.	MSWI Jeju	S Tech Korea		KOR	Waste Incineration, Tail End	20 m ³	2018
364.	Qingdao MSWI	Shanghai Dingtu Environmental	Kangheng	CHN	Municipal Solid Waste Incinerator	71 m ³	2018
365.	Cixi Zhongmao MSWI 2nd phase	Shanghai Dingtu Environmental	Huaxing East	CHN	Municipal Solid Waste Incinerator	27 m ³	2018
366.	Colombes Ligne 2	Le Gaz Integral		FRA	Waste Incineration Tail End; Additional Delivery	5 m ³	2018
367.	Wenling MSWI	Shanghai Dingtu Environmental	Shanghai Zosum	CHN	Municipal Solid Waste Incinerator	56 m ³	2018
368.	Hongbaoli	Shanghai Dingtu Environmental	Shanghai Hoto	CHN	Municipal Solid Waste Incinerator	8 m ³	2019
369.	Soprano PCX	Hamon	Suez Environment	FRA	Chemical Waste Incinerator	23 m ³	2019
370.	MSWI San Sebastian Unit 1+2			ESP	Waste Incineration Tail End	38 m ³	2019
371.	Puyang MSWI	Shanghai Dingtu	Huaxing East	CHN	Waste Incineration, Tail End	32 m ³	2019
372.	Gaoantun Medical Waste	Shanghai Dingtu	Huaxing East	CHN	Medical Waste Incineration	13 m ³	2019
373.	Zhuji Bafang MSWI	Shanghai Dingtu Environmental	Zhejiang	CHN	Municipal Solid Waste Incinerator	16 m ³	2019